


NATIONAL AERONAUTICS AND SPACE ADMINISTRATION



(NASA-CR-151065) RESULTS OF PHASE CHANGE  
PAINT THERMAL MAPPING TEST OH46 USING THE  
0.006-SCALE MODEL 90-0 IN THE NASA LaRC  
VARIABLE DENSITY TUNNEL (Chrysler Corp.)  
277 p HC A13/MF A01


N77-21178

Unclas  
24457

CSSL 20D G3/16

SPACE SHUTTLE

AEROTHERMODYNAMIC DATA REPORT



JOHNSON SPACE CENTER

DATA MANAGEMENT services

March 1977

DMS-DR-2350  
NASA CR-151,065

RESULTS OF PHASE CHANGE PAINT  
THERMAL MAPPING TEST OH46 USING THE 0.006-SCALE  
MODEL 90-0 IN THE NASA LaRC  
VARIABLE DENSITY TUNNEL

by

J. W. Cummings and W. H. Dye  
Shuttle Aero Sciences  
Rockwell International Space Division

Prepared under NASA Contract Number NAS9-13247

by

Data Management Services  
Chrysler Corporation Michoud Defense-Space Division  
New Orleans, La. 70189

for

Engineering Analysis Division

Johnson Space Center  
National Aeronautics and Space Administration  
Houston, Texas

WIND TUNNEL TEST SPECIFICS:

Test Number: NASA LaRC VDT 4502-4601  
NASA Series Number: OH46  
Model Number: 90-0  
Test Dates: November 12 through 15 and December 4 through 7, 197  
Occupancy Hours: 64

FACILITY COORDINATOR:

B. Spencer, Jr.  
Mail Stop 365  
Langley Research Center  
Hampton, Va. 23665

Phone: (804) 827-3911

PROJECT ENGINEERS:

J. W. Cummings, W. H. Dye  
Mail Code AD38  
Rockwell International  
Space Division  
12214 Lakewood Blvd.  
Downey, Ca. 90241

Phone: (213) 922-2030

P. L. Lawing  
Mail Stop 160A  
Langley Research Center  
Hampton, Va. 23665


Phone: (804) 827-3294

DATA MANAGEMENT SERVICES:


Prepared by: Liaison--D. A. Sarver  
Operations--Maurice Moser, Jr.

Reviewed by: G. G. McDonald

Approved:

  
J. L. Glynn, Manager  
Data Operations

Concurrence:

  
N. D. Kemp, Manager  
Data Management Services

Chrysler Corporation Michoud Defense-Space Division assumes no responsibility for the data presented other than publication and distribution.

RESULTS OF PHASE CHANGE PAINT THERMAL MAPPING TEST OH46

USING THE 0.006-SCALE MODEL 90-0

IN THE NASA LaRC VARIABLE DENSITY TUNNEL

J. W. Cummings and W. H. Dye, Rockwell International Space Division

ABSTRACT

Results of Test OH46 are presented in this document. This test was conducted in the NASA LaRC Mach 8 Variable Density Tunnel during November and December 1973 to obtain thermal contours on a 0.006-scale model (no. 90-0) of the configuration 140B Space Shuttle Orbiter using the phase change paint technique. The model was tested at 25°, 30°, and 35° angle of attack at unit Reynolds numbers ranging from 1.0 through 8.0 million per foot. The model was tested with and without a ventral fin mounted on its bottom centerline. Elevon deflections of 0° and 10° and bodyflap deflections of 0 and 13.75° were investigated.



(This page left blank intentionally.)

## TABLE OF CONTENTS

	Page
ABSTRACT	iii
INDEX OF MODEL FIGURES	2
INDEX OF DATA FIGURES	3
NOMENCLATURE	9
CONFIGURATIONS INVESTIGATED	12
TEST FACILITY DESCRIPTION	14
TEST PROCEDURE	15
DATA REDUCTION	17
REFERENCE	20
TABLES	
I. TEST CONDITIONS	21
II. TEST PROGRAM	22
III. MODEL DIMENSIONAL DATA	27
FIGURES	
MODEL	36
DATA	45
APPENDIX - TABULATED THERMAL DATA FOR EACH TRACING CONTOUR	165

## INDEX OF MODEL FIGURES

Figure	Title	Page
1.	Axes System.	36
2.	Model Sketches	
a.	Configuration Designations	37
b.	Orbiter General Arrangement	38
c.	Ventral Fin	39
3.	Model Photographs	
a.	Grid Model	40
b.	Test Model	41
c.	Top View of All Models	42
d.	Bottom View of All Models With Leveling Blocks Installed.	43

# INDEX OF DATA FIGURES

Type of Sketch	Run number(s)	$\alpha$ (deg)	View	T <sub>Pc</sub> (°F)	RE/FT (million per ft.)	Page
Grid	4502-4525	30	Bottom	—	—	46
Thermal Control	4502	↓	↓	350	3.0	47
	4504			400	↓	48
	4505			350		49
	4506			250		50
	4507			300		51
	4508			300		52
	4509			300	1.0	53
	4510			300	↓	54
	4511			300		55
	4512			450	6.0	56
	4513			175	1.0	57
	4514			550	6.0	58
	4515			150	1.0	59
	4516			500	6.0	60
	4517			550	8.0	61
	4518			175	1.0	62
	4519			350	6.0	63
	4520			350	6.0	64
	4521			350	6.0	65
	4523			300	1.0	66
	4524			400	8.0	67
	4525			300	1.0	68

# INDEX OF DATA FIGURES (Continued)

Type of Sketch	Run Number(s)	$\alpha$ (deg)	View	$T_{pc}$ ( $^{\circ}F$ )	RE/FT (million per ft.)	Page
Grid	4526-4545	25	Bottom	—	—	69
Thermal Contour	4526	↓	↓	350	3.0	70
	4527			400	↓	71
	4528			400		72
	4529			250	↓	73
	4530			300		74
	4531			300	↓	75
	4532			450		76
	4533			300	1.0	77
	4534			550	6.0	78
	4535			500	6.0	79
	4536			250	1.0	80
	4537			300	1.0	81
	4538			300	6.0	82
	4539			175	1.0	83
	4540			550	8.0	84
	4541			350	6.0	85
	4542			150	1.0	86
	4543			350	6.0	87
	4544			175	1.0	88
	4545			400	8.0	89

# INDEX OF DATA FIGURES (Continued)

Type of Sketch	Run Number(s)	$\alpha$ (deg)	View	T <sub>pc</sub> (°F)	RE/FT (million per ft.)	Page
Grid	4546-4552	35	Bottom	—	—	90
Thermal Contour	4546	↓	↓	400	3.0	91
↓	4548	↓	↓	400	↓	92
↓	4549	↓	↓	250	↓	93
↓	4550	↓	↓	300	↓	94
↓	4551	↓	↓	450	↓	95
↓	4552	↓	↓	300	↓	96
Grid	4506-4522	30	Side	—	—	97
Thermal Contour	4506	↓	↓	250	3.0	98
↓	4513	↓	↓	175	1.0	99
↓	4519	↓	↓	350	6.0	100
↓	4522	↓	↓	150	3.0	101
Grid	4529	25	↓	—	—	102
Thermal Contour	4529	25	↓	250	3.0	103
Grid	4549-4552	35	↓	—	—	104
Thermal Contour	4549	↓	↓	250	3.0	105
↓	4550	↓	↓	300	3.0	106
↓	4551	↓	↓	450	6.0	107
↓	4552	↓	↓	300	3.0	108

# INDEX OF DATA FIGURES (Continued)

Type of Sketch	Run Number(s)	$\alpha$ (deg)	View	T <sub>pc</sub> (°F)	RE/FT (million per ft.)	Page
Grid	4556-4567	35	Bottom			109
Thermal Contour	4556			250	1.0	110
	4557			300	1.0	111
	4558			500	6.0	112
	4559			550	8.0	113
	4560			550	6.0	114
	4561			175	1.0	115
	4562			300	6.0	116
	4563			175	1.0	117
	4565			350	6.0	118
	4567			400	6.0	119
Grid	4568-4601	30				120
Thermal Contour	4568			550	8.0	121
	4569			550	3.5	122
	4570			400	8.0	123
	4571			400	3.5	124
	4572			400	4.0	125
	4573			300	1.0	126
	4574			300	4.0	127
	4575			200	1.0	128
	4577			350	1.0	129
	4579			200	1.0	130
	4581			500	3.0	131
	4582			300	3.0	132

# INDEX OF DATA FIGURES (Continued)

Type of Sketch	Run number(s)	$\alpha$ (deg)	View	T <sub>pc</sub> (°F)	RE/FT (million per ft.)	Page
Thermal Contour	4583	30	Bottom	550	6.0	133
	4584			350	6.0	134
	4586			450	3.0	135
	4588			250	3.0	136
	4590			550	6.0	137
	4591			400	6.0	138
	4592			550	8.0	139
	4593			400	8.0	140
	4594			300	1.0	141
	4595			400	3.0	142
	4596			550	6.0	143
	4597			200	1.0	144
	4598			300	1.0	145
	4599			450	3.0	146
	4600			200	1.0	147
	4601			300	3.0	148
Grid Thermal Contour	4556-4593	30&35	Side	—	—	149
	4556	35		250	1.0	150
	4557			300	1.0	151
	4558			500	6.0	152
	4561			175	1.0	153
	4562			300	6.0	154
	4564			175	3.0	155
	4565			350	6.0	156
	4569	30		350	3.5	157



# INDEX OF DATA FIGURES (Concluded)

Type of Sketch	Run number(s)	$\alpha$ (deg)	View	T <sub>pc</sub> (°F)	RE/FT (million per ft.)	Page
Thermal Contour	4570	30	Side	400	8.0	158
	4573			300	1.0	159
	4574			300	4.0	160
	4584			350	6.0	161
	4586			450	3.0	162
	4588			250	3.0	163
	4593			400	8.0	164

# NOMENCLATURE

<u>SYMBOL</u>	<u>Mnemonic</u>	<u>Definition</u>
$C_p$		specific heat at constant pressure of model material, BTU/lb.-°F
$C_{p_{air}}$		specific heat at constant pressure of air, BTU/lb.-°F
$g$		acceleration due to gravity, ft./sec <sup>2</sup>
$h$	H	thin film heat transfer coefficient at a given paint melt line on the model, BTU/ft <sup>2</sup> -sec-°F
$h_s, h_{ref}$	HS	stagnation thin film heat transfer coefficient on a scaled foot radius sphere, reference value, BTU/ft <sup>2</sup> -sec-°F
$K$		thermal conductivity of model material, BTU/ft-sec-°F
$K_{air}$		thermal conductivity of air, BTU/ft-sec-°F
$M_\infty$	MINF	freestream Mach number
$N_R$		nose radius, ft.
OML		outer mold line
$P_o, P_{Total}$	PT	stagnation pressure, psf
$P_1$		pressure upstream of normal shock, psf
$P_2$		pressure behind normal shock, psf
$P_r$		Prandtl number
$\dot{q}$		heat transfer rate, BTU/ft <sup>2</sup> -sec
$\dot{q}_s$		stagnation heat transfer rate on scaled 1 foot radius sphere, reference value, BTU/ft <sup>2</sup> -sec
$R$		gas constant for air, $\frac{ft-lb_F}{lb_m-°R}$

# NOMENCLATURE (Continued)

<u>Symbol</u>	<u>Mnemonic</u>	<u>Definition</u>
$R_{\infty}/ft,$ $R_e/ft$	R/FT, RE/FT SQROCK	freestream unit Reynolds number, million per foot square root of $\rho C_p K$ , BTU/ft <sup>2</sup> -°F-sec <sup>.5</sup>
t	T	time, sec
$T_{aw}$	TAW	adiabatic wall temperature, °F
$T_{IN}, T_I$	TIN	initial model wall temperature, °F
$T_o, T_{Total}$	TO	freestream stagnation temperature, °F
$T_{PC}$	TPC	temperature at which paint changes phase, °F
$\bar{T}$	T-BAR	nondimensional temperature parameter defined in context
$V_e$		velocity at edge of boundary layer, ft/sec
x		longitudinal streamwise coordinate, ft.
$x_o$		Orbiter longitudinal coordinate, in.
$y_o$		Orbiter lateral coordinate, in.
$z_o$		Orbiter vertical coordinate, in.
$\alpha$	ALPHA	angle of attack, deg.
$\beta$	BETA	temperature parameter or sideslip angle in degrees as defined in context
$\delta$		local model surface deflection angle to freestream flow, deg.
$\delta_{BF}$		body flap deflection angle, deg.
$\delta_e$		elevon deflection angle, deg.

# NOMENCLATURE (Concluded)

<u>Symbol</u>	<u>Mnemonic</u>	<u>Definition</u>
$\delta_v$		ventral fin deflection angle, deg.
$\gamma$		ratio of specific heats of air
$\theta$		local surface angle with respect to fuselage reference line (axis), deg.
$\phi$	PHI	model roll angle, deg.
$\rho$		density of model material, lb/ft <sup>3</sup>
$\rho_{air}$		freestream density of air, lb/ft <sup>3</sup>
$\rho_s$		stagnation air density lb/ft <sup>3</sup>
$\rho_w$		air density along model wall, lb/ft <sup>3</sup>
$\mu_{air}$		freestream air viscosity, lbm/ft.-sec
$\mu_s$		air stagnation viscosity, lbm/ft.-sec
$\mu_w$		air viscosity along model wall, lbm/ft.-sec

## CONFIGURATIONS INVESTIGATED

The models were 0.006-scale representations of the VL70-000140B Space Shuttle Orbiter Configuration. They were cast in a single piece around an aluminum and fiber glass sleeve using Grumman Aerospace Material G. A metal cap was put on the nose of each test model to protect it in the high Reynolds number environment in the tunnel. Three (3) test models and one (1) grid model were used. They were identified as follow:

<u>Designation</u>	<u>Type</u>	<u><math>\delta_e</math></u>	<u><math>\delta_{BF}</math></u>
-22	Test	0°	0°
-31	Test	+10°	0°
-41	Test	+10°	+13°
Grid or -21	Grid	0°	0°

Each test model had two ventrals which were mounted on its body flap bottom centerline. The ventrals were at either 0° or 30° incidence to freestream flow. Ventrals are designated as:

<u>Designation</u>	<u><math>\delta_v</math></u>
VEN0	0°
VEN30	30°

The models were tested both with and without ventrals.

The model components correspond to the following Orbiter component nomenclature:

<u>Component Nomenclature</u>	<u>Description</u>
B <sub>26</sub>	fuselage

# CONFIGURATIONS INVESTIGATED (Concluded)

<u>Component Nomenclature</u>	<u>Description</u>
C <sub>9</sub>	canopy
F <sub>8</sub>	body flap
L <sub>6</sub>	ventral fin
M <sub>7</sub>	OMS pod
R <sub>5</sub>	rudder
V <sub>8</sub>	vertical tail
W <sub>116</sub>	wing

Table III provides dimensional data for each model component. Figure 2 presents sketches of the model. Figure 3 presents photographs of the model.

## TEST FACILITY DESCRIPTION

The Langley Mach 8 Variable-Density Hypersonic Tunnel is located in Building 1247D and is under the direction of the Aero-Physics Division. This tunnel is used for fundamental aerodynamic and fluid dynamic investigations over large Reynolds number ranges using pressure and heat transfer measurements. The test medium is air and is heated by a combination of Dowtherm and electrical resistance. Model mounting consists of sting mount with injection mechanism. The tunnel has an axially symmetric contoured nozzle. The test section diameter is 18 inches with a core of 4 to 14 inches depending on pressure. It exhausts into a vacuum tank or the atmosphere.

Examples of operating conditions are as follows:

Stagnation pressure (psia) .....15 to 2930

Stagnation temperature (°R).....1160 to 1510

Mach Number .....7.5 to 8.0

Reynolds number per foot(1/ft)..... $0.1 \times 10^6$  to  $12.0 \times 10^6$

Running time (SEC) for

Exhausting into vacuum tank—90

Exhausting into atmosphere — 600

## TEST PROCEDURE

The general test procedures used during the test were as follows:

- 1) Prior to each run, the models were cleaned with solvent, dried and spray painted with predetermined paint, and installed inverted in the injection chamber.
- 2) The initial model temperature was measured and recorded by a contact thermometer placed against the test model.
- 3) After flow was established, two 35mm cameras were activated. The model was then injected into the flow stream. This process enabled the film reader to determine the exact time the model reached tunnel centerline. Continuous pictures were taken at a constant frame rate of 10 frames per second. Time duration for each run was determined by tunnel operating conditions and paint melt temperatures but usually averaged about 10 to 12 seconds. The model was retracted from the flow stream at the end of this time period.
- 4) The model was then removed from the injection chamber and more detailed photographs were taken of areas of interest which were not clearly defined on the 35mm cameras.
- 5) After each model attitude change, the paint stripe model was installed in the tunnel and photographed with the 35mm cameras. The paint stripe model clearly locates various X/L (body) locations as well as particular water planes and chord wise and span wise locations of the wing which would normally be difficult to locate with attitude changes by tracings made using



### TEST PROCEDURE (Concluded)

an overhead projector. These tracings are presented in the data figures.

- 6) This procedure was repeated for each configuration, test condition, and paint temperature.
- 7) Resulting photographs of both melt lines and grid models were traced onto paper using an overhead projector table. Resulting tracings are presented in the data figures.

Table.II describes the test program.

# DATA REDUCTION

Thin film coefficients were calculated for each melt line. Adiabatic wall temperature was calculated as:

$$\begin{aligned} T_{aw} &= T_o \left( \frac{T_{aw}}{T_o} \right) \\ &= T_o [0.876 + 0.133(\sin\delta)^{1.55}] \end{aligned}$$

where:

$$\begin{aligned} \delta &= \alpha + \theta \\ &= \text{local surface angle to freestream flow, deg.} \end{aligned}$$

The temperature parameter,  $\beta$ , was then calculated by an solution of the following equation:

$$1 - \bar{T} = e^{\beta^2} (1 - \text{erf } \beta)$$

where:

$$\bar{T} = \frac{T_{PC} - T_{IN}}{T_{aw} - T_{IN}}$$

Thin film coefficients were then calculated:

$$h = \frac{\beta \sqrt{K\rho C_p}}{\sqrt{t}}$$

and heat transfer rates were calculated as:

$$\dot{q} = h (T_{aw} - T_{PC})$$

Reference thin film coefficients were calculated for a scaled 1 foot full scale radius sphere using the Faye-Riddell method:

# DATA REDUCTION (Continued)

$$h_s = \frac{.768 C_p}{(P_r)^{.6}} (\rho_w \mu_w)^{.1} (\rho_s \mu_s)^{.4} \sqrt{\frac{dV_e}{dx}}$$

where:

$$P_r = \frac{\mu_{air} C_{p_{air}}}{K_{air}}$$

$$\frac{dV_e}{dx} = \frac{1}{N_R} \sqrt{2Rg T_0 \left[ 1 - \frac{1}{P_1 P_2} \right]}$$

$$P_1 = \left[ \frac{\gamma+1}{2} M_\infty^2 \right]^{\frac{\gamma}{\gamma-1}}$$

$$P_2 = \left[ \frac{\gamma+1}{2\gamma M_\infty^2 - (\gamma-1)} \right]^{\frac{1}{\gamma-1}}$$

$$g = 32.2 \frac{\text{lbm ft}}{\text{lb}_f \text{ Sec}^2}$$

$$N_R = 0.006 \text{ ft}$$

$$R = 53.35 \frac{\text{ft} \cdot \text{lb}_f}{\text{lbm} \cdot ^\circ\text{R}}$$

Stagnation heat transfer rate was then calculated as:

$$\dot{q}_s = h_s (T_{aw} - T_{PC})$$

Resulting values of  $h$ ,  $h/h_s$ ,  $T$ ,  $\beta$ , and  $T_{aw}/T_0$  are tabulated in the appendix as a function of model time on tunnel centerline. Each time for which these values are given is indexed by a sequential number called

## DATA REDUCTION (Concluded)

"Contour." Tracings given in the data figures are identified by a frame number which is not necessarily consecutive. The lowest valued frame number corresponds to data given for Contour 1. The highest valued frame number corresponds to the largest contour number. Intermediate frame and contour numbers are similarly matched in order of increasing numbers. The first data figure presents 60th frame and contour numbers as an example of how they are matched.

#### REFERENCE

1. Cummings, J. W., "Pretest Report For Phase Change Paint Test On 0.006-Scale Models of the Rockwell International Space Shuttle Orbiter in the NASA-LRC Variable Density Wind Tunnel-(OH46)", Rockwell International Report No. SD73-SH-0265, September 27, 1973.

TABLE I.

[illegible]

### TABLE II. - TEST PROGRAM

[illegible]

TABLE II. - TEST PROGRAM (Continued)

Run No.	VDT Tun No.	Config.	$\alpha$	RE/FT $\times 10^{-6}$	T <sub>pc</sub> °F	T <sub>i</sub> °F	T <sub>o</sub> °F	P <sub>o</sub> psig	Run Time	Remarks
19	4520	-22	30	6.0	350	82	940	1405	10.5	Check focus
20	4521	-41	↓	↓	350	81	925	1390	10.3	
21	4522	-22	↓	3.0	150	81	850	625	15.2	Side painted only
22	4523	-31	↓	1.0	300	82	775	165	16.7	Repeat of 4510
23	4524	-22	↓	8.0	400	83	925	1935	10.5	
24	4525	-41	30	1.0	300	82	770	163	16.3	Repeat 4510
Grid Model		-21	25	←-----→						Reset cameras
25	4526	-22	↓	3.0	350	77	890	625	13.6	
26	4527	-31	↓	↓	400	81	880	625	13.9	
27	4528	-41	↓	↓	400	82	880	635	13.6	
28	4529	-22	↓	↓	250	81	875	635	13.5	
29	4530	-31	↓	↓	300	83	885	630	13.2	
30	4531	-41	↓	↓	300	82	865	625	13.1	
31	4532	-22	↓	6.0	450	83	955	1400	10.4	
32	4533	-31	↓	1.0	300	83	760	164	13.9	No side camera
33	4534	-41	↓	6.0	550	83	950	1400	10.5	
34	4535	-31	↓	↓	500	84	940	1400	10.4	
35	4536	-22	↓	1.0	250	83	745	160	13.7	
36	4537	-41	↓	↓	350	82	735	156	13.6	
37	4538	-22	↓	6.0	300	82	940	1405	10.5	
38	4539	-31	↓	1.0	175	82	770	150	13.5	



TABLE II. - TEST PROGRAM (Continued)

Run No.	VDT Run No.	Config.	$\alpha$	RE/FT $\times 10^{-6}$	T <sub>pc</sub> °F	T <sub>i</sub> °F	T <sub>o</sub> °F	P <sub>o</sub> psig	Run Time	Remarks
39	4540	-22	25	8.0	550	82	935	1935	10.3	
40	4541	-41	↓	6.0	350	84	950	1400	10.5	
41	4542	-22	↓	1.0	150	85	780	152	13.7	
42	4543	-31	↓	6.0	350	85	980	1390	10.6	
43	4544	-41	↓	1.0	175	82	820	160	13.5	
44	4545	-22	↓	8.0	400	82	940	1930	10.4	
Grid Model		-21	35	←-----→						
24 45	4546	-31	↓	3.0	400	83	850	625	10.6	
46	4547	-22	↓	↓	350	82	860	620	10.4	
47	4548	-41	35	3.0	400	82	865	655	13.8	
48	4549	-22	↓	↓	250	84	875	635	17.1	
49	4550	-31	↓	↓	300	82	885	630	17.7	
50	4551	-22	↓	6.0	450	82	950	1375	12.4	
51	4552	-41	↓	3.0	300	81	865	660	16.6	
52	4553	-31	↓	1.0	175					
53	4556	22	35	1	250	76	840	157	*	
54	4557	41	↓	1	300	73	815	157	↓	
55	4558	31	↓	6	500	74	955	1435	↓	
56	4559	22	↓	8	550	76	965	1960	↓	
57	4560	41	↓	6	550	74	970	1410	↓	
58	4561	31	↓	1	175	78	815	146	↓	

\* Run times for run numbers 53 through 98 are unavailable.

TABLE II. - TEST PROGRAM (Continued)

Run No.	VDT Run No.	Config.	$\alpha$	RE/FT $\times 10^{-6}$	T <sub>pc</sub> °F	T <sub>i</sub> °F	T <sub>o</sub> °F	P <sub>o</sub> psig	Run Time	Remarks
59	4562	22	35	6	300	81	965	1380	↓	
60	4563	41	↓	1	175	76	785	151		
61	4564	22		3	175	79	930	645		
62	4565	31		6	350	78	975	1455		
63	4566	22		1	150	77	825	161		
64	4567	41	↓	6	400	77	965	1450		
65	4568	31	30	8	550	80	980	1915		
66	4569	22	↓	3.5	350	79	930	780		
67	4570	31		8	400	82	990	1870		
68	4571	22		3.5	400	88	825	775		
69	4572	22		4	400	83	880	900		
70	4573	31 ven 0		1	300	84	750	153		
71	4574	22		4	300	79	915	855		
72	4575	31 ven 0		1	200	76	825	172		
73	4576	22		3	oil	oil	875	610		
74	4577	31 ven 30		1	350	76	795	150		
75	4578	22		6	oil	oil	935	1400		
76	4579	31 ven 30		1	200	76	765	156		
77	4580	22	↓	6	oil	oil	965	1470	↓	
78	4581	31 ven 30	30	3	500	80	895	625		
79	4582	31 ven 30	↓	3	300	79	880	620		

TABLE II. - TEST PROGRAM (Concluded)

Run No.	VDT Run No.	Config.	$\alpha$	RE/FT $\times 10^{-6}$	$T_{pc}$ °F	$T_i$ °F	$T_o$ °F	$P_o$ psig	Run Time	Remarks
80	4583	31 ven 30	30	6	550	80	970	1430	↓	
81	4584	31 ven 30		6	350	82	985	1405		
82	4585	22		3	oil	oil	950	1400		
83	4586	31 ven 0		3	450	82	900	630		
84	4587	22		6	oil	oil	945	1435		
85	4588	31 ven 0		3	250	82	905	635		
86	4589	22		3	oil	oil	920	635		
87	4590	31 ven 0		6	550	76	960	1385		
88	4591	31 ven 0		6	400	79	950	1390		
89	4592	31 ven 0		8	550	79	965	1895		
90	4593	31 ven 0		8	400	79	955	1895		
91	4594	41		1	300	76	755	152		
92	4595	41		3	400	76	880	630		
93	4596	41		6	550	74	940	1380		
94	4597	41		1	200	77	765	163		
95	4598	41 ven 30		1	300	76	780	145		
96	4599	41 ven 30		3	450	75	900	635		
97	4600	41 ven 30		1	200	76	805	163		
98	4601	41 ven 30		3	300	76	920	650		

TABLE III. - MODEL DIMENSIONAL DATA

MODEL COMPONENT: BODY - B<sub>26</sub>

GENERAL DESCRIPTION: Orbiter Fuselage Configuration T40A/B

NOTE: B<sub>26</sub> identical to B<sub>24</sub> except underside of fuselage refaired to accept W116.

Model Scale = 0.006

DRAWING NUMBER: VL70-000193

VL70-000140A

<u>DIMENSIONS:</u>	<u>FULL-SCALE</u>	<u>MODEL SCALE</u>
Length (Body Fwd Sta X <sub>0</sub> =235) - in	<u>1293.3</u>	<u>7.759</u>
Max. Width (at X <sub>0</sub> -1520) - in	<u>262.0</u>	<u>1.572</u>
Max. Depth (at X <sub>0</sub> = 1464) - in.	<u>250.0</u>	<u>1.500</u>
Fineness Ratio	<u>0.26357</u>	<u>0.26357</u>
Area - ft <sup>2</sup>		
Max. Cross-Sectional.	<u>340.88462</u>	<u>.01227</u>

TABLE III. - Continued

MODEL COMPONENT: Canopy (C9)

GENERAL DESCRIPTION: Configuration 140B

Model Scale = 0.006

DRAWING NUMBER: VL70-000140B

VL70-000143A

DIMENSIONS:

FULL-SCALE

MODEL-SCALE

Length ( $X_0=434.643$  to  $670.0$ )

235.357

1.412

Max Width @ $X_0 = 513.127$ )

152.412

.914

Max Depth @ $X_0 = 485.0$ )

25.00

.150

TABLE III. - Continued

MODEL COMPONENT: Body Flap - F8GENERAL DESCRIPTION: Configuration 4 body flapModel Scale = 0.006DRAWING NUMBER: VL70-000140BVL70-000200

<u>DIMENSION:</u>	<u>FULL-SCALE</u>	<u>MODEL SCALE</u>
Length in.	<u>84.7</u>	<u>.508</u>
Max Width in.	<u>262.308</u>	<u>1.574</u>
Max Depth in.	<u>23.000</u>	<u>.138</u>
Area - ft <sup>2</sup>		
Planform	<u>158.85350</u>	<u>.0057</u>
Wetted	<u>                    </u>	<u>                    </u>
Base	<u>41.89642</u>	<u>.00151</u>

TABLE III. - Continued

MODEL COMPONENT: Ventral Fin - L<sub>6</sub>GENERAL DESCRIPTION: Single ventral fin located on lower surface of  
body flap at model centerline.Model Scale = 0.006

<u>DIMENSIONS:</u>	<u>FULL-SCALE</u>	<u>MODEL SCALE</u>
Span, in.	<u>52.3</u>	<u>0.314</u>
Chords, in	<u></u>	<u></u>
root	<u>80.5</u>	<u>0.483</u>
tip	<u>50.5</u>	<u>0.303</u>
m.a.c.	<u>74.35</u>	<u></u>
Taper ratio	<u>0.627</u>	<u>0.627</u>
Aspect Ratio	<u>0.79</u>	<u>0.79</u>
Planform area, ft <sup>2</sup>	<u>23.8</u>	<u>0.0008569</u>
Airfoil		
Leading edge radius, in.	<u>6.0</u>	<u>0.036</u>
Max thickness, in.	<u>25.33</u>	<u>0.152</u>
Sweep Angle, deg.		
Leading edge	<u>30</u>	<u>30</u>
Trailing edge	<u>0</u>	<u>0</u>

TABLE III. - Continued.

MODEL COMPONENT: OMS Pod - M<sub>7</sub>

GENERAL DESCRIPTION: Configuration 140B Orbiter OMS Pod

Model Scale = 0.006

DRAWING NUMBER:

DIMENSIONS	FULL-SCALE	MODEL SCALE
Length (Fwd Sta $X_0=1233.0$ in)	<u>327.000</u>	<u>1.962</u>
Max Width (@ $X_0=1450.0$ ) - in.	<u>94.50</u>	<u>.567</u>
Max Depth (@ $X_0=1493.0$ ) - in.	<u>109.000</u>	<u>.654</u>



# MODEL DIMENSIONAL DATA- Continued.

MODEL COMPONENT : RUDDER - R5

GENERAL DESCRIPTION : 2A, 3 and 3A Configuration per Rockwell Lines

VL70-000095

Model Scale = 0.006

DRAWING NUMBER : VL70-000095

## DIMENSIONS :

	FULL-SCALE	MODEL SCALE
Area - FT <sup>2</sup>	<u>106.38</u>	<u>.0038</u>
Span (equivalent)	<u>201.0</u>	<u>1.206</u>
Inb'd equivalent chord	<u>91.585</u>	<u>.549</u>
Outb'd equivalent chord	<u>50.833</u>	<u>.304</u>
Ratio movable surface chord/ total surface chord	<u></u>	<u></u>
At Inb'd equiv. chord	<u>0.400</u>	<u>0.400</u>
At Outb'd equiv. chord	<u>0.400</u>	<u>0.400</u>
Sweep Back Angles, degrees	<u></u>	<u></u>
Leading Edge	<u>34.83</u>	<u>34.83</u>
Trailing Edge	<u>26.25</u>	<u>26.25</u>
Hingeline	<u>34.83</u>	<u>34.83</u>
Area Moment (Normal to hinge line)-FT <sup>3</sup>	<u>526.13</u>	<u>0.189</u>
Product of Area and Mean Chord		

TABLE III. - Continued.

MODEL COMPONENT: Vertical Tail - V8GENERAL DESCRIPTION: Configuration 140B Orbiter Vertical TailNOTE: Similar to V5 with radius of T.E. upper corner and L.E. corner  
where vertical meets fuselage.Model Scale = 0.006DRAWING NUMBER: VL70-000140B

<u>DIMENSIONS:</u>	<u>FULL-SCALE</u>	<u>MODEL SCALE</u>
<u>TOTAL DATA</u>		
Area (Theo) Ft <sup>2</sup>	<u>413.253</u>	<u>.0148</u>
Planform		
Span (Theo) In	<u>315.72</u>	<u>1.894</u>
Aspect Ratio	<u>1.675</u>	<u>1.675</u>
Rate of Taper	<u>0.507</u>	<u>0.507</u>
Taper Ratio	<u>0.404</u>	<u>0.404</u>
Sweep Back Angles, Degrees		
Leading Edge	<u>45.00</u>	<u>45.00</u>
Trailing Edge	<u>25.947</u>	<u>25.947</u>
.025 Element Line	<u>41.130</u>	<u>41.130</u>
Chords:		
Root (Theo) WP	<u>268.500</u>	<u>1.611</u>
Tip (Theo) WP	<u>108.470</u>	<u>0.651</u>
MAC	<u>199.807</u>	<u>1.198</u>
Fus. Sta. of .25 MAC	<u>1463.50</u>	<u>8.781</u>
W. P. of .25 MAC	<u>635.52</u>	<u>3.813</u>
B. L. of .25 MAC	<u>0.00</u>	<u>0.00</u>
Airfoil Section		
Leading Wedge Angle Deg	<u>10.00</u>	<u>10.00</u>
Trailing Wedge Angle Deg	<u>14.920</u>	<u>14.92</u>
Leading Edge Radius	<u>2.00</u>	<u>2.00</u>
Void Area	<u>13.17</u>	<u>13.17</u>
Blanketed Area	<u>0.0</u>	<u>0.00</u>

TABLE III. - Continued

MODEL COMPONENT: WING W<sub>116</sub>GENERAL DESCRIPTION: Configuration 4NOTE: Identical to W<sub>114</sub> except airfoil thickness. Dihedral angle is along trailing edge of wing.

Model Scale = 0.006

DRAWING NUMBER: VL70-000140BVL70-000200

<u>DIMENSIONS:</u>	<u>FULL-SCALE</u>	<u>MODEL SCALE</u>
<u>Total Data</u>		
Area (Theo.) Ft <sup>2</sup>		
Planform	<u>2690.00</u>	<u>.09684</u>
Span (Theo In)	<u>936.6816</u>	<u>5.620'</u>
Aspect Ratio	<u>2.265</u>	<u>2.265</u>
Rate of Taper	<u>1.177</u>	<u>1.177</u>
Taper Ratio	<u>0.200</u>	<u>0.200</u>
Dihedral Angle, degrees (at X <sub>0</sub> =1506.623, Y <sub>0</sub>	<u>3.500</u>	<u>3.500</u>
Incidence Angle, degrees 105, Z <sub>0</sub> =282.75)	<u>0.500</u>	<u>0.500</u>
Aerodynamic Twist, degrees	<u>+3.000</u>	<u>+3.000</u>
Sweep Back Angles, degrees		
Leading Edge	<u>45.00</u>	<u>45.00</u>
Trailing Edge	<u>-10.056</u>	<u>-10.056</u>
0.25 Element Line	<u>35.209</u>	<u>35.209</u>
<u>Chords:</u>		
Root (Theo) B.P. = zero	<u>689.2429</u>	<u>4.135</u>
Tip, (Theo) B.P.	<u>137.8486</u>	<u>.827</u>
MAC	<u>474.8117</u>	<u>2.849</u>
Fus. Sta. of .25 MAC	<u>1126.721</u>	<u>6.760</u>
W.P. of .25 MAC	<u>291.00</u>	<u>1.746</u>
B.L. of .25 MAC	<u>187.33491</u>	<u>1.124</u>
<u>Exposed Data</u>		
Area, (Theo) Ft <sup>2</sup>	<u>1812.2205</u>	<u>.0652</u>
Span, (Theo) In. BP108	<u>736.6816</u>	<u>4.420</u>
Aspect Ratio	<u>2.058</u>	<u>2.058</u>
Taper Ratio	<u>0.2451</u>	<u>0.2451</u>
<u>Chords</u>		
Root BP108	<u>570.6230</u>	<u>3.424</u>
Tip 1.00 b	<u>137.8512</u>	<u>.827</u>
2		
MAC	<u>354.2376</u>	<u>2.1254</u>
Fus. Sta. of .25 MAC	<u>1164.237</u>	<u>6.985</u>
W.P. of .25 MAC	<u>292.00</u>	<u>1.752</u>
B.L. of .25 MAC	<u>239.67786</u>	<u>1.438</u>
<u>Airfoil Section (Rockwell Mod NASA)</u>		
<u>XXXX-64</u>		
Root $\frac{b}{2} = 0.425$	<u>0.113</u>	<u>0.113</u>
Tip $\frac{b}{2} = 1.00$	<u>0.12</u>	<u>0.12</u>

TABLE III. - Concluded.

MODEL COMPONENT: W116

	<u>FULL-SCALE</u>	<u>MODEL SCALE</u>
Data for (1) of (2) Sies		
Planform Area Ft <sup>2</sup>	<u>118.33</u>	<u>.00426</u>
Leading Edge Intersect Fus M. L. @ Sta	<u>505.0</u>	<u>3.030</u>
Leading Edge Intersects Wing @ Sta	<u>1003.5</u>	<u>6.021</u>





Figure 1. - Axes System.



a. Configuration Designations

Figure 2. - Model Sketches.

Technical drawing of a ship's hull cross-section. The drawing shows a central vertical axis and a horizontal dimension line at the bottom indicating a width of 936.68. The hull is symmetrical about the vertical axis. The drawing includes a central vertical axis and a horizontal dimension line at the bottom indicating a width of 936.68. The hull is symmetrical about the vertical axis. The drawing includes a central vertical axis and a horizontal dimension line at the bottom indicating a width of 936.68.

Figure 2. - Continued.





Figure 2. - Concluded.






a. Grid Model


Figure 3. - Model Photographs.





b. Test Model


Figure 3. - Continued.



c. Top View of All Models

Figure 3. - Continued.





d. Bottom View of All Models With Leveling Blocks Installed


Figure 3. - Concluded.

## DATA FIGURES

Notes: On data figures,  $P_{total}$  value is given as psig and  $T_{total}$  value as °F. These values agree with those in Table II and with those in the appendix, which are given as psia and °R.

Data figures are tracings of thermal contours made from frames of photographs taken during the test. Thermal characteristics associated with each tracing are given in the appendix. See Data Reduction section for relationship between index number on each tracing and contour number in the appendix.

# PHASE CHANGE PAINT TEST




ISOTHERM	h	h/h <sub>ref</sub>	h/h <sub>r=1'</sub>	N <sub>St, ∞</sub>
1				
2				
3				
4				
5				
6				
7				
8				
9				
10				

CONFIGURATION	GRID
FACILITY	LaRC/VDT
TEST	OH46
RUNS	4502 thru 4525
LENGTH	
NOSE RADIUS	
SCALE	
M <sub>∞</sub>	
P <sub>total</sub> (psia) =	
T <sub>total</sub> (°R) =	
R <sub>∞</sub> / ft =	
T <sub>aw</sub> / T <sub>total</sub> =	
T <sub>aw</sub> (°R) =	
T <sub>i</sub> (°F) =	
T <sub>pc</sub> (°F) =	
h <sub>r=1'</sub> =	
T <sub>r=1'</sub> =	
(ρC <sub>p</sub> k) <sup>1/2</sup> =	
α =	30
β =	
Φ =	
CAMERA POSITION	BOTTOM VIEW
Engineer	
	CFFS-HVD

4.

PHASE CHANGE PAINT TEST


RUN 4502



ISOTHERM CONTOUR NO.	h	h/h <sub>ref</sub>	h/h <sub>r=1</sub>	N <sub>St,∞</sub>	FRAME NO.
1					13
2					21
3					29
4					39
5					61
6					79
7					84
8					91
9					126
10					130

CONFIGURATION	140B. N <sup>V</sup>
FACILITY	LRC/VOT
TEST	OH-46
RUN	4502
LENGTH	
NOSE RADIUS	
SCALE	.006
M <sub>∞</sub>	8
P <sub>total</sub> (psia)	620
T <sub>total</sub> (°R)	915 °F
R <sub>∞</sub> /ft	3.0(10 <sup>6</sup> )
T <sub>aw</sub> /T <sub>total</sub>	
T <sub>aw</sub> (°R)	
T <sub>f</sub> (°F)	72
T <sub>pc</sub> (°F)	350
h <sub>f</sub>	
T	
(P.C.K)/2	
α	30°
β	
φ	
CAMERA POSITION	Bottom
Engineer	
	CFFS-HVD

# PHASE CHANGE PAINT TEST




ISOTHERM	h	h/h <sub>ref</sub>	h/h <sub>r=1'</sub>	N <sub>St, ∞</sub>
1				
2				
3				
4				
5				
6				
7				
8				
9				
10				

CONFIGURATION	41
FACILITY	LRC/VDT
TEST	04-46
RUN	4504
LENGTH	
NOSE RADIUS	
SCALE	.006
M <sub>∞</sub>	8
P <sub>total</sub> (psia)	625
T <sub>total</sub> (°R)	850
R <sub>∞</sub> / ft	3(106)
T <sub>aw</sub> / T <sub>total</sub>	
T <sub>aw</sub> (°R)	
T <sub>i</sub> (°F)	76
T <sub>pc</sub> (°F)	400
h <sub>r=1'</sub>	
T	
(ρC <sub>p</sub> k) <sup>1/2</sup>	
α	30
β	
Φ	
CAMERA POSITION	Bottom
Engineer	
	CFFS-HVD




PHASE CHANGE PAINT TEST



ISOTHERM	h	h/h <sub>ref</sub>	h/h <sub>r=1'</sub>	N <sub>St,∞</sub>
1				
2				
3				
4				
5				
6				
7				
8				
9				
10				

CONFIGURATION	-31
FACILITY	LRC/VDT
TEST	OH-46
RUN	4505
LENGTH	
NOSE RADIUS	
SCALE	.006
M <sub>∞</sub>	8
P <sub>total</sub> (psia)	= 630
T <sub>total</sub> (°R)	= 875
R <sub>∞</sub> / ft	= 3(10 <sup>4</sup> )
T <sub>aw</sub> / T <sub>total</sub>	
T <sub>aw</sub> (°R)	
T <sub>i</sub> (°F)	= 82
T <sub>pc</sub> (°F)	= 350
h <sub>ref</sub>	
T̄	
(ρC <sub>p</sub> k) <sup>1/2</sup>	
α	= 30
β	
Φ	
CAMERA POSITION	Bottom
Engineer	
	CFFS-HVD


# PHASE CHANGE PAINT TEST



ISOTHERM	h	h/h <sub>ref</sub>	h/h <sub>r=1</sub>	N <sub>St,∞</sub>
1				
2				
3				
4				
5				
6				
7				
8				
9				
10				

CONFIGURATION	-22
FACILITY	LRC/VDT
TEST	OH-46
RUN	4506
LENGTH	
NOSE RADIUS	
SCALE	1006
M <sub>∞</sub>	= 8
P <sub>total</sub> (psia)	= 645
T <sub>total</sub> (°R)	= 905
R <sub>∞</sub> / ft	=
T <sub>aw</sub> / T <sub>total</sub>	=
T <sub>aw</sub> (°R)	=
T <sub>i</sub> (°F)	= 80
T <sub>pc</sub> (°F)	= 250
(P <sub>c</sub> k) <sup>1/2</sup>	
α	= 30
β	=
Φ	=
CAMERA POSITION	Bottom
Engineer	
	CFFS-HVD

ORIGINAL PAGE 10  
POOR QUALITY



ISOTHERM	$h$	$h/h_{ref.}$	$h/h_{r=1'}$	$N_{St, \infty}$
1				
2				
3				
4				
5				
6				
7				
8				
9				
10				

FACILITY	-K-100T
----------	---------

TEST	OH-46
------	-------

RUN 4507

LENGTH

NOSE RADIUS

SCALE 1006

M <sub>∞</sub>	8
----------------	---

$P_{\text{total}}$  (psia) = 625

$$T_{\text{total}} (^{\circ}\text{R}) = 880$$
$$R_{\infty} / \text{ft} = 3.0 (10^6)$$
$$T_{aw} / T_{total} =$$
$$T_{aw} (^{\circ}R) =$$
$$T_i (^{\circ}\text{F}) = 82$$
$$T_{pc} (^{\circ}F) = 300$$
$$h_{r=1} = \dots$$

$\frac{1}{T}$	=	
---------------	---	--

$$(\rho C_k)^{1/2} =$$

0.30

$$\beta =$$
$$\Phi =$$

CAMERA POSITION


$B_0 + t_0 m$

Engineer

CFFS-HVD

# PHASE CHANGE PAINT TEST


ISOTHERM	$h$	$h/h_{ref}$	$h/h_{r=1}$	$N_{St, \infty}$
1				
2				
3				
4				
5				
6				
7				
8				
9				
10				



CONFIGURATION	41
FACILITY	LF-100T
TEST	OH-46
RUN	4508
LENGTH	
NOSE RADIUS	
SCALE	
$M_{\infty}$	= 8
$P_{total}$ (psia)	= 625
$T_{total}$ ( $^{\circ}F$ )	= 855
$R_{\infty}$ / ft	= 3.0 (106)
$T_{aw} / T_{total}$	
$T_{aw}$ ( $^{\circ}R$ )	
$T_i$ ( $^{\circ}F$ )	= 80
$T_{pc}$ ( $^{\circ}F$ )	= 300
$D_{ref}$	
$T$	
$(\rho C_p k)^{1/2}$	
$\alpha$	= 30
$\beta$	
$\Phi$	
CAMERA POSITION	Bottom
Engineer	
CFFS-HVD	

APPROPRIATE PAGE IS  
FOR QUALITY


PHASE CHANGE PAINT TEST



ISOTHERM	h	h/h <sub>ref.</sub>	h/h <sub>r=1</sub>	N <sub>St, ∞</sub>
1				
2				
3				
4				
5				
6				
7				
8				
9				
10				

CONFIGURATION	-22
FACILITY	LRC/VDT
TEST	OH-46
RUN	4509
LENGTH	
NOSE RADIUS	
SCALE	
M <sub>∞</sub>	
P <sub>total</sub> (psia) =	163
T <sub>total</sub> (°R) =	785
R <sub>∞</sub> / ft =	10(10 <sup>6</sup> )
T <sub>aw</sub> / T <sub>total</sub> =	
T <sub>aw</sub> (°R) =	
T <sub>i</sub> (°F) =	80
T <sub>pc</sub> (°F) =	300
h <sub>r=1</sub> =	
T <sub>i</sub> =	
(ρC <sub>p</sub> k) <sup>1/2</sup> =	
α =	30
β =	
Φ =	
CAMERA POSITION	
Engineer	
	CFFS-HVD


# PHASE CHANGE PAINT TEST



CONFIGURATION	-31
FACILITY	LRC/VDT
TEST	OH-46
RUN	4510
LENGTH	
NOSE RADIUS	
SCALE	.006
$M_{\infty}$	= 8
$P_{total}$ (psia)	= 155
$T_{total}$ ( $^{\circ}R$ )	= 800
$R_{\infty}$ / ft	= 1.0 (10 <sup>6</sup> )
$T_{aw} / T_{total}$	=
$T_{aw}$ ( $^{\circ}R$ )	=
$T_i$ ( $^{\circ}F$ )	= 76
$T_{pc}$ ( $^{\circ}F$ )	= 306
$h_{r=l'}$	=
$\bar{T}$	=
$(\rho C_p k)^{1/2}$	=
$\alpha$	= 30
$\beta$	=
$\Phi$	=
CAMERA POSITION	
Engineer	
	CFFS-HVD

ISOTHERM	h	h/h <sub>ref.</sub>	h/h <sub>r=l'</sub>	N <sub>St, ∞</sub>
1				
2				
3				
4				
5				
6				
7				
8				
9				
10				

PHASE CHANGE PAINT TEST



ISOTHERM	$h$	$h/h_{ref}$	$h/h_{ref} = 1/N_{St, \infty}$
1			
2			
3			
4			
5			
6			
7			
8			
9			
10			

CONFIGURATION

FACILITY LRC/VDT

TEST 04-46

RUN 4511

LENGTH

NOSE RADIUS

SCALE

$M_{\infty}$

$P_{total}$  (psia) = 150

$T_{total}$  ( $^{\circ}R$ ) = 770

$R_{\infty}/ft$  = 1.0 (10%)

$T_{aw}/T_{total}$  =

$T_{aw}$  ( $^{\circ}R$ ) =

$T_i$  ( $^{\circ}F$ ) = 76

$T_{pc}$  ( $^{\circ}F$ ) = 360

$h_{ref}$  =

$\bar{T}$  =

$(\bar{P}C_p k)^{1/2}$  =

$\alpha$  = 30

$\beta$  =


$\Phi$  =

CAMERA POSITION

Engineer

CFFS-HVD

## PHASE CHANGE PAINT TEST




ISOTHERM	$h$	$h/h_{ref.}$	$h/h_{r=1'}$	$N_{St, \infty}$
1				
2				
3				
4				
5				
6				
7				
8				
9				
10				

CONFIGURATION	22
FACILITY	LRC/VDT
TEST	OH-46
RUN	4512
LENGTH	
NOSE RADIUS	
SCALE	1006
$M_\infty$	= 9
$P_{\text{total}}$ (psia)	= 1380
$T_{\text{total}}$ ( $^{\circ}\text{R}$ )	= 955
$R_\infty$ / ft	= 6.0 ( $10^6$ )
$T_{\text{aw}} / T_{\text{total}}$	=
$T_{\text{aw}}$ ( $^{\circ}\text{R}$ )	=
$T_i$ ( $^{\circ}\text{F}$ )	= 79
$T_{\text{pc}}$ ( $^{\circ}\text{F}$ )	= 450
$h_{r=1}$	=
$\bar{T}$	=
$(\rho C_p k)^{1/2}$	=
$\alpha$	= 30
$\beta$	=
$\phi$	=
CAMERA POSITION	
Engineer	




ORIGINAL PAGE IS  
OF POOR QUALITY

# PHASE CHANGE PAINT TEST



# PHASE CHANGE PAINT TEST



ISOTHERM	$h$	$h/h_{ref}$	$h/h_{r=1}$	$N_{St, \infty}$
1				
2				
3				
4				
5				
6				
7				
8				
9				
10				


CONFIGURATION	140-B 41
FACILITY	LRC/VDT
TEST	OH-46
RUN	4514
LENGTH	
NOSE RADIUS	
SCALE	1006
$M_{\infty}$	8
$P_{total}$ (psia)	= 1380
$T_{total}$ ( $^{\circ}R$ )	= 905
$R_{\infty}/ft$	= 6.0 (100)
$T_{aw}/T_{total}$	=
$T_{aw}$ ( $^{\circ}R$ )	=
$T_i$ ( $^{\circ}F$ )	= 80
$T_{pc}$ ( $^{\circ}F$ )	= 550
$h_{ref}$	=
$T$	=
$(\rho C_p k)^{1/2}$	=
$\alpha$	= 30
$\beta$	=
$\phi$	=
CAMERA POSITION	
Engineer	
	CFFS-HVD.

CONFIGURATION	-22
FACILITY	LRC/VAT
TEST	OH-46
RUN	4515
LENGTH	
NOSE RADIUS	
SCALE	.006
$M_{\infty}$	8
$P_{\text{total}}$ (psia) =	164
$T_{\text{total}}$ ( $^{\circ}\text{R}$ ) =	795
$R_{\infty}$ / ft =	1.10 (106)
$T_{\text{aw}} / T_{\text{total}}$ =	
$T_{\text{aw}}$ ( $^{\circ}\text{R}$ ) =	
$T_1$ ( $^{\circ}\text{F}$ ) =	79
$T_{\text{pc}}$ ( $^{\circ}\text{F}$ ) =	150
$h$ =	
$T$ =	
$(P_{\text{C}}/P_0)^{1/2}$ =	
$\alpha$ =	30
$\beta$ =	
$\phi$ =	
CAMERA POSITION	
Engineer	
CFFS-HVD	

# PHASE CHANGE PAINT TEST

CONFIGURATION	-31
FACILITY	ZRC/VDT
TEST	OH-46
RUN	4516
LENGTH	
NOSE RADIUS	
SCALE	1006
$M_{\infty}$	8
$P_{total}$ (psia)	1405
$T_{total}$ (°R)	950
$R_{\infty}$ / ft	6.0 (10 <sup>4</sup> )
$T_{aw} / T_{total}$	
$T_{aw}$ (°R)	
$T_{(PF)}$	79
$T_{pc}$ (°F)	500
$h_f$	
$T$	
$(P_{C,K})^{1/2}$	
$\alpha$	30
$\beta$	
$\Phi$	
CAMERA POSITION	
Engineer	
CFFS-HVD	


ISOTHERM	h	h/h <sub>ref</sub>	h/h <sub>ref</sub> - 1	N <sub>St,∞</sub>
1				
2				
3				
4				
5				
6				
7				
8				
9				
10				



ORIGINAL DATA TO

ORIGINAL PAGE IS  
OF POOR QUALITY

# PHASE CHANGE PAINT TEST



ISOTHERM	h	h/h <sub>ref</sub>	h/h <sub>r=1</sub>	N <sub>St,∞</sub>
1				
2				
3				
4				
5				
6				
7				
8				
9				
10				

CONFIGURATION -22

FACILITY 2RC/VOT

TEST 04-46

RUN 4517

LENGTH

NOSE RADIUS

SCALE .006

M<sub>∞</sub> 8

P<sub>total</sub> (psia) = 1920

T<sub>total</sub> (°R) = 925

R<sub>∞</sub> / ft = 8.0(106)

T<sub>aw</sub> / T<sub>total</sub> =

T<sub>aw</sub> (°R) =

T<sub>∞</sub> (°F) = 88.1

T<sub>pc</sub> (°F) = 350

h<sub>ref</sub> =

T<sub>∞</sub> =

(P<sub>∞</sub> / P<sub>0</sub>)<sup>1/2</sup> =

α = 30

β =


Φ =

CAMERA POSITION

Engineer

CFFS-HVD


# PHASE CHANGE PAINT TEST



ISOTHERM	h	h/h <sub>ref.</sub>	h/h <sub>r=1'</sub>	N <sub>St, ∞</sub>
1				
2				
3				
4				
5				
6				
7				
8				
9				
10				

CONFIGURATION	41
FACILITY	ARG-VOT
TEST	OH-86
RUN	451.8
LENGTH	
NOSE RADIUS	
SCALE	1006
M <sub>∞</sub>	8
P <sub>total</sub> (psia)	165
T <sub>total</sub> (°R)	760
R <sub>∞</sub> / ft	1.0 (10 <sup>9</sup> )
T <sub>aw</sub> / T <sub>total</sub>	
-T <sub>aw</sub> (°R)	
J <sub>1</sub> (°F)	
T <sub>pc</sub> (°F)	175
h <sub>ref</sub> / ft	
T <sub>∞</sub>	
(ρC <sub>p</sub> k) <sub>1</sub> / 2	
α	30
β	
Φ	
CAMERA POSITION	
Engineer	
	CFFS-HVD

## PHASE-CHANGE PAINT TEST



ISOTHERM	$h$	$h/h_{ref.}$	$h/h_{r=1}$	$N_{St,\infty}$
1				
2				
3				
4				
5				
6				
7				
8				
9				
10				

CONFIGURATION
---------------

-37

FACILITY	LRD/VOT
----------	---------

TEST	OH-46
------	-------

RUN 4519

LENGTH

NOSE RADIUS

SCALE: 00%

M. 8

$P_{\text{total}} \text{ (psia)} = 1400$

$$T_{\text{total}} (^{\circ}\text{R}) = 930$$
$$R_{\infty} / \text{ft} = 6.0 / 10^6$$
$$T_{aw} / T_{total} =$$

T <sub>max</sub> (°R)	=
-----------------------	---

T <sub>i</sub> (°F) = 80
--------------------------

$$T_{PC} (^{\circ}F) = 350$$
[illegible]

1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	93	94	95	96	97	98	99	100	101	102	103	104	105	106	107	108	109	110	111	112	113	114	115	116	117	118	119	120	121	122	123	124	125	126	127	128	129	130	131	132	133	134	135	136	137	138	139	140	141	142	143	144	145	146	147	148	149	150	151	152	153	154	155	156	157	158	159	160	161	162	163	164	165	166	167	168	169	170	171	172	173	174	175	176	177	178	179	180	181	182	183	184	185	186	187	188	189	190	191	192	193	194	195	196	197	198	199	200	201	202	203	204	205	206	207	208	209	210	211	212	213	214	215	216	217	218	219	220	221	222	223	224	225	226	227	228	229	230	231	232	233	234	235	236	237	238	239	240	241	242	243	244	245	246	247	248	249	250	251	252	253	254	255	256	257	258	259	260	261	262	263	264	265	266	267	268	269	270	271	272	273	274	275	276	277	278	279	280	281	282	283	284	285	286	287	288	289	290	291	292	293	294	295	296	297	298	299	300	301	302	303	304	305	306	307	308	309	310	311	312	313	314	315	316	317	318	319	320	321	322	323	324	325	326	327	328	329	330	331	332	333	334	335	336	337	338	339	340	341	342	343	344	345	346	347	348	349	350	351	352	353	354	355	356	357	358	359	360	361	362	363	364	365	366	367	368	369	370	371	372	373	374	375	376	377	378	379	380	381	382	383	384	385	386	387	388	389	390	391	392	393	394	395	396	397	398	399	400	401	402	403	404	405	406	407	408	409	410	411	412	413	414	415	416	417	418	419	420	421	422	423	424	425	426	427	428	429	430	431	432	433	434	435	436	437	438	439	440	441	442	443	444	445	446	447	448	449	450	451	452	453	454	455	456	457	458	459	460	461	462	463	464	465	466
---	---	---	---	---	---	---	---	---	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----


$$(p C_p k)^{1/2} =$$
 $\alpha = 30$  $\beta =$ 
$$\Phi =$$

CAMERA POSITION

**Engineer**

CFFS-HVD<sup>3</sup>

# PHASE CHANGE PAINT TEST



ISOTHERM	h	h/h <sub>ref.</sub>	h/h <sub>r=1'</sub>	N <sub>St,∞</sub>
1				
2				
3				
4				
5				
6				
7				
8				
9				
10				

CONFIGURATION	-22
FACILITY	2001 VOT
TEST	OH-46
RUN	4520
LENGTH	
NOSE RADIUS	
SCALE	.006
M <sub>∞</sub>	8
P <sub>total</sub> (psia)	1405
T <sub>total</sub> (°R)	940
R <sub>∞</sub> / ft	6.0 (106)
T <sub>aw</sub> / T <sub>total</sub>	
T <sub>aw</sub> (°R)	
T <sub>i</sub> (°F)	82
T <sub>pc</sub> (°F)	350
h <sub>r=1'</sub>	
T <sub>i</sub>	
(ρC <sub>p</sub> k) <sup>1/2</sup>	
α	30
β	
Φ	
CAMERA POSITION	
Engineer	
	CFFS-HVD




[illegible]

ISOTHERM	$h$	$h/h_{ref.}$	$h/h_{ref.}$	$N_{St, \infty}$
1				
2				
3				
4				
5				
6				
7				
8				
9				
10				

CAMERA POSITION

CFFS-HVD

# PHASE CHANGE PAINT TEST




ISOTHERM	h	h/h <sub>ref.</sub>	h/h <sub>r=1</sub>	N <sub>St,∞</sub>
1				
2				
3				
4				
5				
6				
7				
8				
9				
10				

CONFIGURATION	231
FACILITY	ARC/VDT
TEST	04-46
RUN	4523
LENGTH	
NOSE RADIUS	
SCALE	.006
M <sub>∞</sub>	8
P <sub>total</sub> (psia)	165
T <sub>total</sub> (°R)	775
R <sub>∞</sub> / ft	1.0 (10°)
T <sub>aw</sub> / T <sub>total</sub>	
T <sub>aw</sub> (°R)	
T <sub>i</sub> (°F)	82
T <sub>pc</sub> (°F)	300
h <sub>ref</sub>	
T <sub>i</sub>	
(ρC <sub>p</sub> k) <sup>1/2</sup>	
α	130
β	
φ	
CAMERA POSITION	
Engineer	
	CFFS-HVD

PHASE CHANGE PAINT TEST


MODEL HAS BEEN ROLLED



ISOTHERM	h	h/h <sub>ref</sub>	h/h <sub>r=1'</sub>	N <sub>St,∞</sub>
1				
2				
3				
4				
5				
6				
7				
8				
9				
10				

CONFIGURATION	22
FACILITY	2.22/VDT
TEST	OH-AC
RUN	4324
LENGTH	
NOSE RADIUS	
SCALE	1006
M <sub>∞</sub>	0
P <sub>total</sub> (psia)	1935
T <sub>total</sub> (°R)	925
R <sub>∞</sub> / ft	8.0(10°)
T <sub>aw</sub> / T <sub>total</sub>	
T <sub>aw</sub> (°R)	
T <sub>i</sub> (°F)	83
T <sub>pc</sub> (°F)	400
h <sub>r=1'</sub>	
T	
(ρC <sub>p</sub> k) <sup>1/2</sup>	
α	30
β	
Φ	
CAMERA POSITION	
Engineer	
	CFFS-HVD


# PHASE CHANGE PAINT TEST



ISOTHERM	h	h/h <sub>ref</sub>	h/h <sub>r=1</sub>	N <sub>St,∞</sub>
1				
2				
3				
4				
5				
6				
7				
8				
9				
10				

CONFIGURATION: -41
FACILITY LRC/VDT
TEST 04-46
RUN 4525
LENGTH
NOSE RADIUS
SCALE .006
M <sub>∞</sub> 8
P <sub>total</sub> (psia) = 163
T <sub>total</sub> (°R) = 770
R <sub>∞</sub> / ft = 1.0 (10 <sup>0</sup> )
T <sub>aw</sub> / T <sub>total</sub> =
T <sub>aw</sub> (°R) =
T <sub>aw</sub> (°F) = 8.2
T <sub>pc</sub> (°F) = 300
h <sub>ref</sub> =
T <sub>ref</sub> =
(ρC <sub>p</sub> k) <sup>1/2</sup> =
α = 30
β =
φ =
CAMERA POSITION
Engineer
CFFS-HVD

PHASE CHANGE PAINT TEST




ISOTHERM	$h$	$h/h_{ref.}$	$h/h_{r=1}$	$N_{St, \infty}$
1				
2				
3				
4				
5				
6				
7				
8				
9				
10				

CONFIGURATION	
GRID	-21
FACILITY LRC/VDT	
TEST OH-46	
RUNS 4526 THRU 4545	
LENGTH	
NOSE RADIUS	
SCALE	
$M_{\infty}$	
$p_{total}$ (psia) =	
$T_{total}$ (°R) =	
$R_{\infty}$ / ft =	
$T_{aw} / T_{total}$ =	
$T_{aw}$ (°R) =	
$T_i$ (°F) =	
$T_{pc}$ (°F) =	
$h_{ref}$ =	
$T_{ref}$ =	
$(\rho C_p k)^{1/2}$ =	
$\alpha$ = 25	
$\beta$ = 0	
$\phi$ = 0	
CAMERA POSITION	
bottom	
VIEW	
Engineer	
CFFS-HVD	


# PHASE CHANGE PAINT TEST

CONFIGURATION	-22-
FACILITY	LRC/VDT
TEST	OH-46
RUN	4526
LENGTH	
NOSE RADIUS	
SCALE	.006
$M_\infty$	8
$P_{total}$ (psia)	625
$T_{total}$ (°R)	1380
$R_\infty / ft$	34106
$T_{aw} / T_{total}$	
$T_{aw}$ (°R)	
$T_f$ (°F)	77
$T_{pc}$ (°F)	350
$h_{ref}$	
$T_\infty$	
$(\rho C_p k)^{1/2}$	
$\alpha$	25
$\beta$	
$\phi$	
CAMERA POSITION	
	at 13
Engineer	
	CFFS-HVD

ISOTHERM	h	h/h <sub>ref</sub>	h/h <sub>r=1</sub>	N <sub>St,∞</sub>
1				
2				
3				
4				
5				
6				
7				
8				
9				
10				



# PHASE CHANGE PAINT TEST



CONFIGURATION	-31
FACILITY	LRC/VDT
TEST	OH-46
RUN	4527
LENGTH	
NOSE RADIUS:	
SCALE	
$M_\infty$	8
$P_{total}$ (psia) =	625
$T_{total}$ (°R) =	1340
$R_\infty$ / ft =	$3 \times 10^6$
$T_{aw} / T_{total}$ =	
$T_{aw}$ (°R) =	
$T_f$ (°F) =	81
$T_{bc}$ (°F) =	400
$\eta / T_{ref}$ =	
$T$ =	
$(\rho C k)^{1/2}$ =	
$\alpha$ =	25
$\beta$ =	
$\Phi$ =	
CAMERA POSITION	
Engineer	
	CFFS-HVD

PHASE CHANGE PAINT TEST


ISOTHERM	$h$	$h/h_{ref}$	$h/h_{r=1}$	$N_{St, \infty}$
1				
2				
3				
4				
5				
6				
7				
8				
9				
10				

ISOTHERM	$h$	$h/h_{ref.}$	$h/h_{r=1}$	$N_{St, \infty}$
1				
2				
3				
4				
5				
6				
7				
8				
9				
10				

FACILITY	1 RC / VDT
TEST	OH - 46
RUN	1528
LENGTH	
NOSE RADIUS	
SCALE	006
$M_{\infty}$	8
$P_{\text{total}}$ (psia) =	635
$T_{\text{total}}$ ( $^{\circ}\text{R}$ ) =	1340
$R_{\infty}$ / ft =	$3 \times 10^6$
$T_{\text{aw}} / T_{\text{total}}$ =	
$T_{\text{aw}}$ ( $^{\circ}\text{R}$ ) =	
$T_{\text{f}}$ ( $^{\circ}\text{F}$ ) =	
$T_{\text{pc}}$ ( $^{\circ}\text{F}$ ) =	400
$h_{\text{ref}}$ =	
$\bar{T}$ =	
$(\rho C_p k)^{1/2}$ =	
$\alpha$ =	25
$\beta$ =	
$\phi$ =	
CAMERA POSITION	
Engineer	
	CFFS-HVD




# PHASE CHANGE PAINT TEST



ISOTHERM	$h$	$h/h_{ref}$	$h/h_{r=1}$	$N_{St, \infty}$
1				
2				
3				
4				
5				
6				
7				
8				
9				
10				

CONFIGURATION	22
FACILITY	LRC/VDT
TEST	OH-46
RUN	4529
LENGTH	
NOSE RADIUS	
SCALE	006
$M_{\infty}$	8
$P_{total}$ (psia) =	635
$T_{total}$ ( $^{\circ}R$ ) =	875
$R_{\infty}$ / ft =	3x106
$T_{aw} / T_{total}$ =	
$T_{aw}$ ( $^{\circ}R$ ) =	
$T_i$ ( $^{\circ}F$ ) =	
$T_{pc}$ ( $^{\circ}F$ ) =	250
$h_{r=1}$ =	
$\bar{T}$ =	
$(\rho C_p k)^{1/2}$ =	
$\alpha'_{eq}$ =	25
$\beta$ =	
$\Phi$ =	
CAMERA POSITION	
Engineer	
CFFS-HVD	


# PHASE CHANGE PAINT TEST



CONFIGURATION	31
FACILITY	LRC/VDT
TEST	OH-46
RUN	4530
LENGTH	
NOSE RADIUS	
SCALE	.006
M <sub>∞</sub>	8
P <sub>total</sub> (psia)	630
T <sub>total</sub> (°R)	885
R <sub>∞</sub> / ft	3x10 <sup>6</sup>
T <sub>aw</sub> / T <sub>total</sub>	
T <sub>aw</sub> (°R)	
T <sub>i</sub> (°F)	
T <sub>pc</sub> (°F)	300
h <sub>r=1'</sub>	
T	
(ρC <sub>p</sub> k) <sup>1/2</sup>	
α	.25
β	
Φ	
CAMERA POSITION	
Engineer	
	CFFS-HVD

ORIGINAL PAGE IS  
OF POOR QUALITY


PHASE CHANGE PAINT TEST



ISOTHERM	h	h/h <sub>ref</sub>	h/h <sub>r=1</sub>	N <sub>St,∞</sub>
1				
2				
3				
4				
5				
6				
7				
8				
9				
10				

CONFIGURATION:	41
FACILITY	LRV/VDT
TEST	OH-46
RUN	45 31
LENGTH	
NOSE RADIUS	
SCALE	.006
M <sub>∞</sub>	8
P <sub>total</sub> (psia)	625
T <sub>total</sub> (°R)	865
R <sub>∞</sub> / ft	3x10 <sup>6</sup>
T <sub>aw</sub> / T <sub>total</sub>	
T <sub>aw</sub> (°R)	
T <sub>i</sub> (°F)	
T <sub>pc</sub> (°F)	300
h <sub>r=1</sub>	
T <sub>i</sub>	
(ρC <sub>p</sub> k) <sup>1/2</sup>	
α	2.5
β	
Φ	
CAMERA POSITION	
Engineer	
	CFFS-HVD


# PHASE-CHANGE PAINT TEST



ISOTHERM	h	h/h <sub>ref</sub>	h/h <sub>r=1</sub>	N <sub>St,∞</sub>
1				
2				
3				
4				
5				
6				
7				
8				
9				
10				

CONFIGURATION	2.2
FACILITY	LRC/VDI
TEST	OH-46
RUN	453.2
LENGTH	
NOSE RADIUS	
SCALE	006
M <sub>∞</sub>	8
P <sub>total</sub> (psia)	1400
T <sub>total</sub> (°R)	955
R <sub>∞</sub> / ft	6x106
T <sub>aw</sub> / T <sub>total</sub>	
T <sub>aw</sub> (°R)	
T <sub>i</sub> (°F)	
T <sub>pc</sub> (°F)	450
h <sub>r=1</sub>	
T	
(ρC <sub>p</sub> k) <sup>1/2</sup>	
α	25
β	
Φ	
CAMERA POSITION	
Engineer	
	CFFS-HVD


# PHASE CHANGE PAINT TEST



ISOTHERM	h	h/h <sub>ref.</sub>	h/h <sub>r=1</sub>	N <sub>St,∞</sub>
1				
2				
3				
4				
5				
6				
7				
8				
9				
10				

CONFIGURATION	
FACILITY	31 LRC/VDT
TEST	OH-46
RUN	4533
LENGTH	
NOSE RADIUS	
SCALE	.006
M <sub>∞</sub>	8
P <sub>total</sub> (psia) =	167
T <sub>total</sub> (°R) =	1220
R <sub>∞</sub> / ft =	1x10 <sup>6</sup>
T <sub>aw</sub> / T <sub>total</sub> =	
T <sub>aw</sub> (°R) =	
T <sub>i</sub> (°F) =	
T <sub>pc</sub> (°F) =	300
h <sub>r=1</sub> =	
T̄ =	
(ρ C <sub>p</sub> k) <sup>1/2</sup> =	
α =	25
β =	
Φ =	
CAMERA POSITION	
Engineer	
CFFS-HVD	

# PHASE CHANGE PAINT TEST




CONFIGURATION	41
FACILITY	LRC/VDT
TEST	CH-46
RUN	4534
LENGTH	
NOSE RADIUS	
SCALE	.006
$M_\infty$	8
$P_{total}$ (psia) =	1400
$T_{total}$ (°R) =	950
$R_\infty$ / ft =	6x10 <sup>6</sup>
$T_{aw} / T_{total}$ =	
$T_{aw}$ (°R) =	
$T_i$ (°F) =	
$T_{pc}$ (°F) =	550
$\frac{h}{r} =$	
$\bar{T}$ =	
$(\rho C_p k)^{1/2} =$	
$\alpha$ =	25
$\beta$ =	
$\phi$ =	
CAMERA POSITION	
Engineer	
	CFFS-HVD

ISOTHERM	h	h/h <sub>ref.</sub>	h/h <sub>r=1</sub>	N <sub>St,∞</sub>
1				
2				
3				
4				
5				
6				
7				
8				
9				
10				

1000

## 79




CFFS-HVD

# PHASE CHANGE PAINT TEST

CONFIGURATION	22
FACILITY	LRC/VDT
TEST	OH-46
RUN	4536
LENGTH	
NOSE RADIUS	
SCALE	.006
$M_\infty$	8
$P_{total}$ (psia) =	160
$T_{total}$ (°R) =	745
$R_\infty$ / ft =	$1 \times 10^{-6}$
$T_{aw} / T_{total}$ =	
$T_{aw}$ (°R) =	
$T_i$ (°F) =	
$T_{pc}$ (°F) =	250
$h_{ref}$ =	
$\bar{T}$ =	
$(\rho C_p k)^{1/2}$ =	
$\alpha$ =	.25
$\beta$ =	
$\Phi$ =	
CAMERA POSITION	
Engineer	
	CFFS-HVD


ISOTHERM	h	h/h <sub>ref</sub>	h/h <sub>ref</sub>	N <sub>St,∞</sub>
1				
2				
3				
4				
5				
6				
7				
8				
9				
10				





ORIGINAL PAGE IS  
OF POOR QUALITY


# PHASE CHANGE PAINT TEST



ISOTHERM	$h$	$h/h_{ref}$	$h/h_{r=1}$	$N_{St, \infty}$
1				
2				
3				
4				
5				
6				
7				
8				
9				
10				

CONFIGURATION	44
FACILITY	LRC/VDT
TEST	OH-4C
RUN	4537
LENGTH	
NOSE RADIUS	
SCALE	006
$M_{\infty}$	8
$P_{total}$ (psia)	156
$T_{total}$ (°R)	735
$R_{\infty}/R$	$1 \times 10^6$
$T_{aw}/T_{total}$	
$T_{aw}$ (°R)	
$T_i$ (°F)	
$T_{pc}$ (°F)	300
$h_{ref}$	
$\bar{T}$	
$(\rho C_p k)^{1/2}$	
$\alpha$	25
$\beta$	
$\phi$	
CAMERA POSITION	
Engineer	
	CFFS-HVD


# PHASE CHANGE PAINT TEST



ISOTHERM	$h$	$h/h_{ref.}$	$h/h_{r=1}$	$N_{St, \infty}$
1				
2				
3				
4				
5				
6				
7				
8				
9				
10				

CONFIGURATION 22	
FACILITY	LRCLVDI
TEST	8H-46
RUN	4538
LENGTH	
NOSE RADIUS	
SCALE	006
$M_{\infty}$	8
$P_{total}$ (psia) =	1405
$T_{total}$ ( $^{\circ}R$ ) =	940
$R_{\infty}$ / ft =	$6 \times 10^6$
$T_{aw} / T_{total}$ =	
$T_{aw}$ ( $^{\circ}R$ ) =	
$T_i$ ( $^{\circ}F$ ) =	
$T_{pc}$ ( $^{\circ}F$ ) =	360
$h_{r=1}$ =	
$\bar{T}$ =	
$(\rho C_p k)^{1/2}$ =	
$\alpha$ =	25
$\beta$ =	
$\Phi$ =	
CAMERA POSITION	
Engineer	
CFFS-HVD	

PHASE CHANGE PAINT TEST



ISOTHERM	h	h/h <sub>ref</sub>	h/h <sub>r=1</sub>	N <sub>St, ∞</sub>
1				
2				
3				
4				
5				
6				
7				
8				
9				
10				


CONFIGURATION	31
FACILITY	LRC/VDT
TEST	6H-46
RUN	4539
LENGTH	
NOSE RADIUS	
SCALE	006
M <sub>∞</sub>	8
P <sub>total</sub> (psia) =	150
T <sub>total</sub> (°R) =	770
R <sub>∞</sub> / ft =	1x10 <sup>6</sup>
T <sub>aw</sub> / T <sub>total</sub> =	
T <sub>aw</sub> (°R) =	
T <sub>i</sub> (°F) =	
T <sub>pc</sub> (°F) =	-175
h <sub>r=1</sub> =	
T =	
(ρ C <sub>p</sub> k) <sup>1/2</sup> =	
α =	25
β =	
Φ =	
CAMERA POSITION	
Engineer	
	CFFS-HVD

# PHASE CHANGE PAINT TEST

CONFIGURATION	22
FACILITY	LRC/VDT
TEST	OK-46
RUN	4540
LENGTH	
NOSE RADIUS	
SCALE	006
$M_\infty$	8
$P_{total}$ (psia)	1935
$T_{total}$ ( $^{\circ}R$ )	935
$R_\infty$ / ft	8.106
$T_{aw} / T_{total}$	
$T_{aw}$ ( $^{\circ}R$ )	
$T_i$ ( $^{\circ}F$ )	
$T_{pc}$ ( $^{\circ}F$ )	550
$h_{ref}$	
$\bar{T}$	
$(\rho C_p k)^{1/2}$	
$\alpha$	25
$\beta$	
$\Phi$	
CAMERA POSITION	
Engineer	
	CFFS-HVD

ISOTHERM	h	h/h <sub>ref</sub>	h/h <sub>r=1</sub>	N <sub>St,∞</sub>
1				
2				
3				
4				
5				
6				
7				
8				
9				
10				

# PHASE CHANGE PAINT TEST




ISOTHERM	$h$	$h/h_{ref}$	$h/h_{r=1}$	$N_{St, \infty}$
1				
2				
3				
4				
5				
6				
7				
8				
9				
10				

CONFIGURATION	
	41
FACILITY	LRC/VDT
TEST	OH-46
RUN	4541
LENGTH	
NOSE RADIUS	
SCALE	006
$M_{\infty}$	8
$P_{total}$ (psia) =	1400
$T_{total}$ ( $^{\circ}R$ ) =	950
$R_{\infty}$ / ft =	6x106
$T_{aw} / T_{total}$ =	
$T_{aw}$ ( $^{\circ}R$ ) =	
$T_{\infty}$ ( $^{\circ}F$ ) =	
$T_{pc}$ ( $^{\circ}F$ ) =	350
$h_{ref}$ =	
$\bar{T}$ =	
$(\rho C_p k)^{1/2}$ =	
$\alpha$ =	25
$\beta$ =	
$\Phi$ =	
CAMERA POSITION	
Engineer	
CFFS-HVD	


# PHASE CHANGE PAINT TEST

CONFIGURATION	22
FACILITY	LRC/VDT
TEST	OH-46
RUN	4542
LENGTH	
NOSE RADIUS	
SCALE	006
$M_\infty$	8
$P_{total}$ (psia) =	152
$T_{total}$ ( $^{\circ}R$ ) =	780
$R_\infty$ / ft =	$1 \times 10^6$
$T_{aw} / T_{total}$ =	
$T_{aw}$ ( $^{\circ}R$ ) =	
$T_i$ ( $^{\circ}F$ ) =	
$T_{pc}$ ( $^{\circ}F$ ) =	150
$h_{r=1}$ =	
$\bar{T}$ =	
$(\rho C_p k)^{1/2}$ =	
$\alpha$ =	25
$\beta$ =	
$\phi$ =	
CAMERA POSITION	
Engineer	
	CFFS-HVD

ISOTHERM	h	h/h <sub>ref</sub>	h/h <sub>r=1</sub>	N <sub>St,∞</sub>
1				
2				
3				
4				
5				
6				
7				
8				
9				
10				



## PHASE CHANGE PAINT TEST




ISOTHERM	$h$	$h/h_{ref.}$	$h/h_{r=1}$	$N_{St, \infty}$
1				
2				
3				
4				
5				
6				
7				
8				
9				
10				

CONFIGURATION		31
FACILITY		LRC/VDT
TEST		OH-46
RUN		4543
LENGTH		
NOSE RADIUS		
SCALE		.006
$M_{\infty}$		8
$P_{total}$ (psia) =		1390
$T_{total}$ ( $^{\circ}R$ ) =		980
$R_{\infty}$ / ft =		$6 \times 10^6$
$T_{aw} / T_{total}$ =		
$T_{aw}$ ( $^{\circ}R$ ) =		
$T_i$ ( $^{\circ}F$ ) =		
$T_{pc}$ ( $^{\circ}F$ ) =		350
$h_{r-l}$ =		
$\bar{T}$ =		
$(\rho C_p k)^{1/2}$ =		
$\alpha$ =		25
$\beta$ =		
$\Phi$ =		
CAMERA POSITION		
Engineer		
CFFS-HVD		

# PHASE CHANGE PAINT TEST

CONFIGURATION	41
FACILITY	LRC/VDT
TEST	ON 46
RUN	d544
LENGTH	
NOSE RADIUS	
SCALE	.006
$M_\infty$	8
$P_{total}$ (psia) =	160
$T_{total}$ (°R) =	820
$R_\infty$ / ft =	$1 \times 10^6$
$T_{aw} / T_{total}$ =	
$T_{aw}$ (°R) =	
$T_i$ (°F) =	
$T_{pc}$ (°F) =	175
$h_{r=1}$ =	
$\bar{T}$ =	
$(\rho C_p k)^{1/2}$ =	
$\alpha$ =	25
$\beta$ =	
$\phi$ =	
CAMERA POSITION	
Engineer	
	CFFS-HVD

ISOTHERM	h	h/h <sub>ref.</sub>	h/h <sub>r=1</sub>	N <sub>St, ∞</sub>
1				
2				
3				
4				
5				
6				
7				
8				
9				
10				






# PHASE CHANGE PAINT TEST


*Revised 4-3-66  
in model*

CONFIGURATION	- 22
FACILITY	LRC/VDT
TEST	OH-40
RUN	4545
LENGTH	
NOSE RADIUS	
SCALE	1006
$M_\infty$	8
$P_{total}$ (psia)	1930
$T_{total}$ (°R)	940
$R_\infty$ / ft	8.0 (100)
$T_{aw} / T_{total}$	
$T_{aw}$ (°R)	
$T_i$ (°F)	82
$T_{pc}$ (°F)	400
$h_{r=1}$	
$\bar{T}$	
$(\rho C_p k)^{1/2}$	
$\alpha$	25
$\beta$	
$\phi$	
CAMERA POSITION	
Engineer	
	CFFS-HVD

ISOTHERM	h	h/h <sub>ref.</sub>	h/h <sub>r=1</sub>	N <sub>St,∞</sub>
1				
2				
3				
4				
5				
6				
7				
8				
9				
10				



# PHASE CHANGE PAINT TEST



CONFIGURATION	GRID
FACILITY	LRC/V&T
TEST	OH-46
RUNS	4546 THRU 4552
LENGTH	
NOSE RADIUS	
SCALE	
$M_{\infty}$	
$P_{total}$ (psia) =	
$T_{total}$ ( $^{\circ}R$ ) =	
$R_{\infty}$ / ft =	
$T_{aw} / T_{total}$ =	
$T_{aw}$ ( $^{\circ}R$ ) =	
$T_i$ ( $^{\circ}F$ ) =	
$T_{pc}$ ( $^{\circ}F$ ) =	
$h_{r=1}$ =	
$\bar{T}$ =	
$(\rho C_p k)^{1/2}$ =	
$\alpha$ =	35°
$\beta$ =	
$\phi$ =	
CAMERA POSITION	BOTTOM VIEW
Engineer	
	CFFS-HVD

ISOTHERM	h	h/h <sub>ref.</sub>	h/h <sub>r=1</sub>	N <sub>St, ∞</sub>
1				
2				
3				
4				
5				
6				
7				
8				
9				
10				

# PHASE CHANGE PAINT TEST

91

38 51 72 103 118

38 51 72 103

103

constant  
to going  
down


38 51 72 103

118

ISOTHERM	h	h/h <sub>ref.</sub>	h/h <sub>r=1'</sub>	N <sub>St,∞</sub>
1				
2				
3				
4				
5				
6				
7				
8				
9				
10				

CONFIGURATION	-31
FACILITY	LRC/VDT
TEST	OH-46
RUN	4546
LENGTH	
NOSE RADIUS	
SCALE	006
M <sub>∞</sub>	8
P <sub>total</sub> (psia)	625
T <sub>total</sub> (°R)	850
R <sub>∞</sub> / ft	3.0(100)
T <sub>aw</sub> / T <sub>total</sub>	
T <sub>aw</sub> (°R)	
T <sub>i</sub> (°F)	83
T <sub>pc</sub> (°F)	400
h <sub>r=1'</sub>	
T̄	
(ρ C <sub>p</sub> k) <sup>1/2</sup>	
α	35
β	
φ	
CAMERA POSITION	
Engineer	
CFFS-HVD	


# PHASE CHANGE PAINT TEST



ISOTHERM	h	h/h <sub>ref.</sub>	h/h <sub>r=1'</sub>	N <sub>St,∞</sub>
1				
2				
3				
4				
5				
6				
7				
8				
9				
10				

CONFIGURATION	41
FACILITY	LAC/VNT
TEST	
RUN	4548
LENGTH	
NOSE RADIUS	
SCALE	1000
M <sub>∞</sub>	8
P <sub>total</sub> (psia)	655
T <sub>total</sub> (°R)	865
R <sub>∞</sub> / ft	3.0 × 10 <sup>6</sup>
T <sub>aw</sub> / T <sub>total</sub>	
T <sub>aw</sub> (°R)	
T <sub>i</sub> (°F)	82
T <sub>pc</sub> (°F)	400
h <sub>ref.</sub>	
T̄	
(ρC <sub>p</sub> k) <sup>1/2</sup>	
α	35
β	
Φ	
CAMERA POSITION	
Engineer	
	CFFS-HVD


# PHASE CHANGE PAINT TEST



ISOTHERM	h	h/h <sub>ref</sub>	h/h <sub>r=1'</sub>	N <sub>St,∞</sub>
1				
2				
3				
4				
5				
6				
7				
8				
9				
10				


CONFIGURATION	-22
FACILITY	LRC/VAT
TEST	OH-46
RUN	4549
LENGTH	
NOSE RADIUS	
SCALE	1006
M <sub>∞</sub>	8
P <sub>total</sub> (psia)	635
T <sub>total</sub> (°R)	875
R <sub>∞</sub> / ft	3.0 x 10 <sup>6</sup>
T <sub>aw</sub> / T <sub>total</sub>	
T <sub>aw</sub> (°R)	
T <sub>i</sub> (°F)	84
T <sub>pc</sub> (°F)	250
h <sub>r=1'</sub>	
T̄	
(ρC <sub>p</sub> k) <sup>1/2</sup>	
α	35
β	
Φ	
CAMERA POSITION	
Engineer	
	CFFS-HVD

# PHASE CHANGE PAINT TEST



CONFIGURATION	31
FACILITY	LRU/VPT
TEST	OH-46
RUN	1550
LENGTH	
NOSE RADIUS	
SCALE	1006
$M_\infty$	8
$P_{total}$ (psia)	636
$T_{total}$ ( $^{\circ}R$ )	855
$R_\infty / ft$	$3 \times 10^6$
$T_{aw} / T_{total}$	
$T_{aw}$ ( $^{\circ}R$ )	
$T_i$ ( $^{\circ}F$ )	82
$T_{pc}$ ( $^{\circ}F$ )	300
$h_{r=1}$	
$\bar{T}$	
$(\rho C_p k)^{1/2}$	
$\alpha$	35
$\beta$	
$\Phi$	
CAMERA POSITION	
Engineer	
	CFFS-HVD

ISOTHERM	h	h/h <sub>ref.</sub>	h/h <sub>r=1</sub>	N <sub>St, ∞</sub>
1				
2				
3				
4				
5				
6				
7				
8				
9				
10				



ISOTHERM	$h$	$h/h_{ref.}$	$h/h_{r=1}$	$N_{St, \infty}$
1				
2				
3				
4				
5				
6				
7				
8				
9				
10				

CONFIGURATION
1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

22

FACILITY	LRC/VDT
----------	---------

TEST OH-46

RUN 4551

LENGTH	WAVELENGTH	PERIOD	VELOCITY
100	100	100	100
200	200	200	200
300	300	300	300
400	400	400	400
500	500	500	500
600	600	600	600
700	700	700	700
800	800	800	800
900	900	900	900
1000	1000	1000	1000

NOSE RADIUS

SCALE .006

M <sub>3</sub>	8.
----------------	----

$P_{\text{total}}$  (psia) = 1375

$$T_{\text{total}} (^{\circ}\text{R}) = 95.0$$
$$R_{\infty} / \text{ft} = 6.0(10^4)$$
$$T_{aw} / T_{total} =$$
$$T_{aw} (^{\circ}R) =$$

T<sub>i</sub> (°F) = 82

$$T_{pc} (^{\circ}F) = 450$$

h	r=1	1
---	-----	---

1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	93	94	95	96	97	98	99	100	101	102	103	104	105	106	107	108	109	110	111	112	113	114	115	116	117	118	119	120	121	122	123	124	125	126	127	128	129	130	131	132	133	134	135	136	137	138	139	140	141	142	143	144	145	146	147	148	149	150	151	152	153	154	155	156	157	158	159	160	161	162	163	164	165	166	167	168	169	170	171	172	173	174	175	176	177	178	179	180	181	182	183	184	185	186	187	188	189	190	191	192	193	194	195	196	197	198	199	200	201	202	203	204	205	206	207	208	209	210	211	212	213	214	215	216	217	218	219	220	221	222	223	224	225	226	227	228	229	230	231	232	233	234	235	236	237	238	239	240	241	242	243	244	245	246	247	248	249	250	251	252	253	254	255	256	257	258	259	260	261	262	263	264	265	266	267	268	269	270	271	272	273	274	275	276	277	278	279	280	281	282	283	284	285	286	287	288	289	290	291	292	293	294	295	296	297	298	299	300	301	302	303	304	305	306	307	308	309	310	311	312	313	314	315	316	317	318	319	320	321	322	323	324	325	326	327	328	329	330	331	332	333	334	335	336	337	338	339	340	341	342	343	344	345	346	347	348	349	350	351	352	353	354	355	356	357	358	359	360	361	362	363	364	365	366	367	368	369	370	371	372	373	374	375	376	377	378	379	380	381	382	383	384	385	386	387	388	389	390	391	392	393	394	395	396	397	398	399	400	401	402	403	404	405	406	407	408	409	410	411	412	413	414	415	416	417	418	419	420	421	422	423	424	425	426	427	428	429	430	431	432	433	434	435	436	437	438	439	440	441	442	443	444	445	446	447	448	449	450	451	452	453	454	455	456	457	458	459	460	461	462	463	464	465	466
---	---	---	---	---	---	---	---	---	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----


$$(p C_p k)^{1/2} =$$
$$\alpha = 35$$
 $\beta =$ 
$$\Phi =$$

CAMERA POSITION

Engineer

CFFS-HVD

## PHASE CHANGE PAINT TEST




ISOTHERM	$h$	$h/h_{ref.}$	$h/h_{r=1'}$	$N_{St, \infty}$
1				
2				
3				
4				
5				
6				
7				
8				
9				
10				

CONFIGURATION	41
FACILITY	LRL/VOT
TEST-	DH-46
RUN	4552
LENGTH	
NOSE RADIUS	
SCALE	.006
$M_{\infty}$	8
$P_{\text{total}}$ (psia) =	660
$T_{\text{total}}$ ( $^{\circ}\text{R}$ ) =	865
$R_{\infty}/ft$ =	$3.0 \times 10^{-6}$
$T_{\text{aw}}/T_{\text{total}}$ =	
$T_{\text{aw}}$ ( $^{\circ}\text{R}$ ) =	
$T_i$ ( $^{\circ}\text{F}$ ) =	81
$T_{\text{pc}}$ ( $^{\circ}\text{F}$ ) =	300
$h_{r=1}$ =	
$\bar{T}$ =	
$(\rho C_p k)^{1/2}$ =	
$\alpha$ =	35
$\beta$ =	
$\Phi$ =	
CAMERA POSITION	
Engineer	
	CFFS-HVD



# PHASE CHANGE PAINT TEST



CONFIGURATION

GRID

FACILITY *LRC/VDT*

TEST *Q-H-46*

RUNS 4506 THRU 4522

LENGTH

NOSE RADIUS

SCALE

$M_{\infty}$

$P_{total}$  (psia) =

$T_{total}$  ( $^{\circ}R$ ) =

$R_{\infty}$  / ft =

$T_{aw} / T_{total}$  =

$T_{aw}$  ( $^{\circ}R$ ) =

$T_i$  ( $^{\circ}F$ ) =

$T_{pc}$  ( $^{\circ}F$ ) =

$h_{ref}$  =

$\bar{T}$  =

$(\rho C_p k)^{1/2}$  =

$\alpha$  = *30*

$\beta$  =

$\phi$  =

CAMERA POSITION


*SIDE*

Engineer

CFFS-HVD

ISOTHERM	$h$	$h/h_{ref}$	$h/h_{r=1}$	$N_{St, \infty}$
1				
2				
3				
4				
5				
6				
7				
8				
9				
10				

PHASE CHANGE PAINT TEST




ISOTHERM	$h$	$h/h_{ref}$	$h/h_{r=1}$	$N_{St, \infty}$
1				
2				
3				
4				
5				
6				
7				
8				
9				
10				

CONFIGURATION	22
FACILITY	LRC-VDT
TEST	OH-40
RUN	4506
LENGTH	
NOSE RADIUS	
SCALE	.006
$M_{\infty}$	8
$P_{total}$ (psia)	645
$T_{total}$ ( $^{\circ}R$ )	905
$R_{\infty}/ft$	3.0(10 <sup>6</sup> )
$T_{aw}/T_{total}$	
$T_{aw}$ ( $^{\circ}R$ )	
$T_i$ ( $^{\circ}F$ )	80
$T_{pc}$ ( $^{\circ}F$ )	250
$h_{r=1}$	
$\bar{T}$	
$(P C_p k)^{1/2}$	
$\alpha$	30
$\beta$	
$\phi$	
CAMERA POSITION	
Engineer	

CFFS-HVD

# PHASE CHANGE PAINT TEST




ISOTHERM	h	h/h <sub>ref.</sub>	h/h <sub>r=1'</sub>	N <sub>St, ∞</sub>
1				
2				
3				
4				
5				
6				
7				
8				
9				
10				

CONFIGURATION	31
FACILITY	LRG-VPT
TEST	04-46
RUN	4513
LENGTH	
NOSE RADIUS	
SCALE	.006
M <sub>∞</sub>	8
P <sub>total</sub> (psia)	= 157
T <sub>total</sub> (°R)	= 770
R <sub>∞</sub> / ft	= 1.0 (10°)
T <sub>aw</sub> / T <sub>total</sub>	=
T <sub>aw</sub> (°R)	=
T <sub>i</sub> (°F)	= 81
T <sub>pc</sub> (°F)	= 175
h <sub>r=1'</sub>	=
T̄	=
(ρ C <sub>p</sub> k) <sup>1/2</sup>	=
α	= .30
β	=
Φ	=
CAMERA POSITION	
Engineer	
	CFFS-HVD

ORIGINAL PAGE IS  
OF POOR QUALITY

# PHASE CHANGE PAINT TEST




upper tier  

$\frac{h}{L}$	F	$\frac{1}{h_r}$
.468	106	0855
.481	96	0899
.5	96	0899
.53	106	0855

ISOTHERM	h	h/h <sub>ref.</sub>	h/h <sub>r=1</sub>	N <sub>St, ∞</sub>
1				
2				
3				
4				
5				
6				
7				
8				
9				
10				

CONFIGURATION	31
FACILITY	LRC/VNT
TEST	ON-46
RUN	4519
LENGTH	
NOSE RADIUS	
SCALE	1006
M <sub>∞</sub>	9
P <sub>total</sub> (psia)	= 1400
T <sub>total</sub> (°R)	= 930
R <sub>∞</sub> / ft	= 6.0(10°)
T <sub>aw</sub> / T <sub>total</sub>	=
T <sub>aw</sub> (°R)	=
T <sub>i</sub> (°F)	= 80
T <sub>pc</sub> (°F)	= 350
h <sub>r=1</sub>	=
T <sub>i</sub>	=
(ρ C <sub>p</sub> k) <sup>1/2</sup>	=
α	= 30
β	=
Φ	=
CAMERA POSITION	
Engineer	
CFFS-HVD	

# PHASE CHANGE PAINT TEST




ISOTHERM	h	h/h <sub>ref</sub>	b/h <sub>ref</sub>	N <sub>St, ∞</sub>
1				
2				
3				
4				
5				
6				
7				
8				
9				
10				

h/h <sub>ref</sub>	N <sub>St, ∞</sub>	h/h <sub>ref</sub>	N <sub>St, ∞</sub>	h/h <sub>ref</sub>	N <sub>St, ∞</sub>
8	0.245	329	67	0.298	
381	99	0.245	329	67	0.298
405	67	0.298	1341	97	0.356
413	47	0.356	1355	15	0.609
45	15	0.609	39	15	0.609
497	15	0.609	4	47	0.356
52	47	0.356	41	67	0.298
541	99	0.245	44	99	0.245
582	159	0.193	48	159	0.193

CONFIGURATION	-22
FACILITY	LRC/VOT
TEST	OH-46
RUN	4522
LENGTH	
NOSE RADIUS	
SCALE	.006
M <sub>∞</sub>	8
P <sub>total</sub> (psia)	= 625
T <sub>total</sub> (°R)	= 850
R <sub>∞</sub> / ft	= 3.0(10 <sup>4</sup> )
T <sub>aw</sub> / T <sub>total</sub>	=
T <sub>aw</sub> (°R)	=
T <sub>i</sub> (°F)	= 8.1
T <sub>pc</sub> (°F)	= 150
h <sub>ref</sub>	=
T	=
(P <sub>C</sub> k) <sup>1/2</sup>	=
α	= 30
β	=
Φ	=
CAMERA POSITION	
Engineer	
CFFS-HVD	

# PHASE CHANGE PAINT TEST



## CONFIGURATION

GRID

FACILITY LRC/VDT

TEST OH-46

RUN. 4529

LENGTH

NOSE RADIUS

SCALE

$M_\infty$

$P_{total}$  (psia) =

$T_{total}$  ( $^{\circ}R$ ) =

$R_\infty$  / ft =

$T_{aw} / T_{total}$  =

$T_{aw}$  ( $^{\circ}R$ ) =

$T_i$  ( $^{\circ}F$ ) =

$T_{pc}$  ( $^{\circ}F$ ) =

$h_{r=1}$  =

$\bar{T}$  =

$(\rho C_p k)^{1/2}$  =

$\alpha = 25^{\circ}$

$\beta$  =

$\phi$  =

CAMERA POSITION

SIDE

Engineer

CFFS-HVD

ISOTHERM	$h$	$h/h_{ref}$	$h/h_{r=1}$	$N_{St,\infty}$
1				
2				
3				
4				
5				
6				
7				
8				
9				
10				

# PHASE CHANGE PAINT TEST

CONFIGURATION - 22

FACILITY LRC/VDT

TEST 04-46

RUN 4529

LENGTH

NOSE RADIUS

SCALE 1006

$M_{\infty}$  8

$P_{total}$  (psia) = 635

$T_{total}$  (°R) = 875

$R_{\infty}/ft$  = 3.0 (106)

$T_{aw}/T_{total}$  =

$T_{aw}$  (°R) =

$T_i$  (°F) = 81

$T_{pc}$  (°F) = 250

$h_{r=1'}$  =

$\bar{T}$  =

$(\rho C_p k)^{1/2}$  =

$\alpha$  = 25


$\beta$  =

$\Phi$  =

CAMERA POSITION

Engineer


CFFS-HVD



upper cam			wh. 100			lower cam		
$\frac{h}{l}$	F	$h/h_c$	$\frac{h}{l}$	F	$h/h_c$	$\frac{h}{l}$	F	$h/h_c$
.471	134	0618	.375	134	0618	.298	134	0618
.489	100	0715	.381	100	0715	.34	134	0618
.500	56	0956	.435	100	0715			
.515	46	.105	.452	134	0618			
.545	46	.105						
.56	56	0956						
.565	100	0715						
.58	134	0618						

ISOTHERM	h	h/h <sub>ref.</sub>	h/h <sub>r=1'</sub>	N <sub>St,∞</sub>
1				
2				
3				
4				
5				
6				
7				
8				
9				
10				

# PHASE CHANGE PAINT TEST




CONFIGURATION	GRID
FACILITY	LRC/VDT
TEST	OH-46
RUNS	4549 THRU 4552
LENGTH	
NOSE RADIUS	
SCALE	.006
$M_{\infty}$	
$P_{total}$ (psia) =	
$T_{total}$ ( $^{\circ}R$ ) =	
$R_{\infty}$ / ft =	
$T_{aw} / T_{total}$ =	
$T_{aw}$ ( $^{\circ}R$ ) =	
$T_i$ ( $^{\circ}F$ ) =	
$T_{pc}$ ( $^{\circ}F$ ) =	
$h_{r=1}$ =	
$\bar{T}$ =	
$(\rho C_p k)^{1/2}$ =	
$\alpha$ =	35
$\beta$ =	
$\Phi$ =	
CAMERA POSITION	SIDE
Engineer	
	CFFS-HVD

ISOTHERM	h	h/h <sub>ref.</sub>	h/h <sub>r=1</sub>	N <sub>St, ∞</sub>
1				
2				
3				
4				
5				
6				
7				
8				
9				
10				



## PHASE CHANGE PAINT TEST



Upper Tan			Lower Tan		
$\frac{1}{2}$	$\frac{1}{4}$	$\frac{1}{8}$	$\frac{1}{2}$	$\frac{1}{4}$	$\frac{1}{8}$
57	181	0503	311	181	0523
1385	146	0552	325	146	0582
46	181	0503	330	119	0645
			345	119	0645
			36	181	0523

CONFIGURATION	22
---------------	----

FACILITY - LRC/NOT

TEST 04-46

RUN	4549
-----	------

LENGTH

NOSE RADIUS

SCALE 006

$M_{\infty}$	8
--------------	---

$P_{\text{total}}$  (psia) = 635

$$T_{\text{total}} (\text{OR}) = 875$$
$$R_{\infty} / \text{ft} = 3 \times 10^6$$
$$T_{aw} / T_{total} =$$
$$T_{a\dot{w}} (^{\circ}R) =$$

$T_i$  (°F) = 84

$$T_{DC} (^{\circ}F) = 250$$

100

1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	93	94	95	96	97	98	99	100
---	---	---	---	---	---	---	---	---	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	-----


$$-(\rho C_p k)^{1/2}$$
$$a = 35$$
$$\beta =$$
$$\Phi =$$

CAMERA POSITION

Engineer

CFFS-HVD


# PHASE CHANGE PAINT TEST



CONFIGURATION	31
FACILITY	LRL/VOT
TEST	OH-46
RUN	4550
LENGTH	
NOSE RADIUS	
SCALE	.006
$M_{\infty}$	8
$P_{total}$ (psia) =	630
$T_{total}$ ( $^{\circ}R$ ) =	825
$R_{\infty}$ / ft =	$3.0(10^6)$
$T_{aw} / T_{total}$ =	
$T_{aw}$ ( $^{\circ}R$ ) =	
$T_i$ ( $^{\circ}F$ ) =	82
$T_{pc}$ ( $^{\circ}F$ ) =	300
$h_{r=1}$ =	
$\bar{T}$ =	
$(\rho C_p k)^{1/2}$ =	
$\alpha$ =	.35
$\beta$ =	
$\phi$ =	
CAMERA POSITION	
Engineer	
	CFFS-HVD

ISOTHERM	h	h/h <sub>ref.</sub>	h/h <sub>r=1</sub>	N <sub>St,∞</sub>
1				
2				
3				
4				
5				
6				
7				
8				
9				
10				


# PHASE CHANGE PAINT TEST



CONFIGURATION	2
FACILITY	LRC/VDT
TEST	OH-46
RUN	455-1
LENGTH	
NOSE RADIUS	
SCALE	.006
$M_\infty$	8
$P_{total}$ (psia)	1375
$T_{total}$ (°R)	950
$R_\infty$ / ft	$6 \times 10^6$
$T_{aw} / T_{total}$	
$T_{aw}$ (°R)	
$T_i$ (°F)	82
$T_{pc}$ (°F)	450
$h_{r=1'}$	
$\bar{T}$	
$(\rho C_p k)^{1/2}$	
$\alpha$	35
$\beta$	
$\phi$	
CAMERA POSITION	
Engineer	
	CFFS-HVD

ISOTHERM	h	h/h <sub>ref.</sub>	h/h <sub>r=1'</sub>	N <sub>St,∞</sub>
1				
2				
3				
4				
5				
6				
7				
8				
9				
10				


# PHASE CHANGE PAINT TEST



CONFIGURATION	41
FACILITY	LRC/VDT
TEST	OH-46
RUN	4552
LENGTH	4552
NOSE RADIUS	
SCALE	006
$M_{\infty}$	8
$P_{total}$ (psia) =	660
$T_{total}$ ( $^{\circ}R$ ) =	845
$R_{\infty}$ / ft =	$3 \times 10^6$
$T_{aw} / T_{total}$ =	
$T_{aw}$ ( $^{\circ}R$ ) =	
$T_i$ ( $^{\circ}F$ ) =	81
$T_{pc}$ ( $^{\circ}F$ ) =	300
$h_{r=1}$ =	
$\bar{T}$ =	
$(\rho C_p k)^{1/2}$ =	
$\alpha$ =	35
$\beta$ =	
$\Phi$ =	
CAMERA POSITION	
Engineer	
	CFFS-HVD

ISOTHERM	h	h/h <sub>ref.</sub>	h/h <sub>r=1</sub>	N <sub>St,∞</sub>
1				
2				
3				
4				
5				
6				
7				
8				
9				
10				


# PHASE CHANGE PAINT TEST



ISOTHERM	h	h/h <sub>ref.</sub>	h/h <sub>r=1'</sub>	N <sub>St,∞</sub>
1				
2				
3				
4				
5				
6				
7				
8				
9				
10				

CONFIGURATION GRID
FACILITY LRC/VDT
TEST OH-46B
RUNS 4556 THRU 4567
LENGTH
NOSE RADIUS
SCALE .006
M <sub>∞</sub>
P <sub>total</sub> (psia) =
T <sub>total</sub> (°R) =
R <sub>∞</sub> / ft =
T <sub>aw</sub> / T <sub>total</sub> =
T <sub>aw</sub> (°R) =
T <sub>i</sub> (°F) =
T <sub>pc</sub> (°F) =
h <sub>r=1'</sub> =
T <sub>i</sub> =
(ρ C <sub>p</sub> k) <sup>1/2</sup> =
α = 35°
β = 0
Φ = 0
CAMERA POSITION BOTTOM VIEW
Engineer
CFFS-HVD


# PHASE CHANGE PAINT TEST



ISOTHERM	h	h/h <sub>ref.</sub>	h/h <sub>r=1'</sub>	N <sub>St, ∞</sub>
1-18	.0126		.3219	
2-38	.0087		.2216	
3-69	.0065		.1644	
4-82	.0059		.1508	
5-118	.0049		.1257	
6-148	.0044		.1123	
7-191	.0039		.0988	
8				
9				
10				

CONFIGURATION	22
FACILITY	LRC/VDT
TEST	ΦH-46B
RUN	1 (4556)
LENGTH	7.7418 in. m.s.
NOSE RADIUS	.006
SCALE	.006
M <sub>∞</sub>	8
P <sub>total</sub> (psia)	= 157
T <sub>total</sub> (°R)	= 840
R <sub>∞</sub> / ft	= 1 × 10 <sup>6</sup>
T <sub>aw</sub> / T <sub>total</sub>	= .923
T <sub>aw</sub> (°R)	=
T <sub>i</sub> (°F)	= 76
T <sub>pc</sub> (°F)	= 250
h <sub>r=1'</sub>	= .0392
T̄	= .2621
(ρC <sub>p</sub> k) <sup>1/2</sup>	= .0574
α	= 35°
β	= 0
Φ	= 0
CAMERA POSITION	TOP
	BOTTOM VIEW
Engineer	W. DYE, P. LAWING
	CFFS-HVD

# PHASE CHANGE PAINT TEST




ISOTHERM	h	h/h <sub>ref.</sub>	h/h <sub>r=1'</sub>	N <sub>St,∞</sub>
1 - 36	.0136		.3472	
2 - 89	.0087		.2208	
3 - 136	.0070		.1786	
4 - 170	.0063		.1598	
5				
6				
7				
8				
9				
10				

CONFIGURATION	41
FACILITY	LRC/YDT
TEST	ØH-46'B
RUN	2 (4557)
LENGTH	7.7418m. m.s.
NOSE RADIUS	.006
SCALE	.006
M <sub>∞</sub>	8
P <sub>total</sub> (psia)	= 157
T <sub>total</sub> (°R)	= 815
R <sub>∞</sub> / ft	= 1 x 10 <sup>6</sup>
T <sub>aw</sub> / T <sub>total</sub>	= .923
T <sub>aw</sub> (°R)	=
T <sub>i</sub> (°F)	= 73
T <sub>pc</sub> (°F)	= 300
h <sub>r=1'</sub>	= .0392
T̄	= .3525
(ρC <sub>p</sub> k) <sup>1/2</sup>	= .0586
α	= 35
β	= 0
Φ	= 0
CAMERA POSITION	T: D
Engineer	D. J. ...
CFFS-HVD	

# PHASE CHANGE PAINT TEST


CONFIGURATION	31
FACILITY	LRC/VDT
TEST	ØH-46B
RUN	3 (455P)
LENGTH	7.7418 in. m.s.
NOSE RADIUS	.006
SCALE	.006
$M_\infty$	8
$P_{total}$ (psia)	= 1435
$T_{total}$ (°R)	= 955
$R_\infty$ / ft	= $6 \times 10^6$
$T_{aw} / T_{total}$	= .923
$T_{aw}$ (°R)	=
$T_i$ (°F)	= 74
$T_{pc}$ (°F)	= 500
$h_{r=1'}$	= .1061
$\bar{T}$	= .5518
$(\rho C_p k)^{1/2}$	= .0617
$\alpha$	= .35
$\beta$	= 0
$\Phi$	= 0
CAMERA POSITION	TOP
Engineer	W. Dye, P. LAWING
	CFFS-HVD

ISOTHERM	h	$h/h_{ref}$	$h/h_{r=1'}$	$N_{St, \infty}$
1 -1.3	.0502		.4731	
2 2.5	.0362		.3412	
3 2.9	.0336		.3168	
4 4.2	.0279		.2632	
5 5.3	.0249		.2343	
6 6.3	.0228		.2149	
7 7.6	.0208		.1957	
8 9.7	.0184		.1732	
9 11.7	.0167		.1577	
10 15.3	.0143		.1379	






# PHASE CHANGE PAINT TEST



ISOTHERM	h	h/h <sub>ref.</sub>	h/h <sub>r=1'</sub>	N <sub>St,∞</sub>
1-13	.0618		.5040	
2-33	.0388		.3164	
3-50	.0315		.2570	
4-61	.0285		.2327	
5-72	.0262		.2142	
6-94	.0298		.1874	
7				
8				
9				
10				

CONFIGURATION	22
FACILITY	LRC/VDT
TEST	ØH-46B
RUN	4559
LENGTH	7.7418 in. m.s.
NOSE RADIUS	.002
SCALE	= .006
M <sub>∞</sub>	= 8.
P <sub>total</sub> (psia)	= 1960
T <sub>total</sub> (°R)	= 965
R <sub>∞</sub> / ft	= 8 × 10 <sup>6</sup>
T <sub>aw</sub> / T <sub>total</sub>	= .923
T <sub>aw</sub> (°R)	=
T <sub>i</sub> (°F)	= 76
T <sub>pc</sub> (°F)	= 550
h <sub>r=1'</sub>	= .1224
T̄	= .6083
(pC <sub>p</sub> k) <sup>1/2</sup>	= .0617
α	= 35°
β	= 0
Φ	= 0
CAMERA POSITION	TOP
Engineer	W. Dye
	CFFS-HVD


# PHASE CHANGE PAINT TEST



ISOTHERM	h	h/h <sub>ref.</sub>	h/h <sub>r=1'</sub>	N <sub>St,∞</sub>
1-13	.01612		.5814	
2-37	.0363		.3446	
3-60	.0285		.2706	
4-91	.0231		.2200	
5-133	.0191		.1818	
6				
7				
8				
9				
10				

CONFIGURATION	41
FACILITY	LRC/VDT
TEST	ØH-46 B
RUN	4560
LENGTH	7.7418 in. m.s
NOSE RADIUS	.006
SCALE	.006
M <sub>∞</sub>	8
P <sub>total</sub> (psia)	= 1410
T <sub>total</sub> (°R)	= 970
R <sub>∞</sub> / ft	= 6
T <sub>aw</sub> / T <sub>total</sub>	= .923
T <sub>aw</sub> (°R)	=
T <sub>i</sub> (°F)	= 74
T <sub>pc</sub> (°F)	= 550
h <sub>r=1'</sub>	= .1052
T̄	= .6057
(ρC <sub>p</sub> k) <sup>1/2</sup>	= .0617
α	= 35
β	= 0
Φ	= 0
CAMERA POSITION	rop
Engineer	W. Dye
	CFFS-HVD


# PHASE CHANGE PAINT TEST



ISOTHERM	h	h/h <sub>ref</sub>	h/h <sub>r=1"</sub>	N <sub>St,∞</sub>
1-15	.0072		.1905	
2-23	.0054		.1432	
3-33	.0045		.1195	
4-45	.0039		.1024	
5-66	.0032		.0845	
6-83	.0029		.0754	
7-120	.0024		.0627	
8-167	.0020		.0531	
9				
10				

CONFIGURATION	31
FACILITY	LRC/VDT
TEST	OH-46B
RUN	4561
LENGTH	7.7418 in m.s.
NOSE RADIUS	.006
SCALE	.006
M <sub>∞</sub>	8
P <sub>total</sub> (psia)	= 146
T <sub>total</sub> (°R)	= 815
R <sub>∞</sub> / ft	= 1 x 10 <sup>6</sup>
T <sub>aw</sub> / T <sub>total</sub>	= .923
T <sub>aw</sub> (°R)	=
T <sub>i</sub> (°F)	= 78
T <sub>pc</sub> (°F)	= 175
h <sub>r=1"</sub>	= .0379
T̄	= .1518
(ρC <sub>p</sub> k) <sup>1/2</sup>	= .0537
α	= 35
β	= 0
Φ	= 0
CAMERA POSITION	TOP
Engineer	W.Dye
	CFFS-HVD


# PHASE CHANGE PAINT TEST



ISOTHERM SEC	h	h/h <sub>ref.</sub>	h/h <sub>r=1'</sub>	N <sub>St, ∞</sub>
1-13	.0167		.1603	
2-15	.0156		.1492	
3-18	.0142		.1362	
4-22	.0129		.1232	
5-30	.0110		.1055	
6-40	.0095		.0914	
7-50	.0085		.0817	
8-57	.0080		.0765	
9-60	.0078		.0746	
10				

CONFIGURATION	22
FACILITY	LRC/VDT
TEST	ØH-46B
RUN	4562
LENGTH	7.7418 in. m.s.
NOSE RADIUS	.006
SCALE	.006
M <sub>∞</sub>	8
P <sub>total</sub> (psia)	= 1380
T <sub>total</sub> (°R)	= 965
R <sub>∞</sub> /ft	= 6 x 10 <sup>6</sup>
T <sub>aw</sub> /T <sub>total</sub>	= .923
T <sub>aw</sub> (°R)	=
T <sub>i</sub> (°F)	= 81
T <sub>pc</sub> (°F)	= 300
h <sub>r=1'</sub>	= .1045
T̄	= .2828
(ρC <sub>p</sub> k) <sup>1/2</sup>	= .0586
α	= 35
β	= 0
Φ	= 0
CAMERA POSITION	TOP
Engineer	W. Dye
	CFFS-HVD


# PHASE CHANGE PAINT TEST



ISOTHERM	h	h/h <sub>ref.</sub>	h/h <sub>r=1'</sub>	N <sub>St, ∞</sub>
1 - 13	.0074		.2020	
2 - 34	.0048		.1250	
3 - 45	.0042		.1086	
4 - 55	.0036		.0957	
5 - 78	.0032		.0825	
6 - 108	.0027		.0701	
7 - 160	.0022		.0576	
8				
9				
10				

CONFIGURATION	41
FACILITY	LRC/VDT
TEST	OH-46B
RUN	4563
LENGTH	7.7418 in. m.s.
NOSE RADIUS	.006
SCALE	.006
M <sub>∞</sub>	8
P <sub>total</sub> (psia)	= 151
T <sub>total</sub> (°R)	= 785
R <sub>∞</sub> / ft	= 1 x 10 <sup>6</sup>
T <sub>aw</sub> / T <sub>total</sub>	= .923
T <sub>aw</sub> (°R)	=
T <sub>i</sub> (°F)	= 76
T <sub>pc</sub> (°F)	= 175
h <sub>r=1'</sub>	= .0383
T <sub>i</sub>	= .1615
(ρC <sub>p</sub> k) <sup>1/2</sup>	= .0537
α	= 35°
β	= 0
Φ	= 0°
CAMERA POSITION	TOP
Engineer	W. Dye
	CFFS-HVD


## PHASE CHANGE PAINT TEST



ISOTHERM	h	h/h <sub>ref.</sub>	h/h <sub>r=1'</sub>	N <sub>St,∞</sub>
1-13	.0224		.2087	
2-16	.0202		.1882	
3-20	.0180		.1683	
4-26	.0158		.1476	
5-33	.0140		.1310	
6-44	.0122		.1135	
7-59	.0105		.0980	
8-76	.0092		.0863	
9				
10				

CONFIGURATION	31
FACILITY	LRC/VDT
TEST	OH-46B
RUN	4565
LENGTH	7.7418 in m.s.
NOSE RADIUS	.006
SCALE	.006
M <sub>∞</sub>	8
P <sub>total</sub> (psia)	= 1455
T <sub>total</sub> (°R)	= 975
R <sub>∞</sub> / ft	= 6 x 10 <sup>6</sup>
T <sub>aw</sub> / T <sub>total</sub>	= .923
T <sub>aw</sub> (°R)	=
T <sub>i</sub> (°F)	= 78
T <sub>pc</sub> (°F)	= 350
h <sub>r=1'</sub>	= .1072
T̄	= .3458
(ρC <sub>p</sub> k) <sup>1/2</sup>	= .0595
α	= 35
β	= 0
Φ	= 0
CAMERA POSITION	TOP
Engineer	W. Dye
	CFFS-HVD

### PHASE CHANGE PAINT TEST



ISOTHERM $T_{\text{rec}}$	h	h/h <sub>ref.</sub>	h/h <sub>r=1'</sub>	N <sub>St, ∞</sub>
1 - 1.3	.0298		.2789	
2 - 1.7	.0261		.2439	
3 - 2.0	.0240		.2248	
4 - 2.6	.0212		.1972	
5 - 3.0	.0196		.1836	
6 - 3.3	.0187		.1750	
7 - 3.6	.0172		.1610	
8 - 4.0	.0155		.1451	
9 - 4.5	.0119		.1117	
10 - 11.0	.0102		.0959	
11 - 14.1	.0090		.0847	

CONFIGURATION	41
FACILITY	LRC/VDT
TEST	OH-46B
RUN	4567
LENGTH	7.7418 in. m.s.
NOSE RADIUS	.006
SCALE	.006
$M_{\infty}$	8
$P_{total}$ (psia)	= 1450
$T_{total}$ ( $^{\circ}R$ )	= 965
$R_{\infty}$ / ft	= $6 \times 10^6$
$T_{aw} / T_{total}$	= .923
$T_{aw}$ ( $^{\circ}R$ )	=
$T_i$ ( $^{\circ}F$ )	= 77
$T_{pc}$ ( $^{\circ}F$ )	= 400
$h_{r=1}$	= .1069
$\bar{T}$	= .4150
$(P_{C_p})^{1/2}$	= .0604
$\alpha$	= 35
$\beta$	= 0
$\phi$	= 0
CAMERA POSITION	TLCP
Engineer	W. Dye
	CFFS-HVD

## PHASE CHANGE PAINT TEST


MISSING

ISOTHERM	h	h/h <sub>ref.</sub>	h/h <sub>r=1'</sub>	N <sub>St,∞</sub>
1				
2				
3				
4				
5				
6				
7				
8				
9				
10				

CONFIGURATION
GRID
FACILITY
TEST
RUNS 4568 thru 4601
LENGTH
NOSE RADIUS
SCALE
M <sub>∞</sub>
P <sub>total</sub> (psia) =
T <sub>total</sub> (°R) =
R <sub>∞</sub> / ft =
T <sub>aw</sub> / T <sub>total</sub> =
T <sub>aw</sub> (°R) =
T <sub>i</sub> (°F) =
T <sub>pc</sub> (°F) =
h <sub>r=1'</sub> =
T̄ =
(ρ C <sub>p</sub> k) <sup>1/2</sup> =
α = 30
β = 0
Φ = 0
CAMERA POSITION
Engineer
CFFS-HVD



# PHASE CHANGE PAINT TEST



ISOTHERM	h	h/h <sub>ref.</sub>	h/h <sub>r=1'</sub>	N <sub>St, ∞</sub>
1 -1.3	.0617		.5081	
2 -2.0	.0497		.4097	
3 -4.1	.0318		.2617	
4 -7.1	.0264		.2174	
5 -11.2	.0210		.1731	
6				
7				
8				
9				
10				

CONFIGURATION 31

FACILITY LRC/VDT

TEST OH46-B

RUN 456B

LENGTH 7.7418 in. m. s.

NOSE RADIUS .006

SCALE .006

M<sub>∞</sub> 8

P<sub>total</sub> (psia) = 1915

T<sub>total</sub> (°R) = 980

R<sub>∞</sub>/ft = 8 x 10<sup>6</sup>

T<sub>aw</sub>/T<sub>total</sub> = .912

T<sub>aw</sub> (°R) = ---

T<sub>i</sub> (°F) = 80

T<sub>pc</sub> (°F) = 550

h<sub>r=1'</sub> = .1214

T̄ = .6078

(ρC<sub>p</sub>k)<sup>1/2</sup> = .0617

α = 30

β = 0


Φ = 0

CAMERA POSITION TOP

Engineer W.D. e

CFFS-HVD


# PHASE CHANGE PAINT TEST



ISOTHERM	h	h/h <sub>ref</sub>	h/h <sub>r=1'</sub>	N <sub>St,∞</sub>
1-13	.0249		.3049	
2-29	.0166		.2075	
3-43	.0136		.1704	
4-57	.0119		.1490	
5-73	.0105		.1308	
6-91	.0094		.1171	
7-119	.0084		.1046	
8-144			.0954	
9				
10				

CONFIGURATION	22
FACILITY	LRC/VDT
TEST	ØH-46B
RUN	4569
LENGTH	7.7418 in. m.s.
NOSE RADIUS	.006
SCALE	.006
M <sub>∞</sub>	8
P <sub>total</sub> (psia)	= 1915
T <sub>total</sub> (°R)	= 980
R <sub>∞</sub> /ft	= 3.5
T <sub>aw</sub> /T <sub>total</sub>	= .912
T <sub>aw</sub> (°R)	=
T <sub>i</sub> (°F)	= 90
T <sub>pc</sub> (°F)	= 550
h <sub>r=1'</sub>	= .0802
T̄	= .3719
(ρC <sub>p</sub> k) <sup>1/2</sup>	= .0595
α	= 30
β	= 0
Φ	= 0
CAMERA POSITION	TOP
Engineer	W. D. J. C.
	CFFS-HVD


PHASE CHANGE PAINT TEST



ISOTHERM	h	h/h <sub>ref</sub>	h/h <sub>r=1'</sub>	N <sub>St,∞</sub>
1 - 13	.0290		.2404	
2 - 26	.0197		.1638	
3 - 41	.0163		.1354	
4 - 43	.0131		.1092	
5 - 79	.0175		.0975	
6				
7				
8				
9				
10				

CONFIGURATION	31
FACILITY	LRC/VDT
TEST	0H46 B
RUN	4570
LENGTH	7.7418 m.m.s.
NOSE RADIUS	.006
SCALE	.006
M <sub>∞</sub>	8
P <sub>total</sub> (psia)	= 1870
T <sub>total</sub> (°R)	= 990
R <sub>∞</sub> / ft	= 8 x 10 <sup>6</sup>
T <sub>aw</sub> / T <sub>total</sub>	= .912
T <sub>aw</sub> (°R)	=
T <sub>i</sub> (°F)	= 82
T <sub>pc</sub> (°F)	= 400
h <sub>r=1'</sub>	= .1204
T̄	= .4075
(ρC <sub>p</sub> k) <sup>1/2</sup>	= .0604
α	= 30
β	= 0
Φ	= 0
CAMERA POSITION	TOP
Engineer	W Dye
	CFFS-HVD


# PHASE CHANGE PAINT TEST



ISOTHERM	h	h/h <sub>ref.</sub>	h/h <sub>r=1'</sub>	N <sub>St,∞</sub>
1-13				
2-47				
3-71				
4-124				
5-163				
6				
7				
8				
9				
10				

CONFIGURATION	22
FACILITY	LRC/VDT
TEST	ØH-46B
RUN	4571
LENGTH	7.7418 IN, M.S.
NOSE RADIUS	.006 M.S.
SCALE	.006
M <sub>∞</sub>	=
P <sub>total</sub> (psia)	= 775
T <sub>total</sub> (°R)	= 825
R <sub>∞</sub> / ft	= 3.5
T <sub>aw</sub> / T <sub>total</sub>	=
T <sub>aw</sub> (°R)	=
T <sub>i</sub> (°F)	= 88
T <sub>pc</sub> (°F)	= 400
h <sub>r=1'</sub>	=
T̄	=
(ρC <sub>p</sub> k) <sup>1/2</sup>	=
α	= 30
β	= 0
Φ	= 0
CAMERA POSITION	TOP
Engineer	W. Dye
	CFFS-HVD

# PHASE CHANGE PAINT TEST



ISOTHERM	h	h/h <sub>ref</sub>	h/h <sub>r=1</sub>	N <sub>St,∞</sub>
1-13	.0361		.4236	
2-32	.0230		.2700	
3-52	.0181		.2118	
4-77	.0148		.1740	
5-110	.0124		.1456	
6-138	.0111		.1300	
7				
8				
9				
10				

CONFIGURATION 22

FACILITY LRC/YDT

TEST ØH-46B

RUN 4572

LENGTH 7.7418 in. m.s.

NOSE RADIUS .006 m.s.

SCALE .006

M<sub>∞</sub> 8

P<sub>total</sub> (psia) = 900

T<sub>total</sub> (°R) = 880

R<sub>∞</sub> / ft = 4.0

T<sub>aw</sub> / T<sub>total</sub> = .912

T<sub>aw</sub> (°R) =

T<sub>i</sub> (°F) = 83

T<sub>pc</sub> (°F) = 400

h<sub>r=1</sub> = .0853

T̄ = .4668

(ρC<sub>p</sub>k)<sup>1/2</sup> = .0604

α = 30

β = 0


φ = 0

CAMERA POSITION TOP

Engineer W. Dye

CFFS-HVD


# PHASE CHANGE PAINT TEST



ISOTHERM	h	h/h <sub>ref</sub>	h/h <sub>r=1</sub>	N <sub>St,∞</sub>
1-3.7	.0153		.3977	
2-6.8	.0113		.2933	
3-8.0	.0104		.2704	
4-12.8	.0082		.2138	
5				
6				
7				
8				
9				
10				

CONFIGURATION	31 Ven D
FACILITY	LRC/VDT
TEST	ØH-46B
RUN	4573
LENGTH	7.7418 in. m.s.
NOSE RADIUS	.006
SCALE	.006
M <sub>∞</sub>	8
P <sub>total</sub> (psia)	= 153
T <sub>total</sub> (°R)	= 750
R <sub>∞</sub> / ft	= 1 x 10 <sup>6</sup>
T <sub>aw</sub> / T <sub>total</sub>	= .912
T <sub>aw</sub> (°R)	=
T <sub>i</sub> (°F)	= 84
T <sub>pc</sub> (°F)	= 300
h <sub>r=1</sub>	= .0386
T <sub>i</sub>	= .3860
(ρC <sub>p</sub> k) <sup>1/2</sup>	= .0586
α	= 30
β	= 0
Φ	= 0
CAMERA POSITION	Top
Engineer	W. Dye
	CFFS-HVD


# PHASE CHANGE PAINT TEST



ISOTHERM	h	h/h <sub>ref</sub>	h/h <sub>r=1'</sub>	N <sub>St,∞</sub>
1-14	.0182		.2175	
2-25	.0136		.1628	
3-32	.0120		.1439	
4-42	.0105		.1256	
5-61	.0087		.1042	
6-67	.0073		.0872	
7-111	.0065		.0772	
8				
9				
10				

CONFIGURATION	22
FACILITY	LRC/VDT
TEST	ØH-46B
RUN	4574
LENGTH	7.7418 in. m.s.
NOSE RADIUS	.006
SCALE	.006
M <sub>∞</sub>	8
P <sub>total</sub> (psia)	= 855
T <sub>total</sub> (°R)	= 915
R <sub>∞</sub> / ft	= 4.0
T <sub>aw</sub> / T <sub>total</sub>	= .912
T <sub>aw</sub> (°R)	=
T <sub>i</sub> (°F)	= 79
T <sub>pc</sub> (°F)	= 300
h <sub>r=1'</sub>	= .0835
T̄	= .3090
(ρC <sub>p</sub> k) <sup>1/2</sup>	= .0586
α	= 30
β	= 0
Φ	= 0
CAMERA POSITION	TOP
Engineer	L.W. Dye
	CFFS-HVD

# PHASE CHANGE PAINT TEST




CONFIGURATION	31 ven. 0
FACILITY	LRC/VDT
TEST	OH-46B
RUN	4575
LENGTH	7.7418 in. m. s.
NOSE RADIUS	.006
SCALE	.006
$M_\infty$	
$P_{total}$ (psia)	= 172
$T_{total}$ ( $^{\circ}R$ )	= 825
$R_\infty / ft$	= $1 \times 10^6$
$T_{aw} / T_{total}$	=
$T_{aw}$ ( $^{\circ}R$ )	=
$T_i$ ( $^{\circ}F$ )	= 76
$T_{pc}$ ( $^{\circ}F$ )	= 200
$h_{r=1}$	=
$\bar{T}$	=
$(\rho C_p k)^{1/2}$	=
$\alpha$	= 30
$\beta$	= 0
$\Phi$	= 0
CAMERA POSITION	TOP
Engineer	W.Dye
	CFFS-HVD

ISOTHERM	h	h/h <sub>ref.</sub>	h/h <sub>r=1</sub>	$N_{St,\infty}$
1 16				
2 32				
3 46				
4 61				
5 76				
6 100				
7 119				
8 138				
9 166				
10				



# PHASE CHANGE PAINT TEST



ISOTHERM	h	h/h <sub>ref</sub>	h/h <sub>r=1</sub>	N <sub>St,∞</sub>
1	3.6	.0201	.5238	
2	7.9	.0136	.3536	
3	144	.0101	.2619	
4	182	.0099	.2330	
5				
6				
7				
8				
9				
10				

CONFIGURATION 31 VEN. 30

FACILITY LRC/VDT

TEST OH46B

RUN 4577

LENGTH 7.7418 in. m.s.

NOSE RADIUS .006

SCALE .006

M<sub>∞</sub> 8

P<sub>total</sub> (psia) = 150

T<sub>total</sub> (°R) = 795

R<sub>∞</sub>/ft = 1 x 10<sup>6</sup>

T<sub>aw</sub>/T<sub>total</sub> = .912

T<sub>aw</sub> (°R) =

T<sub>i</sub> (°F) = 76

T<sub>pc</sub> (°F) = 350

h<sub>r=1</sub> = .0384

T̄ = -4302

(ρC<sub>p</sub>k)<sup>1/2</sup> = .0595

α = 30

β = 0


φ = 0

CAMERA POSITION TOP

Engineer K. Dye

CFFS-HVD


# PHASE CHANGE PAINT TEST



ISOTHERM	h	h/h <sub>ref.</sub>	h/h <sub>r=1'</sub>	N <sub>St, ∞</sub>
1-13	.0109		.2818	
2-35	.0067		.1717	
3-68	.0048		.1232	
4-113	.0037		.0956	
5				
6				
7				
8				
9				
10				

CONFIGURATION	31 ven. 30
FACILITY	LRC/VDT
TEST	ØH-46B
RUN	4579
LENGTH	7.7418 in. m.s.
NOSE RADIUS	.006
SCALE	.006
M <sub>∞</sub>	8
P <sub>total</sub> (psia)	= 156
T <sub>total</sub> (°R)	= 765
R <sub>∞</sub> / ft	= 1 x 10 <sup>6</sup>
T <sub>aw</sub> / T <sub>total</sub>	= .912
T <sub>aw</sub> (°R)	=
T <sub>i</sub> (°F)	= 76
T <sub>pc</sub> (°F)	= 200
h <sub>r=1'</sub>	= .0388
T̄	=
(ρC <sub>p</sub> k) <sup>1/2</sup>	= .0546
α	= 30
β	= 0
Φ	= 0
CAMERA POSITION	TOP
Engineer	W. Dye
	CFFS-HVD


# PHASE CHANGE PAINT TEST



ISOTHERM	h	h/h <sub>ref.</sub>	h/h <sub>r=1'</sub>	N <sub>St,∞</sub>
1 - 13	.0607		.8417	
2 - 13	.0516		.7153	
3 - 58	.0287		.3985	
4 - 93	.0227		.3147	
5				
6				
7				
8				
9				
10				

CONFIGURATION	31 ven 30
FACILITY	LRC/VDT
TEST	OH468
RUN	4581
LENGTH	7.7418 in. m.s.
NOSE RADIUS	.006
SCALE	.006
M <sub>∞</sub>	8
P <sub>total</sub> (psia)	= 625
T <sub>total</sub> (°R)	= 895
R <sub>∞</sub> / ft	= 3.0 x 10 <sup>6</sup>
T <sub>aw</sub> / T <sub>total</sub>	= .912
T <sub>aw</sub> (°R)	=
T <sub>i</sub> (°F)	= 80
T <sub>pc</sub> (°F)	= 500
h <sub>r=1'</sub>	= .07215
T̄	= .6037
(ρC <sub>p</sub> k) <sup>1/2</sup>	= .0617
α	= 30
β	= 0
Φ	= 0
CAMERA POSITION	TOP
Engineer	W. Dye
	CFFS-HVD


# PHASE CHANGE PAINT TEST



ISOTHERM	h	h/h <sub>ref</sub>	h/h <sub>r=1</sub>	N <sub>St,∞</sub>
1-13	.0201		.2789	
2-21	.0158		.2194	
3-26	.0142		.1972	
4-33	.0126		.1750	
5-47	.0106		.1467	
6-76	.0083		.1153	
7-120	.0066		.0918	
8				
9				
10				

CONFIGURATION	31 ven 30
FACILITY	LRC/VDT
TEST	OH-46B
RUN	4582
LENGTH	7.7418
NOSE RADIUS	.006
SCALE	.006
M <sub>∞</sub>	8
P <sub>total</sub> (psia)	= 620
T <sub>total</sub> (°R)	= 880
R <sub>∞</sub> / ft	= 3 x 10 <sup>6</sup>
T <sub>aw</sub> / T <sub>total</sub>	= .912
T <sub>aw</sub> (°R)	=
T <sub>i</sub> (°F)	= 79
T <sub>pc</sub> (°F)	= 300
h <sub>r=1</sub>	= .0719
T̄	= .3235
(ρC <sub>p</sub> k) <sup>1/2</sup>	= .0586
α	= 30
β	= 0
Φ	= 0
CAMERA POSITION	TOP
Engineer	w. Dye
	CFFS-HVD

# PHASE CHANGE PAINT TEST



ISOTHERM	h	h/h <sub>ref.</sub>	h/h <sub>r=1'</sub>	N <sub>St,∞</sub>
1-13	.0634		.5983	
2-22	.0407		.4599	
3-34	.0392		.3699	
4-72	.0269		.2592	
5-111	.0217		.2097	
6				
7				
8				
9				
10				

CONFIGURATION 31 VEN. 30

FACILITY LRC/VDT

TEST ØH-46B

RUN 4583

LENGTH 7.7418 in. m.s.

NOSE RADIUS .006

SCALE .006

M<sub>∞</sub> 8

P<sub>total</sub> (psia) = 1430

T<sub>total</sub> (°R) = 970

R<sub>∞</sub>/ft = 6 × 10<sup>6</sup>

T<sub>aw</sub>/T<sub>total</sub> = .912

T<sub>aw</sub> (°R) =

T<sub>i</sub> (°F) = 80

T<sub>pc</sub> (°F) = 550

h<sub>r=1'</sub> = .1059

T̄ = .6150

(ρC<sub>p</sub>k)<sup>1/2</sup> = .0617

α = 30

β = 0


Φ = 0

CAMERA POSITION TOP

Engineer W. DYE

CFFS-HVD

# PHASE CHANGE PAINT TEST



CONFIGURATION 31 VEN. 30

FACILITY LRC/VDT

TEST OH-46B

RUN 4584

LENGTH 7.7418 in. m.s.

NOSE RADIUS .006

SCALE .006

$M_{\infty}$  8

$P_{total}$  (psia) = 1405

$T_{total}$  ( $^{\circ}R$ ) = 985

$R_{\infty}/ft = 6 \times 10^6$

$T_{aw}/T_{total} = .912$

$T_{aw}$  ( $^{\circ}R$ ) =

$T_i$  ( $^{\circ}F$ ) = 82

$T_{pc}$  ( $^{\circ}F$ ) = 350

$h_{r=1} = .1055$

$\bar{T} = .3454$

$(\rho C_p k)^{1/2} = .0595$

$\alpha = 30$

$\beta = 0$

$\phi = 0$


CAMERA POSITION TOP

Engineer W. DYE

CFFS-HVD

ISOTHERM	h	$h/h_{ref}$	$h/h_{r=1}$	$N_{St,\infty}$
1-13	.0232		.2203	
2-17	.0185		.1751	
3-47	.0117		.1113	
4-79	.0091		.0859	
5				
6				
7				
8				
9				
10				

# PHASE CHANGE PAINT TEST



ISOTHERM	h	h/h <sub>ref.</sub>	h/h <sub>r=1'</sub>	N <sub>St, ∞</sub>
1-42	.0254		.3498	
2-75	.0189		.2618	
3-128	.0145		.2003	
4-156	.0132		.1815	
5				
6				
7				
8				
9				
10				

CONFIGURATION 31 YENO

FACILITY LRC/VDT

TEST OH-46B

RUN 4586

LENGTH 7.7418

NOSE RADIUS .006

SCALE .006

M<sub>∞</sub> 8

P<sub>total</sub> (psia) = 630

T<sub>total</sub> (°R) = 900

R<sub>∞</sub>/ft = 3 × 10<sup>6</sup>

T<sub>aw</sub>/T<sub>total</sub> = .912

T<sub>aw</sub> (°R) =

T<sub>i</sub> (°F) = 82

T<sub>pc</sub> (°F) = 450

h<sub>r=1'</sub> = .0725

T̄ = .5270

(ρC<sub>p</sub>k)<sup>1/2</sup> = .0613

α = 30

β = 0

Φ = 0


CAMERA POSITION TOP

Engineer W. Dye

CFFS-HVD

# PHASE CHANGE PAINT TEST


CONFIGURATION	31 ver. 0
FACILITY	LRC/VDT
TEST	OH-46B
RUN	4588
LENGTH	7.7418 in. m.s
NOSE RADIUS	.006
SCALE	.006
$M_\infty$	8
$P_{total}$ (psia)	= 635
$T_{total}$ (°R)	= 905
$R_\infty / ft$	= $3 \times 10^6$
$T_{aw} / T_{total}$	= .912
$T_{aw}$ (°R)	=
$T_i$ (°F)	= 82
$T_{pc}$ (°F)	= 250
$h_{r=1'}$	= .0728
$\bar{T}$	= .239
$(\rho C_p k)^{1/2}$	= .0574
$\alpha$	= 30
$\beta$	= 0
$\phi$	= 0
CAMERA POSITION	TOP
Engineer	W.P. 0
	CFFS-HVD



ISOTHERM	h	$h/h_{ref.}$	$h/h_{r=1'}$	$N_{St, \infty}$
1-13	.0132		.1817	
2-21	.0104		.1430	
3-41	.0074		.1023	
4-59	.0062		.0853	
5-61	.0051		.0698	
6				
7				
8				
9				
10				



# PHASE CHANGE PAINT TEST



ISOTHERM	h	h/h <sub>ref</sub>	h/h <sub>r=1'</sub>	N <sub>St, ∞</sub>
1-13	.0657		.6297	
2-24	.0483		.4634	
3-35	.0400		.3837	
4-80	.0265		.2538	
5-110	.0226		.2165	
6				
7				
8				
9				
10				

CONFIGURATION 31VEN. O

FACILITY LRC/VDT

TEST OH46-B

RUN 4590

LENGTH 7.7418 in. m.s

NOSE RADIUS .006

SCALE .006

M<sub>∞</sub> 8

P<sub>total</sub> (psia) = 1385

T<sub>total</sub> (°R) = 960

R<sub>∞</sub> / ft = 6 x 10<sup>6</sup>

T<sub>aw</sub> / T<sub>total</sub> = .912

T<sub>aw</sub> (°R) =

T<sub>i</sub> (°F) = 76

T<sub>pc</sub> (°F) = 550

h<sub>r=1'</sub> = .1043

T̄ = .6245

(ρC<sub>p</sub>k)<sup>1/2</sup> = .0617

α = 30

β = 0


φ = 0

CAMERA POSITION TOP

Engineer L. Dyc

CFFS-HVD

# PHASE CHANGE PAINT TEST



CONFIGURATION 31 VEN. 0

FACILITY LRC/VDT

TEST 0H-46B

RUN 4591

LENGTH 7.7418 in. m.s.

NOSE RADIUS .006

SCALE .006

$M_\infty$  8

$P_{total}$  (psia) = 1390

$T_{total}$  ( $^{\circ}R$ ) = 950

$R_\infty / ft$  =  $6 \times 10^6$

$T_{aw} / T_{total}$  = .912

$T_{aw}$  ( $^{\circ}R$ ) =

$T_i$  ( $^{\circ}F$ ) = 79

$T_{pc}$  ( $^{\circ}F$ ) = 400

$h_{r=1}$  = .1047

$\bar{T}$  = .4298

$(P_{C,p})^{1/2}$  = .0604

$\alpha$  = 30

$\beta$  = 0

$\Phi$  = 0


CAMERA POSITION TOP

Engineer W. Dye

CFFS-HVD

ISOTHERM	h	h/h <sub>ref.</sub>	h/h <sub>r=1</sub>	N <sub>St,∞</sub>
1-13	.0315		.3009	
2-25	.0227		.2169	
3-36	.0189		.1808	
4-64	.0142		.1356	
5-86	.0122		.1170	
6-112	.0173		.1025	
7				
8				
9				
10				

## PHASE CHANGE PAINT TEST



ISOTHERM	h	h/h <sub>ref.</sub>	h/h <sub>r=1'</sub>	N <sub>St,∞</sub>
1-13	.0644		.5336	
2-45	.0346		.2868	
3-61	.0258		.2138	
4				
5				
6				
7				
8				
9				
10				

CONFIGURATION 31 ven. 0

FACILITY LRC/VDT

TEST  $\phi H-46 B$ 

RUN 4592

LENGTH 7.7418 in. m.s.

NOSE RADIUS .006

SCALE .006


 $M_{\infty}$  8 $P_{total}$  (psia) = 1895 $T_{total}$  (°R) = 965 $R_{\infty}/ft$  =  $8 \times 10^6$  $T_{aw}/T_{total}$  = .912 $T_{aw}$  (°R) = $T_i$  (°F) = 79 $T_{pc}$  (°F) = 550 $h_{r=1'}$  = .1207 $\bar{T}$  = .6192 $(\rho C_p k)^{1/2}$  = .0417 $\alpha$  = 30 $\beta$  = 0 $\Phi$  = 0

CAMERA POSITION TOP

Engineer W Dye

CFFS-HVD


# PHASE CHANGE PAINT TEST



ISOTHERM	h	h/h <sub>ref.</sub>	h/h <sub>r=1"</sub>	N <sub>St,∞</sub>
1-13	.0312		.2580	
2-25	.0225		.1860	
3-39	.0180		.1489	
4-64	.0141		.1163	
5				
6				
7				
8				
9				
10				

CONFIGURATION	31 ver. ①
FACILITY	LRC/VDT
TEST	Φ446 B
RUN	4593
LENGTH	7.7418 in. m.s
NOSE RADIUS	.006
SCALE	.006
M <sub>∞</sub>	8
P <sub>total</sub> (psia)	= 1895
T <sub>total</sub> (°R)	= 955
R <sub>∞</sub> / ft	= 8 × 10 <sup>6</sup>
T <sub>aw</sub> / T <sub>total</sub>	= .912
T <sub>aw</sub> (°R)	=
T <sub>i</sub> (°F)	= 79
T <sub>pc</sub> (°F)	= 400
h <sub>r=1"</sub>	= .1209
T̄	= .4272
(ρC <sub>p</sub> k) <sup>1/2</sup>	= .0604
α	= 30
β	= 0
φ	= 0
CAMERA POSITION	TOP
Engineer	W. Dye
	CFFS-HVD


# PHASE CHANGE PAINT TEST



ISOTHERM	h	h/h <sub>ref.</sub>	h/h <sub>r=1'</sub>	N <sub>St,∞</sub>
1-56	.0127		.3310	
2-120	.0087		.2261	
3-152	.0077		.2009	
4				
5				
6				
7				
8				
9				
10				

CONFIGURATION	41
FACILITY	LRC/VDT
TEST	OH-46B
RUN	4594
LENGTH	7.7418 in. m.s.
NOSE RADIUS	.006
SCALE	.006
M <sub>∞</sub>	0
P <sub>total</sub> (psia)	= 152
T <sub>total</sub> (°R)	= 755
R <sub>∞</sub> / ft	= 1X10 <sup>6</sup>
T <sub>aw</sub> / T <sub>total</sub>	= .912
T <sub>aw</sub> (°R)	=
T <sub>i</sub> (°F)	= 76
T <sub>pc</sub> (°F)	= 300
h <sub>r=1'</sub> / l	= .0385
T̄	= .3916
(ρC <sub>p</sub> k) <sup>1/2</sup>	= .0586
α	= 30
β	= 0
Φ	= 0
CAMERA POSITION	TOP
Engineer	Widye
CFFS-HVD	


PHASE CHANGE PAINT TEST



ISOTHERM	h	h/h <sub>ref.</sub>	h/h <sub>r=1"</sub>	N <sub>St,∞</sub>
1-14	.0355		.4899	
2-31	.0239		.3292	
3-58	.0174		.2407	
4-98	.0134		.1852	
5-154	.0107		.1477	
6				
7				
8				
9				
10				

CONFIGURATION	41
FACILITY	LRC/VDT
TEST	ØH-46B
RUN	4595
LENGTH	7.7418 in. m.s.
NOSE RADIUS	.006
SCALE	.006
M <sub>∞</sub>	8
P <sub>total</sub> (psia)	= 630
T <sub>total</sub> (°R)	= 880
R <sub>∞</sub> / ft	= 3 x 10 <sup>6</sup>
T <sub>aw</sub> / T <sub>total</sub>	= .912
T <sub>aw</sub> (°R)	=
T <sub>i</sub> (°F)	= .76
T <sub>pc</sub> (°F)	= 400
h <sub>r=1"</sub>	= .0725
T̄	= .4722
(ρC <sub>p</sub> k) <sup>1/2</sup>	= .0604
α	= 30°
β	= 0
Φ	= 0
CAMERA POSITION	TOP
Engineer	W.Dye
	CFFS-HVD


# PHASE CHANGE PAINT TEST



ISOTHERM	h	h/h <sub>ref.</sub>	h/h <sub>r=1'</sub>	N <sub>St,∞</sub>
1-43	.0385		.3497	
2-51	.0353		.3395	
3-70	.0301		.2899	
4-98	.0255		.2449	
5-135	.0217		.2087	
6				
7				
8				
9				
10				

CONFIGURATION	41
FACILITY	LRC/VDT
TEST	ØH-46B
RUN	4596
LENGTH	7.7418 in. m.s.
NOSE RADIUS	.006
SCALE	.006
M <sub>∞</sub>	8
P <sub>total</sub> (psia)	= 1380
T <sub>total</sub> (°R)	= 940
R <sub>∞</sub> / ft	= 6 × 10 <sup>6</sup>
T <sub>aw</sub> / T <sub>total</sub>	= .912
T <sub>aw</sub> (°R)	=
T <sub>i</sub> (°F)	= 74
T <sub>pc</sub> (°F)	= 550
h <sub>r=1'</sub>	= .10399
T̄	= .6408
(ρC <sub>p</sub> k) <sup>1/2</sup>	= .0617
α	= 30
β	= 0
Φ	= 0
CAMERA POSITION	TOP
Engineer	W. Dye
	CFFS-HVD

## PHASE CHANGE PAINT TEST




ISOTHERM	h	h/h <sub>ref</sub>	h/h <sub>r=1'</sub>	N <sub>St, ∞</sub>
1-13	.0185		.2745	
2-37	.0064		.1627	
3-64	.0049		.1237	
4-86	.0042		.1067	
5-111	.0037		.0939	
6-148	.0032		.0814	
7				
8				
9				
10				

CONFIGURATION	41
FACILITY	LRC/VDT
TEST	OH46 B
RUN	4597
LENGTH	7.7418 in. m.s.
NOSE RADIUS	.006
SCALE	.006
M <sub>∞</sub>	8
P <sub>total</sub> (psia)	= 163
T <sub>total</sub> (°R)	= 765
R <sub>∞</sub> / ft	= 1 × 10 <sup>6</sup>
T <sub>aw</sub> / T <sub>total</sub>	= .912
T <sub>aw</sub> (°R)	=
T <sub>i</sub> (°F)	= 77
T <sub>pc</sub> (°F)	= 200
h <sub>r=1'</sub>	= .0395
T̄	= .2120
(ρC <sub>p</sub> k) <sup>1/2</sup>	= .0546
α	= 30
β	= 0
Φ	= 0
CAMERA POSITION	TOP
Engineer	W. Dye
	CFFS-HVD



# PHASE CHANGE PAINT TEST



ISOTHERM	h	h/h <sub>ref</sub>	h/h <sub>r=1'</sub>	N <sub>St,∞</sub>
1-3.3	.0154		.4138	
2-8.1	.0099		.2641	
3-9.8	.0091		.2401	
4-13.0	.0082		.2170	
5-13.9	.0065		.1729	
6-20.9	.0062		.1644	
7				
8				
9				
10				

CONFIGURATION 41VEN 30

FACILITY LRC/VDT

TEST OH-46B

RUN 4598

LENGTH 7.7418 in. m s.

NOSE RADIUS .006

SCALE .006

M<sub>∞</sub> 8

P<sub>total</sub> (psia) = 145

T<sub>total</sub> (°R) = 780

R<sub>∞</sub> / ft = 1 x 10<sup>6</sup>

T<sub>aw</sub> / T<sub>total</sub> = .912

T<sub>aw</sub> (°R) =

T<sub>i</sub> (°F) = 76

T<sub>pc</sub> (°F) = 300

h<sub>r=1'</sub> = .0379

T̄ =

(ρC<sub>p</sub>k)<sup>1/2</sup> = .0586

α = 30

β = 0


Φ = 0

CAMERA POSITION TOP

Engineer W.Dye

CFFS-HVD

## PHASE CHANGE PAINT TEST



ISOTHERM	h	h/h <sub>ref.</sub>	h/h <sub>r=1'</sub>	N <sub>St,∞</sub>
1-27	.0322		.4422	
2-39	.0268		.3679	
3-80	.0187		.2569	
4-97	.0170		.2333	
5-131	.0146		.2007	
6				
7				
8				
9				
10				

CONFIGURATION	41ven 30
FACILITY	LRC/YDT
TEST	
RUN	4599
LENGTH	7.7418 in m.s.
NOSE RADIUS	.006
SCALE	.006
M <sub>∞</sub>	8
P <sub>total</sub> (psia)	= 635
T <sub>total</sub> (°R)	= 900
R <sub>∞</sub> / ft	= 3 × 10 <sup>6</sup>
T <sub>aw</sub> / T <sub>total</sub>	= .912
T <sub>aw</sub> (°R)	=
T <sub>i</sub> (°F)	= 75
T <sub>pc</sub> (°F)	= 450
h <sub>r=1'</sub>	= .0728
T̄	= .5317
(ρC <sub>p</sub> k) <sup>1/2</sup>	= .0613
α	= 30
β	= 0
Φ	= 0
CAMERA POSITION	TOP
Engineer	W. Dye
	CFFS-HVD

# PHASE CHANGE PAINT TEST

CONFIGURATION 41 ven 30

FACILITY LRC/VDT

TEST OH-46B

RUN 4600

LENGTH 7.7418 in m.s.

NOSE RADIUS .006

SCALE .006

$M_\infty$  8

$P_{total}$  (psia) = 163

$T_{total}$  (°R) = 805

$R_\infty / ft = 1 \times 10^6$

$T_{aw} / T_{total} = .912$

$T_{aw}$  (°R) = 7

$T_i$  (°F) = 76

$T_{pc}$  (°F) = 200

$h_{r=1} = .0397$

$\bar{T} = .2007$

$(\rho C_p k)^{1/2} = .0516$

$\alpha = 30$

$\beta = 0$

$\Phi = 0$


CAMERA POSITION TOP

Engineer W.Dye

CFFS-HVD

ISOTHERM	h	h/h <sub>ref.</sub>	h/h <sub>r=1</sub>	N <sub>St,∞</sub>
1-2.0	.0082		.2066	
2-2.5	.0073		.1847	
3-3.3	.0064		.1608	
4-4.3	.0056		.1409	
5-7.8	.0041		.1046	
6-110	.0035		.0881	
7-154	.0029		.0744	
8				
9				
10				

# PHASE CHANGE PAINT TEST



ISOTHERM	h	h/h <sub>ref.</sub>	h/h <sub>r=1'</sub>	N <sub>St,∞</sub>
1-13	.0189		.2567	
2-17	.0165		.2245	
3-22	.0145		.1973	
4-32	.0121		.1636	
5-50	.0097		.1308	
6-98	.0069		.0935	
7				
8				
9				
10				

CONFIGURATION 41 ven 30

FACILITY LRC/VDT

TEST ØH-46B

RUN 4601

LENGTH 7.7418 m.m.s.

NOSE RADIUS .006

SCALE .006

M<sub>∞</sub> 8

P<sub>total</sub> (psia) = 650

T<sub>total</sub> (°R) = 920

R<sub>∞</sub> / ft = 3 x 10<sup>6</sup>

T<sub>aw</sub> / T<sub>total</sub> = .912

T<sub>aw</sub> (°R) =

T<sub>i</sub> (°F) = 76

T<sub>pc</sub> (°F) = 300

h<sub>r=1'</sub> = .0737

T̄ = .3100

(ρC<sub>p</sub>k)<sup>1/2</sup> = .0586

α = 30

β = 0


Φ = 0

CAMERA POSITION TOP

Engineer W. Dye

CFFS-HVD


# PHASE CHANGE PAINT TEST



ISOTHERM	h	h/h <sub>ref.</sub>	h/h <sub>r=1'</sub>	N <sub>St, ∞</sub>
1				
2				
3				
4				
5				
6				
7				
8				
9				
10				

CONFIGURATION	22, 31, 41
GRID	
FACILITY	L RC / VDT
TEST	ØH-46B
RUNS	4556 thru 4593
LENGTH	7.7418 in m.s.
NOSE RADIUS	.006
SCALE	.006
M <sub>∞</sub>	
P <sub>total</sub> (psia) =	
T <sub>total</sub> (°R) =	
R <sub>∞</sub> / ft =	
T <sub>aw</sub> / T <sub>total</sub> =	
T <sub>aw</sub> (°R) =	
T <sub>i</sub> (°F) =	
T <sub>pc</sub> (°F) =	
h <sub>r=1'</sub> =	
T̄ =	
(ρC <sub>p</sub> k) <sup>1/2</sup> =	
α = 30° 35'	
β =	
Φ =	
CAMERA POSITION	SIDE
Engineer	W. Dye
	CFFS-HVD


# PHASE CHANGE PAINT TEST



ISOTHERM	h	h/h <sub>ref.</sub>	h/h <sub>r=1'</sub>	N <sub>St, ∞</sub>
1-13	.0158		.4021	
2-38	.0092		.2352	
3-60	.0073		.1871	
4-87	.0061		.1554	
5-122	.0051		.1312	
6-186	.0042		.1063	
7				
8				
9				
10				

CONFIGURATION	22
FACILITY	LRC/VDT
TEST	PH-46B
RUN	4556
LENGTH	7.7418 in m.s.
NOSE RADIUS	.006
SCALE	.006
M <sub>∞</sub>	8
P <sub>total</sub> (psia)	= 157
T <sub>total</sub> (°R)	= 840
R <sub>∞</sub> / ft	= 1 x 10 <sup>6</sup>
T <sub>aw</sub> / T <sub>total</sub>	= .90
T <sub>aw</sub> (°R)	=
T <sub>i</sub> (°F)	= 76
T <sub>pc</sub> (°F)	= 250
h <sub>r=1'</sub>	= .0392
T̄	= .2744
(Pc <sub>p</sub> k) <sup>1/2</sup>	= .0574
α	= 35
β	= 0
φ	= 0
CAMERA POSITION	SIDE
Engineer	W. Dye F. L. HARRIS
	CFFS-HVD

# PHASE CHANGE PAINT TEST



ISOTHERM	h	h/h <sub>ref.</sub>	h/h <sub>r=1'</sub>	N <sub>St,∞</sub>
1-13	.0242		.6182	
2-107	.0084		.2155	
3-135	.0075		.1918	
4				
5				
6				
7				
8				
9				
10				

CONFIGURATION 41

FACILITY LRC/VDT

TEST PH-4613

RUN 4557

LENGTH 7.7418 m.m.s.

NOSE RADIUS .006

SCALE .006

M<sub>∞</sub> 0

P<sub>total</sub> (psia) = 157

T<sub>total</sub> (°R) = 815

R<sub>∞</sub> / ft = 1 x 10<sup>6</sup>

T<sub>aw</sub> / T<sub>total</sub> = .90

T<sub>aw</sub> (°R) =

T<sub>i</sub> (°F) = 73

T<sub>pc</sub> (°F) = 300

h<sub>r=1'</sub> = .0392

T̄ = .3694

(ρC<sub>p</sub>k)<sup>1/2</sup> = .0586

α = 35

β = 0


φ = 0

CAMERA POSITION 51°E

Engineer W Dye

CFFS-HVD

# PHASE CHANGE PAINT TEST




ISOTHERM	h	h/h <sub>ref.</sub>	h/h <sub>r=1'</sub>	N <sub>St, ∞</sub>
1-13	.0548		.5169	
2-38	.0321		.3023	
3-59	.0257		.2427	
4-78	.0224		.2110	
5-100	.0198		.1864	
6-118	.0182		.1716	
7-132	.0172		.1622	
8				
9				
10				

CONFIGURATION	31
FACILITY	LRC/VDT
TEST	ΦH-46B
RUN	3 (455B)
LENGTH	7.7418 in m.i.s.
NOSE RADIUS	.006
SCALE	.006
M <sub>∞</sub>	8
P <sub>total</sub> (psia)	= 1435
T <sub>total</sub> (°R)	= 955
R <sub>∞</sub> / ft	= 6 x 10 <sup>6</sup>
T <sub>aw</sub> / T <sub>total</sub>	= .9
T <sub>aw</sub> (°R)	=
T <sub>i</sub> (°F)	= 74
T <sub>pc</sub> (°F)	= 500
h <sub>r=1'</sub>	= .1061
T̄	= .5761
(ρC <sub>p</sub> k) <sup>1/2</sup>	= .0617
α	= 35°
β	= 0
Φ	= 0
CAMERA POSITION	51.2E
Engineer	U Dye
	CFFS-HVD




# PHASE CHANGE PAINT TEST



ISOTHERM	h	h/h <sub>ref.</sub>	h/h <sub>r=1'</sub>	N <sub>St,∞</sub>
1 -61	.00305		.0805	
2 -170	.0021		.0536	
3				
4				
5				
6				
7				
8				
9				
10				

CONFIGURATION	31
FACILITY	LRC/VDT
TEST	ØH-46B
RUN	4561
LENGTH	7.7418 in m.s.
NOSE RADIUS	.006
SCALE	.006
M <sub>∞</sub>	8
P <sub>total</sub> (psia)	= 146
T <sub>total</sub> (°R)	= 815
R <sub>∞</sub> / ft	= 1 x 10 <sup>6</sup>
T <sub>aw</sub> / T <sub>total</sub>	= .9
T <sub>aw</sub> (°R)	=
T <sub>i</sub> (°F)	= 78
T <sub>pc</sub> (°F)	= 175
h <sub>r=1'</sub>	= .0379
T̄	= .0379
(ρC <sub>p</sub> k) <sup>1/2</sup>	= .0537
α	= 35
β	= 0
Φ	= 0
CAMERA POSITION	SIDE
Engineer	W Dye
	CFFS-HVD


# PHASE CHANGE PAINT TEST



ISOTHERM	h	h/h <sub>ref</sub>	h/h <sub>r=1</sub>	N <sub>St,∞</sub>
1-63	.0098		.0933	
2-67	.0079		.0743	
3-94	.0066		.0631	
4-119	.0059		.0561	
5				
6				
7				
8				
9				
10				

CONFIGURATION	22
FACILITY	LRC/VDI
TEST	OH46B
RUN	4562
LENGTH	7.7418 in. m.s.
NOSE RADIUS	.006
SCALE	.006
M <sub>∞</sub>	8
P <sub>total</sub> (psia)	= 1380
T <sub>total</sub> (°R)	= 965
R <sub>∞</sub> / ft	= 6 x 10 <sup>6</sup>
T <sub>aw</sub> / T <sub>total</sub>	= .90
T <sub>aw</sub> (°R)	=
T <sub>i</sub> (°F)	= 81.
T <sub>pc</sub> (°F)	= 300
h <sub>r=1</sub>	= .1045
T̄	= .2953
(PC <sub>p</sub> k) <sup>1/2</sup>	= .0586
α	= 35
β	= 0
Φ	= 0
CAMERA POSITION	SIDE
Engineer	W. Dye
	CFFS-HVD

PHASE CHANGE PAINT TEST



ISOTHERM	h	h/h <sub>ref</sub>	h/h <sub>r=1</sub>	N <sub>St,∞</sub>
1-33	.00396		.0540	
2-41	.00355		.0485	
3-58	.00299		.0408	
4-85	.00247		.0337	
5-125	.00204		.0278	
6-153	.00184		.0251	
7				
8				
9				
10				

CONFIGURATION 22

FACILITY LRC/VDT

TEST OH-46 B

RUN 4564

LENGTH 7.7418 in. m.s.

NOSE RADIUS .006

SCALE .006

M<sub>∞</sub> 8

P<sub>total</sub> (psia) = 645

T<sub>total</sub> (°R) = 930

R<sub>∞</sub>/ft = 3.710<sup>6</sup>

T<sub>aw</sub>/T<sub>total</sub> = .90

T<sub>aw</sub> (°R) =

T<sub>i</sub> (°F) = 79

T<sub>pc</sub> (°F) = 175

h<sub>r=1</sub> = .0732

T̄ = .1348

(ρC<sub>p</sub>k)<sup>1/2</sup> = .0537

α = 35

β = 0

Φ = 0

CAMERA POSITION SIDE


Engineer W Dye

CFPS-HVD

# PHASE CHANGE PAINT TEST


CONFIGURATION	31
FACILITY	LRC/YDT
TEST	ØH-46B
RUN	4565
LENGTH	7.7418 in. m.s.
NOSE RADIUS	.006
SCALE	.006
$M_{\infty}$	8
$P_{total}$ (psia)	= 1455
$T_{total}$ (°R)	= 975
$R_{\infty}$ / ft	= $6 \times 10^6$
$T_{aw} / T_{total}$	= .9
$T_{aw}$ (°R)	=
$T_i$ (°F)	= 78
$T_{pc}$ (°F)	= 350
$h_{r=1}$	= .1071
$\bar{T}$	= .3609
$(\rho C_p k)^{1/2}$	= .0595
$\alpha$	= 35
$\beta$	= 0
$\phi$	= 0
CAMERA POSITION	SIDE
Engineer	W. Dye
	CFFS-HVD

156



ISOTHERM	h	h/h <sub>ref.</sub>	h/h <sub>r=1</sub>	N <sub>St,∞</sub>
1 ~ 99	.00862		.0804	
2 - 152	.00696		.0649	
3				
4				
5				
6				
7				
8				
9				
10				


# PHASE CHANGE PAINT TEST



ISOTHERM	h	h/h <sub>ref.</sub>	h/h <sub>r=1'</sub>	N <sub>St, ∞</sub>
1-106	.0090		.1123	
2-143	.00775		.0967	
3				
4				
5				
6				
7				
8				
9				
10				

CONFIGURATION	22
FACILITY	LRC/VDT
TEST	ØH-46B
RUN	4569
LENGTH	7.7418 in. i.s.
NOSE RADIUS	.006
SCALE	.006
M <sub>∞</sub>	8
P <sub>total</sub> (psia)	= 780
T <sub>total</sub> (°R)	= 930
R <sub>∞</sub> / ft	= 3.5 x 10 <sup>6</sup>
T <sub>aw</sub> / T <sub>total</sub>	= .90
T <sub>aw</sub> (°R)	=
T <sub>i</sub> (°F)	= 79
T <sub>pc</sub> (°F)	= 350
h <sub>r=1'</sub>	= .0802
T̄	= 3806
(ρC <sub>p</sub> k) <sup>1/2</sup>	= .0595
α	= 30
β	= 0
Φ	= 0
CAMERA POSITION	SIDE
Engineer	W. Dye
	CFFS-HVD


PHASE CHANGE PAINT TEST



ISOTHERM	h	h/h <sub>ref</sub>	h/h <sub>r=1</sub>	N <sub>St,∞</sub>
1-62	.0137		.1140	
2-110	.0103		.0856	
3				
4				
5				
6				
7				
8				
9				
10				

CONFIGURATION	31
FACILITY	LRC/VDT
TEST	OH-
RUN	4570
LENGTH	7.7418 in.m.s.
NOSE RADIUS	.006
SCALE	.006
M <sub>∞</sub>	8
P <sub>total</sub> (psia)	= 1870
T <sub>total</sub> (°R)	= 990
R <sub>∞</sub> / ft	= 8 × 10 <sup>6</sup>
T <sub>aw</sub> / T <sub>total</sub>	= .90
T <sub>aw</sub> (°R)	=
T <sub>i</sub> (°F)	= 8.2
T <sub>pc</sub> (°F)	= 400
h <sub>r=1</sub>	= .1204
$\bar{I}$	= .4168
(ρC <sub>p</sub> k) <sup>1/2</sup>	= .0604
α	= 30
β	= 0
φ	= 0
CAMERA POSITION	SIDE
Engineer	W. Dye
	CFFS-HVD

# PHASE CHANGE PAINT TEST



CONFIGURATION 31 vend

FACILITY LRC/VDT

TEST 04-46B

RUN 4573

LENGTH 7.7418 in, m.s.

NOSE RADIUS .006

SCALE .006

$M_{\infty}$  8

$P_{total}$  (psia) = 153

$T_{total}$  (°R) = 750

$R_{\infty}/ft$  =  $1 \times 10^6$

$T_{aw}/T_{total}$  = .9

$T_{aw}$  (°R) =

$T_i$  (°F) = 84

$T_{pc}$  (°F) = 300

$h_{r=1}$  = .0386

$\bar{T}$  = .3963

$(\rho C_p k)^{1/2}$  = .0586

$\alpha$  = 30

$\beta$  = 0

$\phi$  = 0


CAMERA POSITION SIDE

Engineer W. Dye

CFFS-HVD

ISOTHERM	h	h/h <sub>ref.</sub>	h/h <sub>r=1</sub>	$N_{St, \infty}$
1-2.2	.0207		.5367	
2-4.0	.0153		.3980	
3-5.1	.0136		.3525	
4-7.0	.0116		.3009	
5				
6				
7				
8				
9				
10				

# PHASE CHANGE PAINT TEST




CONFIGURATION	22
FACILITY	LRC/VDT
TEST	OH-46B
RUN	4574
LENGTH	7.7418 in. m.s.
NOSE RADIUS	.006
SCALE	.006
$M_\infty$	
$P_{total}$ (psia)	= 855
$T_{total}$ ( $^{\circ}R$ )	= 915
$R_\infty$ / ft	= $4 \times 10^6$
$T_{aw} / T_{total}$	=
$T_{aw}$ ( $^{\circ}R$ )	=
$T_i$ ( $^{\circ}F$ )	= 79
$T_{pc}$ ( $^{\circ}F$ )	= 300
$h_{r=1'}$	=
$\bar{T}$	=
$(\rho C_p k)^{1/2}$	=
$\alpha$	= 30
$\beta$	= 0
$\Phi$	= 0
CAMERA POSITION	SIDE
Engineer	W. Dye
	CFFS-HVD

ISOTHERM	h	h/h <sub>ref.</sub>	h/h <sub>r=1'</sub>	N <sub>St, ∞</sub>
1 - 86				
2 - 140				
3				
4				
5				
6				
7				
8				
9				
10				



# PHASE CHANGE PAINT TEST



ISOTHERM	h	h/h <sub>ref.</sub>	h/h <sub>r=l'</sub>	N <sub>St,∞</sub>
1-54	.0113		.1073	
2-66	.0102		.0970	
3-93	.0086		.0817	
4-139	.0071		.0669	
5				
6				
7				
8				
9				
10				

CONFIGURATION 31 ven 30

FACILITY LRC/VDT

TEST ØH-46B

RUN 4584

LENGTH 7.7418 in. m.s.

NOSE RADIUS .006

SCALE .006

M<sub>∞</sub> B

P<sub>total</sub> (psia) = 1405

T<sub>total</sub> (°R) = 985

R<sub>∞</sub> / ft = 6 x 10<sup>6</sup>

T<sub>aw</sub> / T<sub>total</sub> = .90

T<sub>aw</sub> (°R) =

T<sub>i</sub> (°F) = 82

T<sub>pc</sub> (°F) = 350

h<sub>r=l'</sub> = .1055

T̄ = .4420

(ρC<sub>p</sub>k)<sup>1/2</sup> = .0595

α = 30

β = 0


Φ = 0

CAMERA POSITION SIDE

Engineer W. Dye

CFFS-HVD

PHASE CHANGE PAINT TEST



ISOTHERM	h	h/h <sub>ref</sub>	h/h <sub>r=1'</sub>	N <sub>St,∞</sub>
1-2,3	.0359		.4948	
2-3,4	.0295		.4069	
3-4,6	.0254		.3498	
4				
5				
6				
7				
8				
9				
10				

CONFIGURATION	31 ven 0
FACILITY	LRC/VDT
TEST	ØH-46B
RUN	4586
LENGTH	7.7418 in. m.s.
NOSE RADIUS	.006
SCALE	.006
M <sub>∞</sub>	8
P <sub>total</sub> (psia)	= 630
T <sub>total</sub> (°R)	= 900
R <sub>∞</sub> / ft	= 3 x 10 <sup>6</sup>
T <sub>aw</sub> / T <sub>total</sub>	= .90
T <sub>aw</sub> (°R)	=
T <sub>i</sub> (°F)	= 82
T <sub>pc</sub> (°F)	= 450
h <sub>r=1'</sub>	= .0725
$\bar{T}$	= .5396
(ρC <sub>p</sub> k) <sup>1/2</sup>	= .0613
α <sub>∞</sub>	= 30
β <sub>∞</sub>	= 0
Φ	= 0
CAMERA POSITION	SIDE
Engineer	W. Dye
	CFFS-HVD

# PHASE CHANGE PAINT TEST

CONFIGURATION 31vrn 0

FACILITY LRC/VDT

TEST OH 46 B

RUN 4588

LENGTH 7.7418 in. m.s.

NOSE RADIUS .006

SCALE .006

$M_\infty$  .8

$P_{total}$  (psia) = 635

$T_{total}$  (°R) = 905

$R_\infty$  / ft =  $3 \times 10^6$

$T_{aw} / T_{total}$  = .90

$T_{aw}$  (°R) =

$T_f$  (°F) = 82

$T_{pc}$  (°F) = 250

$h_{T=1}$  = .0728

$\bar{T}$  = .2447

$(\rho C_p k)^{1/2}$  = .0574

$\alpha$  = 30

$\beta$  = 0

$\phi$  = 0


CAMERA POSITION SIDE

Engineer W. D. e

CFFS-HVD

ISOTHERM	$h$	$h/h_{ref.}$	$h/h_{r=1}$	$N_{St, \infty}$
1-13	.0136		.1871	
2-60	.0063		.0871	
3-99	.0049		.0678	
4-137	.0042		.0576	
5				
6				
7				
8				
9				
10				

# PHASE CHANGE PAINT TEST



ISOTHERM	h	h/h <sub>ref.</sub>	h/h <sub>r=1'</sub>	N <sub>St,∞</sub>
1-92	.0122		.1006	
2				
3				
4				
5				
6				
7				
8				
9				
10				

CONFIGURATION	31VPH 0
FACILITY	LRC/VDT
TEST	04-46B
RUN	4593
LENGTH	7.7418 in m.s.
NOSE RADIUS	.006
SCALE	.006
M <sub>∞</sub>	B
P <sub>total</sub> (psia)	= 12.15
T <sub>total</sub> (°R)	= 455
R <sub>∞</sub> / ft	= 8 × 10 <sup>6</sup>
T <sub>aw</sub> / T <sub>total</sub>	= .40
T <sub>aw</sub> (°R)	=
T <sub>i</sub> (°F)	= 79
T <sub>pc</sub> (°F)	= 400
h <sub>r=1'</sub>	= .1208
T̄	= .4370
(ρC <sub>p</sub> k) <sup>1/2</sup>	= .0604
α	= 30°
β	= C.
Φ	= C.
CAMERA POSITION	11
Engineer	10 12-1
	CFFS-HVD

APPENDIX  
TABULATED THERMAL DATA FOR EACH TRACING CONTOUR

Note: See Data Reduction Section for definition of contour number and number given on tracings. Also, data are arranged by the same sequential run number as data figures.

RUN=4502 TOP AIR P1 = 034.70  
 TPC = 810.00 DEG-R MINT = 7.936  
 TI = 532.00 DEG-R R/FI = 2.90553E+00  
 TV = 1375.00 DEG-R  
 SROCK= .0395 ALPHA=30.000  
 MODEL=22 PHI= 0.000  
 HS= 7.21644E-02 BTU/FT.SU-SEC-DEG-R

CONTOUR	I, SEC	H, BTU/FT.SU-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/T0
1	1.30	2.61671E-02	3.62003E-01	3.85042E-01	5.01429E-01	9.12000E-01
2	2.10	2.05881E-02	2.85295E-01	3.85042E-01	5.01429E-01	9.12000E-01
3	2.90	1.75197E-02	2.42775E-01	3.85042E-01	5.01429E-01	9.12000E-01
4	3.90	1.51076E-02	2.09349E-01	3.85042E-01	5.01429E-01	9.12000E-01
5	6.10	1.20798E-02	1.67393E-01	3.85042E-01	5.01429E-01	9.12000E-01
6	7.90	1.00140E-02	1.47092E-01	3.85042E-01	5.01429E-01	9.12000E-01
7	8.40	1.02941E-02	1.42047E-01	3.85042E-01	5.01429E-01	9.12000E-01
8	9.10	9.89022E-03	1.37051E-01	3.85042E-01	5.01429E-01	9.12000E-01
9	12.60	8.40507E-03	1.16471E-01	3.85042E-01	5.01429E-01	9.12000E-01
10	13.00	8.27475E-03	1.14665E-01	3.85042E-01	5.01429E-01	9.12000E-01

RUN=4504 TJP AIR PT = 639.70  
 IPC = 800.00 DEG-K MINF = 7.937  
 TI = 336.00 DEG-K R/FT = 3.17441E+06  
 Ts = 1310.00 DEG-K  
 SQRCK = .0504 ALPHA=30.000  
 MODEL=41 PHI= 0.000  
 HS= 7.20267E-02 BTU/FT.SW-SEC-DEG-K

CONTOUR	T, SEC	H, BTU/FT.SW-SEC-DEG-K	H/HS	T-BAR	BETA	TAW/TU
1	2.20	3.04088E-02	4.22188E-01	4.91863E-01	7.46747E-01	9.12000E-01
2	3.40	2.44608E-02	3.39508E-01	4.91863E-01	7.46747E-01	9.12000E-01
3	3.60	2.37717E-02	3.30039E-01	4.91863E-01	7.46747E-01	9.12000E-01
4	4.00	2.25518E-02	3.13103E-01	4.91863E-01	7.46747E-01	9.12000E-01
5	4.50	2.12620E-02	2.95196E-01	4.91863E-01	7.46747E-01	9.12000E-01
6	5.20	1.97792E-02	2.74009E-01	4.91863E-01	7.46747E-01	9.12000E-01
7	6.40	1.78287E-02	2.47529E-01	4.91863E-01	7.46747E-01	9.12000E-01
8	7.40	1.65804E-02	2.30198E-01	4.91863E-01	7.46747E-01	9.12000E-01
9	8.20	1.57508E-02	2.18680E-01	4.91863E-01	7.46747E-01	9.12000E-01
10	9.00	1.50345E-02	2.08735E-01	4.91863E-01	7.46747E-01	9.12000E-01
11	9.50	1.46335E-02	2.03168E-01	4.91863E-01	7.46747E-01	9.12000E-01
12	10.20	1.41225E-02	1.96073E-01	4.91863E-01	7.46747E-01	9.12000E-01
13	11.50	1.33003E-02	1.84658E-01	4.91863E-01	7.46747E-01	9.12000E-01
14	13.20	1.24143E-02	1.72357E-01	4.91863E-01	7.46747E-01	9.12000E-01
15	13.50	1.22304E-02	1.69804E-01	4.91863E-01	7.46747E-01	9.12000E-01
16	14.30	1.19273E-02	1.65596E-01	4.91863E-01	7.46747E-01	9.12000E-01
17	14.60	1.18041E-02	1.63885E-01	4.91863E-01	7.46747E-01	9.12000E-01

RUN=4505 TOP: AIR PI = 544.70  
 TPC = 810.00 DEG-R MINF = 7.938  
 TI = 542.00 DEG-R H/FT = 3.09858E+00  
 T3 = 1335.00 DEG-R  
 SQROCK= .0395 ALPHA=30.000  
 MODEL=31 PHI= 0.000  
 HS= 7.24717E-02 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/T0
1	.10	9.87154E-02	1.36212E+00	3.96731E-01	5.24648E-01	9.12000E-01
2	.30	5.69934E-02	7.86423E-01	3.96731E-01	5.24648E-01	9.12000E-01
3	1.30	2.73787E-02	3.77785E-01	3.96731E-01	5.24648E-01	9.12000E-01
4	2.40	2.01502E-02	2.78042E-01	3.96731E-01	5.24648E-01	9.12000E-01
5	3.10	1.77298E-02	2.44045E-01	3.96731E-01	5.24648E-01	9.12000E-01
6	3.90	1.58071E-02	2.18114E-01	3.96731E-01	5.24648E-01	9.12000E-01
7	4.30	1.50540E-02	2.07722E-01	3.96731E-01	5.24648E-01	9.12000E-01
8	5.50	1.33108E-02	1.83669E-01	3.96731E-01	5.24648E-01	9.12000E-01
9	6.30	1.27441E-02	1.75849E-01	3.96731E-01	5.24648E-01	9.12000E-01
10	6.70	1.20060E-02	1.66410E-01	3.96731E-01	5.24648E-01	9.12000E-01
11	7.50	1.13987E-02	1.57285E-01	3.96731E-01	5.24648E-01	9.12000E-01
12	8.00	1.10367E-02	1.52290E-01	3.96731E-01	5.24648E-01	9.12000E-01
13	8.40	1.07707E-02	1.48620E-01	3.96731E-01	5.24648E-01	9.12000E-01
14	9.40	1.01817E-02	1.40492E-01	3.96731E-01	5.24648E-01	9.12000E-01
15	10.60	9.58609E-03	1.32301E-01	3.96731E-01	5.24648E-01	9.12000E-01
16	12.10	8.97413E-03	1.23829E-01	3.96731E-01	5.24648E-01	9.12000E-01
17	13.00	8.65792E-03	1.19466E-01	3.96731E-01	5.24648E-01	9.12000E-01



RUN=4506 TOP AIR FT = 659.70  
 TPC = 710.00 DEG-R MINF = 7.941  
 TI = 540.00 DEG-R R/FI = 3.05244E+06  
 T0 = 1365.00 DEG-R  
 SQROCK=.0574 ALPHA=30.000  
 MODEL=22 PHI= 0.000  
 HS= 7.3311E-02 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/T0
1	.50	1.70510E-02	2.32585E-01	2.41176E-01	2.65695E-01	9.12000E-01
2	1.30	1.33759E-02	1.82454E-01	2.41176E-01	2.65695E-01	9.12000E-01
3	1.70	1.16969E-02	1.59552E-01	2.41176E-01	2.65695E-01	9.12000E-01
4	1.95	1.10642E-02	1.50921E-01	2.41176E-01	2.65695E-01	9.12000E-01
5	2.00	1.07840E-02	1.47099E-01	2.41176E-01	2.65695E-01	9.12000E-01
6	2.40	9.84442E-03	1.34283E-01	2.41176E-01	2.65695E-01	9.12000E-01
7	3.30	8.39535E-03	1.14517E-01	2.41176E-01	2.65695E-01	9.12000E-01
8	4.70	7.03471E-03	9.59571E-02	2.41176E-01	2.65695E-01	9.12000E-01
9	5.40	6.56295E-03	8.95219E-02	2.41176E-01	2.65695E-01	9.12000E-01
10	6.50	5.98190E-03	8.15961E-02	2.41176E-01	2.65695E-01	9.12000E-01
11	7.80	5.46070E-03	7.44867E-02	2.41176E-01	2.65695E-01	9.12000E-01
12	10.60	4.68428E-03	6.38959E-02	2.41176E-01	2.65695E-01	9.12000E-01
13	13.50	4.15077E-03	5.66186E-02	2.41176E-01	2.65695E-01	9.12000E-01

ORIGINAL PAGE IS  
 OF POOR QUALITY

RUN=4507 TOP AIR PT = 639.70  
 IPC = 760.00 DEG-R MINP = 7.937  
 TI = 542.00 DEG-R R/FT = 3.05629E+00  
 TO = 1340.00 DEG-R \*  
 SQRQCKE=0.0580 ALPHA=50.000  
 MODEL=3T PHI= 0.000  
 HS= 7.22281E-02 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T,SEC	M,BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/TO
1	.50	2.38134E-02	3.29697E-01	3.20551E-01	3.85518E-01	9.12000E-01
2	1.30	1.98139E-02	2.74324E-01	3.20551E-01	3.85518E-01	9.12000E-01
3	1.70	1.73268E-02	2.39890E-01	3.20551E-01	3.85518E-01	9.12000E-01
4	2.00	1.59745E-02	2.21167E-01	3.20551E-01	3.85518E-01	9.12000E-01
5	2.40	1.45827E-02	2.01897E-01	3.20551E-01	3.85518E-01	9.12000E-01
6	2.80	1.35009E-02	1.86920E-01	3.20551E-01	3.85518E-01	9.12000E-01
7	4.00	1.12957E-02	1.56389E-01	3.20551E-01	3.85518E-01	9.12000E-01
8	5.20	9.90090E-03	1.37162E-01	3.20551E-01	3.85518E-01	9.12000E-01
9	7.00	8.53873E-03	1.18219E-01	3.20551E-01	3.85518E-01	9.12000E-01
10	9.00	7.53045E-03	1.04259E-01	3.20551E-01	3.85518E-01	9.12000E-01
11	11.40	6.69098E-03	9.26368E-02	3.20551E-01	3.85518E-01	9.12000E-01
12	11.80	6.57660E-03	9.10531E-02	3.20551E-01	3.85518E-01	9.12000E-01

RUN=4508 TOP AIR PT = 039.70  
 TPC = 700.00 DEG-R MINF = 7.937  
 FI = 540.00 DEG-R R/FT = 3.15419E+06  
 T0 = 1315.00 DEG-R  
 SQROCK= .0586 ALPHA=30.000  
 MODEL=41 PHI= 0.000  
 HS= 7 20884E-02 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FI.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/T0
1	1.30	2.09500E-02	2.90615E-01	3.33697E-01	4.07622E-01	9.12000E-01
2	1.50	1.95034E-02	2.70548E-01	3.33697E-01	4.07622E-01	9.12000E-01
3	2.20	1.61044E-02	2.23398E-01	3.33697E-01	4.07622E-01	9.12000E-01
4	2.30	1.57504E-02	2.18487E-01	3.33697E-01	4.07622E-01	9.12000E-01
5	3.50	1.27679E-02	1.77115E-01	3.33697E-01	4.07622E-01	9.12000E-01
6	4.00	1.11372E-02	1.54494E-01	3.33697E-01	4.07622E-01	9.12000E-01
7	5.20	9.91839E-03	1.37587E-01	3.33697E-01	4.07622E-01	9.12000E-01
8	7.00	9.02830E-03	1.25239E-01	3.33697E-01	4.07622E-01	9.12000E-01
9	10.00	7.33672E-03	1.01774E-01	3.33697E-01	4.07622E-01	9.12000E-01

ORIGINAL PAGE IS  
 OF POOR QUALITY

RUN=4509 TOP AIR "PT" = 177.70  
TPC = 760.00 DEG-R MINF = 7.761  
T1 = 540.00 DEG-R R/FT = 1.01280E+06  
T2 = 1245.00 DEG-R  
SQROCK = .0586 ALPHA = 30.000  
MODEL = 22 PHI = 0.000  
HS = 3.97190E-02 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/T0
1	2.00	1.95430E-02	4.92031E-01	3.69475E-01	4.71638E-01	9.12000E-01
2	4.00	1.31759E-02	3.31727E-01	3.69475E-01	4.71638E-01	9.12000E-01
3	7.00	1.01599E-02	2.55795E-01	3.69475E-01	4.71638E-01	9.12000E-01
4	11.00	8.18567E-03	2.06089E-01	3.69475E-01	4.71638E-01	9.12000E-01
5	15.00	7.04281E-03	1.77316E-01	3.69475E-01	4.71638E-01	9.12000E-01

RUN=4510 TOP AIR PT = 169.70  
 TPC = 760.00 DEG-R MINF = 7.754  
 TI = 536.00 DEG-R R/FT = 9.49967E+05  
 T0 = 1200.00 DEG-R  
 SQROCK = .0586 ALPHA=30.000  
 MODEL=31 PHI= 0.000  
 HS= 3.89412E-02 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/T0
1	3.60	1.43288E-02	3.67959E-01	3.65344E-01	4.63941E-01	9.12000E-01
2	7.10	1.02031E-02	2.62012E-01	3.65344E-01	4.63941E-01	9.12000E-01
3	10.10	8.55459E-03	2.19680E-01	3.65344E-01	4.63941E-01	9.12000E-01
4	13.70	7.34513E-03	1.88621E-01	3.65344E-01	4.63941E-01	9.12000E-01

ORIGINAL PAGE IS  
 OF POOR QUALITY

RUN=4511 TOP AIR PT = 164.70  
 TPC = 760.00 DEG-R MINF = 7.750  
 TI = 530.00 DEG-R R/FT = 9.61302E+05  
 T0 = 1230.00 DEG-R  
 SQRCK = .0380 ALPHA = 30.000  
 MODEL = 41 PHI = 0.000  
 HS = 3.83153E-02 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/T0
1	5.20	1.27539E-02	3.32867E-01	3.82409E-01	4.96303E-01	9.12000E-01
2	8.50	9.97550E-03	2.60353E-01	3.82409E-01	4.96303E-01	9.12000E-01
3	9.10	9.64103E-03	2.51623E-01	3.82409E-01	4.96303E-01	9.12000E-01
4	10.40	9.01830E-03	2.35372E-01	3.82409E-01	4.96303E-01	9.12000E-01
5	10.90	8.80909E-03	2.29910E-01	3.82409E-01	4.96303E-01	9.12000E-01
6	11.10	8.72937E-03	2.27830E-01	3.82409E-01	4.96303E-01	9.12000E-01
7	11.60	8.53910E-03	2.22866E-01	3.82409E-01	4.96303E-01	9.12000E-01
8	12.00	8.39564E-03	2.19120E-01	3.82409E-01	4.96303E-01	9.12000E-01
9	13.10	8.03542E-03	2.09718E-01	3.82409E-01	4.96303E-01	9.12000E-01
10	13.50	7.91548E-03	2.06588E-01	3.82409E-01	4.96303E-01	9.12000E-01
11	14.30	7.69088E-03	2.00726E-01	3.82409E-01	4.96303E-01	9.12000E-01

RUN=4512 TOP AIR PT = 1394.70  
 TPC = 910.00 DEG-R MINF = 8.032  
 TI = 535.00 DEG-R R/FT = 5.91383E+06  
 TS = 1415.00 DEG-R  
 SQRCK= .0613 \*ALPHA=30.000  
 MODEL=22 PHI= 0.000  
 HS= 1.04275E-01 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T,SEC	H,BTU/FT.SQ-SEC-DEG-R	H/H5	T-BAR	BETA	TAW/TO
1	1.00	4.60801E-02	4.41911E-01	4.93692E-01	7.51714E-01	9.12000E-01
2	1.20	4.20652E-02	4.03408E-01	4.93692E-01	7.51714E-01	9.12000E-01
3	1.30	4.04149E-02	3.87582E-01	4.93692E-01	7.51714E-01	9.12000E-01
4	1.50	3.34300E-02	3.20596E-01	4.93692E-01	7.51714E-01	9.12000E-01
5	2.30	3.03843E-02	2.91388E-01	4.93692E-01	7.51714E-01	9.12000E-01
6	2.90	2.70592E-02	2.59499E-01	4.93692E-01	7.51714E-01	9.12000E-01
7	3.70	2.39559E-02	2.29739E-01	4.93692E-01	7.51714E-01	9.12000E-01
8	3.90	2.33330E-02	2.23770E-01	4.93692E-01	7.51714E-01	9.12000E-01
9	4.30	2.22218E-02	2.13108E-01	4.93692E-01	7.51714E-01	9.12000E-01
10	5.10	2.04040E-02	1.95682E-01	4.93692E-01	7.51714E-01	9.12000E-01
11	5.30	2.00159E-02	1.91954E-01	4.93692E-01	7.51714E-01	9.12000E-01
12	5.70	1.93008E-02	1.85096E-01	4.93692E-01	7.51714E-01	9.12000E-01
13	6.50	1.80741E-02	1.73332E-01	4.93692E-01	7.51714E-01	9.12000E-01
14	7.70	1.66061E-02	1.59254E-01	4.93692E-01	7.51714E-01	9.12000E-01
15	8.70	1.56220E-02	1.49822E-01	4.93692E-01	7.51714E-01	9.12000E-01
16	10.80	1.40217E-02	1.34469E-01	4.93692E-01	7.51714E-01	9.12000E-01

RUN=4513 TOP AIR PT = 171.70  
 TPC = 635.00 DEG-R MINF = 7.756  
 TI = 541.00 DEG-R R/FT = 1.00031E+06  
 T<sub>0</sub> = 1230.00 DEG-R  
 SQRCK= .0537 ALPHA=30.000  
 MODEL=31 PHI= 0.000  
 HS= 3.88940E-02 BTU/FT.SQ-SEC-DEG-R

CONTOUR	I,SEC	H,BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/T0
1	1.30	7.76327E-03	1.99601E-01	1.61857E-01	1.64832E-01	9.12000E-01
2	2.50	5.59817E-03	1.43934E-01	1.61857E-01	1.64832E-01	9.12000E-01
3	3.00	5.11041E-03	1.31393E-01	1.61857E-01	1.64832E-01	9.12000E-01
4	3.80	4.54072E-03	1.16746E-01	1.61857E-01	1.64832E-01	9.12000E-01
5	4.30	4.20857E-03	1.09749E-01	1.61857E-01	1.64832E-01	9.12000E-01
6	4.90	3.99809E-03	1.02810E-01	1.61857E-01	1.64832E-01	9.12000E-01
7	5.20	3.88163E-03	9.98004E-02	1.61857E-01	1.64832E-01	9.12000E-01
8	5.60	3.67538E-03	9.44974E-02	1.61857E-01	1.64832E-01	9.12000E-01
9	7.20	3.29875E-03	8.48140E-02	1.61857E-01	1.64832E-01	9.12000E-01
10	8.00	3.12947E-03	8.04617E-02	1.61857E-01	1.64832E-01	9.12000E-01
11	10.40	2.74473E-03	7.05695E-02	1.61857E-01	1.64832E-01	9.12000E-01
12	12.40	2.51305E-03	6.46284E-02	1.61857E-01	1.64832E-01	9.12000E-01
13	14.20	2.34894E-03	6.03934E-02	1.61857E-01	1.64832E-01	9.12000E-01
14	14.00	2.31654E-03	5.95604E-02	1.61857E-01	1.64832E-01	9.12000E-01
15	14.90	2.29310E-03	5.89577E-02	1.61857E-01	1.64832E-01	9.12000E-01



RUN=4514 TOP AIR PT = 1394.70  
 TPC = 1010.00 DEG-R MINF = 8.032  
 TI = 540.00 DEG-R R/FT = 6.27978E+06  
 Tu = 1303.00 DEG-R  
 SQROCK= .0617 ALPHA=30.000  
 MODEL=41 PHI= 0.000  
 HS= 1.03728E-01 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/T0
1	.30	1.61219E-01	1.55425E+00	6.66780E-01	1.43117E+00	9.12000E-01
2	.40	1.39019E-01	1.34002E+00	6.66780E-01	1.43117E+00	9.12000E-01
3	1.20	8.06093E-02	7.77124E-01	6.66780E-01	1.43117E+00	9.12000E-01
4	1.40	7.46297E-02	7.19477E-01	6.66780E-01	1.43117E+00	9.12000E-01
5	1.70	6.77253E-02	6.52915E-01	6.66780E-01	1.43117E+00	9.12000E-01
6	2.20	5.95339E-02	5.73944E-01	6.66780E-01	1.43117E+00	9.12000E-01
7	2.60	5.47032E-02	5.27952E-01	6.66780E-01	1.43117E+00	9.12000E-01
8	3.70	4.59066E-02	4.42568E-01	6.66780E-01	1.43117E+00	9.12000E-01
9	5.00	3.94903E-02	3.80711E-01	6.66780E-01	1.43117E+00	9.12000E-01
10	7.70	3.18222E-02	3.06780E-01	6.66780E-01	1.43117E+00	9.12000E-01
11	9.00	2.94343E-02	2.83765E-01	6.66780E-01	1.43117E+00	9.12000E-01
12	10.30	2.75142E-02	2.65254E-01	6.66780E-01	1.43117E+00	9.12000E-01
13	11.70	2.58156E-02	2.48879E-01	6.66780E-01	1.43117E+00	9.12000E-01

ORIGINAL PAGE IS  
 OF POOR QUALITY

RUN=4515 TOP AIR PI = 178.70  
 TPC = 619.00 DEG-R MINF = 7.762  
 TI = 539.00 DEG-R R/FT = 1.00460E+06  
 TO = 1255.00 DEG-R  
 SQRCK= .0527 ALPHA=30.000  
 MODEL=22 PHI= 0.000  
 HS= 3.9633E-02 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/TO
1	1.20	5.51405E-03	1.39127E-01	1.17247E-01	1.14618E-01	9.12000E-01
2	1.30	5.29773E-03	1.33669E-01	1.17247E-01	1.14618E-01	9.12000E-01
3	1.80	4.50221E-03	1.13597E-01	1.17247E-01	1.14618E-01	9.12000E-01
4	2.80	3.74606E-03	9.45181E-02	1.17247E-01	1.14618E-01	9.12000E-01
5	3.40	3.27584E-03	8.26537E-02	1.17247E-01	1.14618E-01	9.12000E-01
6	4.60	2.81632E-03	7.10596E-02	1.17247E-01	1.14618E-01	9.12000E-01
7	6.70	2.33359E-03	5.88795E-02	1.17247E-01	1.14618E-01	9.12000E-01
8	7.20	2.25110E-03	5.67983E-02	1.17247E-01	1.14618E-01	9.12000E-01
9	9.40	2.01345E-03	5.08019E-02	1.17247E-01	1.14618E-01	9.12000E-01
10	10.80	1.83802E-03	4.63756E-02	1.17247E-01	1.14618E-01	9.12000E-01

RUN=4516 TOP AIR PT = 1419.70  
 TPC = 900.00 DEG-R MINF = 9.034  
 TI = 539.00 DEG-R R/FT = 0.05167E+06  
 TL = 1410.00 DEG-R  
 SROCK = .0617 ALPHA = 30.000  
 MODEL = 31 PHI = 0.000

HS = 1.05018E-01 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T-SEC	H-BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/TU
1	1.30	5.24060E-02	4.99044E-01	5.63648E-01	9.68477E-01	9.12000E-01
2	1.80	4.45388E-02	4.24106E-01	5.63648E-01	9.68477E-01	9.12000E-01
3	2.50	3.77924E-02	3.59806E-01	5.63648E-01	9.68477E-01	9.12000E-01
4	3.70	3.10052E-02	2.95808E-01	5.63648E-01	9.68477E-01	9.12000E-01
5	4.40	2.84871E-02	2.71259E-01	5.63648E-01	9.68477E-01	9.12000E-01
6	5.00	2.67233E-02	2.54463E-01	5.63648E-01	9.68477E-01	9.12000E-01
7	6.00	2.43949E-02	2.32292E-01	5.63648E-01	9.68477E-01	9.12000E-01
8	7.40	2.19064E-02	2.09168E-01	5.63648E-01	9.68477E-01	9.12000E-01
9	8.50	2.04958E-02	1.95164E-01	5.63648E-01	9.68477E-01	9.12000E-01
10	10.20	1.87100E-02	1.78160E-01	5.63648E-01	9.68477E-01	9.12000E-01
11	11.70	1.74695E-02	1.66348E-01	5.63648E-01	9.68477E-01	9.12000E-01

RUN=4517 TOP AIR PT = 1934.70  
 TPC =1010.00 DEG-R MINF = 0.070  
 TI = 541.00 DEG-R R/FT = 0.40099E+06  
 Tg =1385.00 DEG-R  
 SROCK= .0617 ALPHA=30.000  
 MODEL=22 PHI= 0.000  
 HS= 1.21066E-01 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/T0
1	1.10	7.86258E-02	0.49445E-01	6.49477E-01	1.33652E+00	9.12000E-01
2	1.30	7.23252E-02	5.97402E-01	6.49477E-01	1.33652E+00	9.12000E-01
3	1.80	6.14040E-02	5.07694E-01	6.49477E-01	1.33652E+00	9.12000E-01
4	2.70	5.01856E-02	4.14531E-01	6.49477E-01	1.33652E+00	9.12000E-01
5	3.10	4.68361E-02	3.86863E-01	6.49477E-01	1.33652E+00	9.12000E-01
6	4.30	3.97674E-02	3.28476E-01	6.49477E-01	1.33652E+00	9.12000E-01
7	5.40	3.54866E-02	2.93117E-01	6.49477E-01	1.33652E+00	9.12000E-01
8	6.20	3.31181E-02	2.73554E-01	6.49477E-01	1.33652E+00	9.12000E-01
9	6.30	3.28542E-02	2.71374E-01	6.49477E-01	1.33652E+00	9.12000E-01
10	6.60	3.20988E-02	2.65135E-01	6.49477E-01	1.33652E+00	9.12000E-01
11	8.10	2.89747E-02	2.39329E-01	6.49477E-01	1.33652E+00	9.12000E-01
12	9.50	2.67547E-02	2.20992E-01	6.49477E-01	1.33652E+00	9.12000E-01

RUN=4518 TOP AIR PT = 179.70  
 TPC = 535.00 DEG-R MINF = 1.763  
 TI = 541.00 DEG-R R/FT = 1.05919E+06  
 TO = 1220.00 DEG-R  
 SQRCK= .0537 ALPHA=30.000  
 MODEL=41 PHI=0.000  
 HS= 3.9677E-02 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/TO
1	1.30	7.90630E-03	1.99267E-01	1.64439E-01	1.67870E-01	9.12000E-01
2	1.50	6.93990E-03	1.64828E-01	1.64439E-01	1.67870E-01	9.12000E-01
3	2.70	5.48613E-03	1.38269E-01	1.64439E-01	1.67870E-01	9.12000E-01
4	3.40	4.88887E-03	1.23216E-01	1.64439E-01	1.67870E-01	9.12000E-01
5	3.50	4.81852E-03	1.21443E-01	1.64439E-01	1.67870E-01	9.12000E-01
6	4.20	4.39869E-03	1.10862E-01	1.64439E-01	1.67870E-01	9.12000E-01
7	4.30	4.34724E-03	1.09565E-01	1.64439E-01	1.67870E-01	9.12000E-01
8	4.70	4.15814E-03	1.04799E-01	1.64439E-01	1.67870E-01	9.12000E-01
9	5.40	3.87928E-03	9.77712E-02	1.64439E-01	1.67870E-01	9.12000E-01
10	5.90	3.71127E-03	9.35367E-02	1.64439E-01	1.67870E-01	9.12000E-01
11	6.00	3.50894E-03	8.84374E-02	1.64439E-01	1.67870E-01	9.12000E-01
12	6.80	3.45095E-03	8.71271E-02	1.64439E-01	1.67870E-01	9.12000E-01
13	8.70	3.05625E-03	7.70279E-02	1.64439E-01	1.67870E-01	9.12000E-01
14	9.80	2.87962E-03	7.25763E-02	1.64439E-01	1.67870E-01	9.12000E-01
15	9.90	2.86504E-03	7.22088E-02	1.64439E-01	1.67870E-01	9.12000E-01
16	12.30	2.57037E-03	6.47821E-02	1.64439E-01	1.67870E-01	9.12000E-01
17	12.50	2.54972E-03	6.42618E-02	1.64439E-01	1.67870E-01	9.12000E-01
18	13.30	2.47185E-03	6.22991E-02	1.64439E-01	1.67870E-01	9.12000E-01

ORIGINAL PAGE IS  
 OF POOR QUALITY

RUN=4519 TOP AIR PT = 1414.70  
 TPC = 810.00 DEG-R MINF = 8.034  
 TI = 540.00 DEG-R R/FT = 0.17649E+00  
 TV = 1390.00 DEG-R  
 SROCK = .0595 ALPHA = 30.000  
 MODEL = 31 PHI = 0.000  
 HS = 1.04939E-01 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/T0
1	.40	4.46476E-02	4.25461E-01	3.71042E-01	4.74582E-01	9.12000E-01
2	.50	3.99340E-02	3.80544E-01	3.71042E-01	4.74582E-01	9.12000E-01
3	.60	3.64546E-02	3.47388E-01	3.71042E-01	4.74582E-01	9.12000E-01
4	.70	3.37504E-02	3.21618E-01	3.71042E-01	4.74582E-01	9.12000E-01
5	.80	3.15700E-02	3.00840E-01	3.71042E-01	4.74582E-01	9.12000E-01
6	1.00	2.82376E-02	2.69085E-01	3.71042E-01	4.74582E-01	9.12000E-01
7	1.30	2.47660E-02	2.36003E-01	3.71042E-01	4.74582E-01	9.12000E-01
8	1.40	2.38651E-02	2.27419E-01	3.71042E-01	4.74582E-01	9.12000E-01
9	1.80	2.10471E-02	2.00564E-01	3.71042E-01	4.74582E-01	9.12000E-01
10	2.10	1.94858E-02	1.85686E-01	3.71042E-01	4.74582E-01	9.12000E-01
11	2.50	1.78590E-02	1.70184E-01	3.71042E-01	4.74582E-01	9.12000E-01
12	2.70	1.71849E-02	1.63760E-01	3.71042E-01	4.74582E-01	9.12000E-01
13	2.90	1.65817E-02	1.58012E-01	3.71042E-01	4.74582E-01	9.12000E-01
14	3.30	1.55443E-02	1.48127E-01	3.71042E-01	4.74582E-01	9.12000E-01
15	3.80	1.44856E-02	1.38038E-01	3.71042E-01	4.74582E-01	9.12000E-01
16	4.20	1.37785E-02	1.31300E-01	3.71042E-01	4.74582E-01	9.12000E-01
17	5.00	1.26282E-02	1.20339E-01	3.71042E-01	4.74582E-01	9.12000E-01
18	5.70	1.18274E-02	1.12707E-01	3.71042E-01	4.74582E-01	9.12000E-01
19	9.10	9.36068E-03	8.92009E-02	3.71042E-01	4.74582E-01	9.12000E-01
20	11.30	8.40019E-03	8.00480E-02	3.71042E-01	4.74582E-01	9.12000E-01

K/10

9.6

0896

16.6

0853

RUN=4520 TOP AIR PT = 1419.70  
 TPC = 810.00 DEG-R MINF = 8.034  
 TI = 542.00 DEG-R R/FT = 6.12388E+06  
 TG = 1400.00 DEG-R  
 SQRCK= .0595 ALPHA=30.000  
 MODEL=22 PHI= 0.000  
 HS= 1.05188E-01 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T-SEC	H-BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/TO
1	.50	3.89421E-02	3.70213E-01	3.64725E-01	4.62793E-01	9.12000E-01
2	.60	3.55491E-02	3.37957E-01	3.64725E-01	4.62793E-01	9.12000E-01
3	.80	3.07864E-02	2.92679E-01	3.64725E-01	4.62793E-01	9.12000E-01
4	1.30	2.41509E-02	2.29596E-01	3.64725E-01	4.62793E-01	9.12000E-01
5	1.90	1.99769E-02	1.89915E-01	3.64725E-01	4.62793E-01	9.12000E-01
6	2.20	1.85649E-02	1.76492E-01	3.64725E-01	4.62793E-01	9.12000E-01
7	2.60	1.70772E-02	1.62349E-01	3.64725E-01	4.62793E-01	9.12000E-01
8	2.90	1.61698E-02	1.53723E-01	3.64725E-01	4.62793E-01	9.12000E-01
9	3.10	1.56395E-02	1.48681E-01	3.64725E-01	4.62793E-01	9.12000E-01
10	3.30	1.51582E-02	1.44105E-01	3.64725E-01	4.62793E-01	9.12000E-01
11	3.60	1.45129E-02	1.37970E-01	3.64725E-01	4.62793E-01	9.12000E-01
12	4.00	1.37681E-02	1.30890E-01	3.64725E-01	4.62793E-01	9.12000E-01
13	4.10	1.35992E-02	1.29284E-01	3.64725E-01	4.62793E-01	9.12000E-01
14	4.90	1.24396E-02	1.18260E-01	3.64725E-01	4.62793E-01	9.12000E-01
15	5.90	1.13365E-02	1.07773E-01	3.64725E-01	4.62793E-01	9.12000E-01
16	6.70	1.06382E-02	1.01134E-01	3.64725E-01	4.62793E-01	9.12000E-01
17	6.90	1.04829E-02	9.96580E-02	3.64725E-01	4.62793E-01	9.12000E-01
18	7.70	9.92336E-03	9.43390E-02	3.64725E-01	4.62793E-01	9.12000E-01
19	8.90	9.23016E-03	8.77489E-02	3.64725E-01	4.62793E-01	9.12000E-01
20	9.70	8.84134E-03	8.40525E-02	3.64725E-01	4.62793E-01	9.12000E-01

ORIGINAL PAGE IS  
 OF POOR QUALITY

RUN= 4521 TOP AIR PT = 1404.70  
 TPC = 810.00 DEG-R MINE = -8.033  
 TI = 541.00 DEG-R R/FT = 6.17136E+06  
 T<sub>0</sub> = 1385.00 DEG-R  
 SOROCK= .0595 ALPHA=30.000  
 MODEL=41 PHI= 0.000  
 HS= 1.04554E-01 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/TO
1	.30	5.18561E-02	4.95974E-01	3.72514E-01	4.77358E-01	9.12000E-01
2	.40	4.49087E-02	4.29526E-01	3.72514E-01	4.77358E-01	9.12000E-01
3	.50	4.01676E-02	3.84180E-01	3.72514E-01	4.77358E-01	9.12000E-01
4	.60	3.66678E-02	3.50707E-01	3.72514E-01	4.77358E-01	9.12000E-01
5	1.10	2.70810E-02	2.59014E-01	3.72514E-01	4.77358E-01	9.12000E-01
6	1.30	2.49109E-02	2.38258E-01	3.72514E-01	4.77358E-01	9.12000E-01
7	1.60	2.24544E-02	2.14763E-01	3.72514E-01	4.77358E-01	9.12000E-01
8	2.00	2.00838E-02	1.92090E-01	3.72514E-01	4.77358E-01	9.12000E-01
9	2.10	1.95998E-02	1.87461E-01	3.72514E-01	4.77358E-01	9.12000E-01
10	2.40	1.83339E-02	1.75353E-01	3.72514E-01	4.77358E-01	9.12000E-01
11	2.90	1.66787E-02	1.59522E-01	3.72514E-01	4.77358E-01	9.12000E-01
12	3.20	1.58776E-02	1.51860E-01	3.72514E-01	4.77358E-01	9.12000E-01
13	3.30	1.56352E-02	1.49542E-01	3.72514E-01	4.77358E-01	9.12000E-01
14	4.20	1.38591E-02	1.32555E-01	3.72514E-01	4.77358E-01	9.12000E-01
15	5.90	1.16932E-02	1.11839E-01	3.72514E-01	4.77358E-01	9.12000E-01
16	6.60	1.10558E-02	1.05742E-01	3.72514E-01	4.77358E-01	9.12000E-01
17	7.40	1.04411E-02	9.98628E-02	3.72514E-01	4.77358E-01	9.12000E-01
18	8.60	9.68527E-03	9.26340E-02	3.72514E-01	4.77358E-01	9.12000E-01
19	10.90	8.60295E-03	8.22823E-02	3.72514E-01	4.77358E-01	9.12000E-01



RUN=4523 TOP AIR PT = 179.70  
 TPC = 760.00 DEG-R MINF = 7.763  
 TI = 542.00 DEG-R R/FT = 1.03764E+06  
 TQ = 1235.00 DEG-R  
 SQROCK = .0586 ALPHA = 30.000  
 MODEL = 31 PHI = 0.000  
 HS = 3.98886E-02 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/TQ
1	3.40	1.52048E-02	3.81181E-01	3.73083E-01	4.78433E-01	9.12000E-01
2	6.60	1.09131E-02	2.73589E-01	3.73083E-01	4.78433E-01	9.12000E-01
3	10.00	8.86582E-03	2.22265E-01	3.73083E-01	4.78433E-01	9.12000E-01
4	13.50	7.63048E-03	1.91295E-01	3.73083E-01	4.78433E-01	9.12000E-01
5	17.00	6.79977E-03	1.70409E-01	3.73083E-01	4.78433E-01	9.12000E-01
6	18.00	6.60819E-03	1.65666E-01	3.73083E-01	4.78433E-01	9.12000E-01

RUN=4524 TOP AIR PT = 1949.70  
 TPC = 860.00 DEG-R MINF = 8.071  
 T1 = 543.00 DEG-R R/FT = 0.46996E+06  
 T2 = 1385.00 DEG-R  
 SQROCK = .0604 ALPHA=30.000  
 MODEL=22 PHI= 0.000  
 HS= 1.21812E-01 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T,SEC	H,BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/T0
1	.60	4.61997E-02	3.95689E-01	4.40204E-01	6.18135E-01	9.12000E-01
2	.70	4.46243E-02	3.66336E-01	4.40204E-01	6.18135E-01	9.12000E-01
3	.90	3.93549E-02	3.23078E-01	4.40204E-01	6.18135E-01	9.12000E-01
4	1.30	3.27453E-02	2.68817E-01	4.40204E-01	6.18135E-01	9.12000E-01
5	2.00	2.64001E-02	2.16728E-01	4.40204E-01	6.18135E-01	9.12000E-01
6	2.10	2.57638E-02	2.11504E-01	4.40204E-01	6.18135E-01	9.12000E-01
7	2.20	2.51715E-02	2.06042E-01	4.40204E-01	6.18135E-01	9.12000E-01
8	2.30	2.46182E-02	2.02100E-01	4.40204E-01	6.18135E-01	9.12000E-01
9	2.60	2.31544E-02	1.90083E-01	4.40204E-01	6.18135E-01	9.12000E-01
10	3.00	2.15550E-02	1.76957E-01	4.40204E-01	6.18135E-01	9.12000E-01
11	3.20	2.08711E-02	1.71338E-01	4.40204E-01	6.18135E-01	9.12000E-01
12	3.60	1.96775E-02	1.61539E-01	4.40204E-01	6.18135E-01	9.12000E-01
13	4.00	1.86077E-02	1.53250E-01	4.40204E-01	6.18135E-01	9.12000E-01
14	4.80	1.70412E-02	1.39897E-01	4.40204E-01	6.18135E-01	9.12000E-01
15	6.40	1.67581E-02	1.21154E-01	4.40204E-01	6.18135E-01	9.12000E-01
16	8.00	1.32000E-02	1.08364E-01	4.40204E-01	6.18135E-01	9.12000E-01

RUN=4525 TOP AIR PT = 177.70  
 TPC = 750.00 DEG-R MINF = 7.761  
 TI = 542.00 DEG-R R/FT = 1.03364E+06  
 T0 = 1230.00 DEG-R  
 SQRCK= 0.85 ALPHA=30.000  
 MODEL=41 PHI=0.000  
 HS= 3.96680E-02 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/T0
1	3.50	1.51606E-02	3.82187E-01	3.76018E-01	4.84008E-01	9.12000E-01
2	6.30	1.13000E-02	2.84865E-01	3.76018E-01	4.84008E-01	9.12000E-01
3	9.60	9.15407E-03	2.30767E-01	3.76018E-01	4.84008E-01	9.12000E-01
4	12.40	8.05451E-03	2.03048E-01	3.76018E-01	4.84008E-01	9.12000E-01
5	17.20	6.83889E-03	1.72403E-01	3.76018E-01	4.84008E-01	9.12000E-01

ORIGINAL PAGE IS  
 NOT FOR QUANTIFICATION

RUN=4526 TOP AIR PT = 639.70  
TPC = 810.00 DEG-R MINF = 7.937  
TI = 537.00 DEG-R R/FT = 3.01855E+06  
TO = 1350.00 DEG-R  
SQROCK=.0595 ALPHA=25.000  
MODEL=22 PHI= 0.000  
HS= 7.22928E-02 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/TO
1	.90	3.34562E-02	4.62788E-01	4.01058E-01	5.33435E-01	9.02000E-01
2	1.40	2.68247E-02	3.71056E-01	4.01058E-01	5.33435E-01	9.02000E-01
3	2.00	2.24431E-02	3.10448E-01	4.01058E-01	5.33435E-01	9.02000E-01
4	2.60	1.96839E-02	2.72281E-01	4.01058E-01	5.33435E-01	9.02000E-01
5	3.70	1.65005E-02	2.28246E-01	4.01058E-01	5.33435E-01	9.02000E-01
6	4.70	1.46403E-02	2.02514E-01	4.01058E-01	5.33435E-01	9.02000E-01
7	5.70	1.32942E-02	1.83893E-01	4.01058E-01	5.33435E-01	9.02000E-01
8	6.70	1.22620E-02	1.69616E-01	4.01058E-01	5.33435E-01	9.02000E-01
9	7.40	1.16676E-02	1.61394E-01	4.01058E-01	5.33435E-01	9.02000E-01
10	9.00	1.05798E-02	1.46346E-01	4.01058E-01	5.33435E-01	9.02000E-01
11	10.50	9.79498E-03	1.35490E-01	4.01058E-01	5.33435E-01	9.02000E-01
12	14.40	8.36406E-03	1.15697E-01	4.01058E-01	5.33435E-01	9.02000E-01

881

AL

2

1

0

9

8

7

6

5

4

3

RUN=4527 TOP AIR PT = 639.70  
 TPC = 860.00 DEG-R MINF = 7.937  
 TI = 541.00 DEG-R R/FT = 3.05629E+06  
 TO = 1340.00 DEG-R  
 SQROCK= .0604 ALPHA=25.000  
 MODEL=31 PHI= 0.000  
 HS= 7.21948E-02 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/TO
1	1.70	3.28676E-02	4.55263E-01	4.77774E-01	7.09505E-01	9.02000E-01
2	2.20	2.88922E-02	4.00198E-01	4.77774E-01	7.09505E-01	9.02000E-01
3	2.70	2.60802E-02	3.61247E-01	4.77774E-01	7.09505E-01	9.02000E-01
4	3.30	2.35904E-02	3.26761E-01	4.77774E-01	7.09505E-01	9.02000E-01
5	4.00	2.14271E-02	2.96795E-01	4.77774E-01	7.09505E-01	9.02000E-01
6	4.60	1.99808E-02	2.76763E-01	4.77774E-01	7.09505E-01	9.02000E-01
7	6.00	1.74951E-02	2.42332E-01	4.77774E-01	7.09505E-01	9.02000E-01
8	6.70	1.65560E-02	2.29324E-01	4.77774E-01	7.09505E-01	9.02000E-01
9	7.80	1.53442E-02	2.12539E-01	4.77774E-01	7.09505E-01	9.02000E-01
10	9.70	1.37596E-02	1.90590E-01	4.77774E-01	7.09505E-01	9.02000E-01
11	12.40	1.21697E-02	1.68568E-01	4.77774E-01	7.09505E-01	9.02000E-01
12	13.30	1.17508E-02	1.62765E-01	4.77774E-01	7.09505E-01	9.02000E-01
13	14.30	1.13325E-02	1.56971E-01	4.77774E-01	7.09505E-01	9.02000E-01

68L

AA

12

11

10

9

8

7

6

5

4

000

RUN=4528 TOP AIR PT = 649.70  
TPC = 860.00 DEG-R MINF = 7.939  
TI = 542.00 DEG-R R/FT = 3.10224E+06  
TO = 1340.00 DEG-R  
SQROCK= .0604 ALPHA=25.000  
MODEL=41 PHI= 0.000  
HS= 7.27165E-02 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/TO
1	1.70	3.27740E-02	4.50710E-01	4.76990E-01	7.07485E-01	9.02000E-01
2	1.80	3.18506E-02	4.38011E-01	4.76990E-01	7.07485E-01	9.02000E-01
3	2.50	2.70262E-02	3.71665E-01	4.76990E-01	7.07485E-01	9.02000E-01
4	3.40	2.31747E-02	3.18700E-01	4.76990E-01	7.07485E-01	9.02000E-01
5	4.20	2.08511E-02	2.86746E-01	4.76990E-01	7.07485E-01	9.02000E-01
6	4.80	1.95045E-02	2.68226E-01	4.76990E-01	7.07485E-01	9.02000E-01
7	7.20	1.59253E-02	2.19006E-01	4.76990E-01	7.07485E-01	9.02000E-01
8	8.70	1.44875E-02	1.99233E-01	4.76990E-01	7.07485E-01	9.02000E-01
9	11.60	1.25466E-02	1.72541E-01	4.76990E-01	7.07485E-01	9.02000E-01
10	14.60	1.11835E-02	1.53796E-01	4.76990E-01	7.07485E-01	9.02000E-01

RUN=4529 TOP AIR PT = 649.70  
TPC = 710.00 DEG-R MINF = 7.939  
TI = 541.00 DEG-R R/FT = 3.12170E+06  
TO = 1335.00 DEG-R  
SQROCK= .0574 ALPHA=25.000  
MODEL=22 PHI= 0.000  
HS= 7.26281E-02 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/TO
1	1.00	1.63484E-02	2.25098E-01	2.54837E-01	2.84816E-01	9.02000E-01
2	1.50	1.33484E-02	1.83792E-01	2.54837E-01	2.84816E-01	9.02000E-01
3	2.00	1.15601E-02	1.59168E-01	2.54837E-01	2.84816E-01	9.02000E-01
4	2.70	9.94933E-03	1.36990E-01	2.54837E-01	2.84816E-01	9.02000E-01
5	3.90	8.27835E-03	1.13983E-01	2.54837E-01	2.84816E-01	9.02000E-01
6	6.10	6.61928E-03	9.11394E-02	2.54837E-01	2.84816E-01	9.02000E-01
7	7.80	5.85368E-03	8.05979E-02	2.54837E-01	2.84816E-01	9.02000E-01
8	10.30	5.09398E-03	7.01379E-02	2.54837E-01	2.84816E-01	9.02000E-01
9	13.00	4.53424E-03	6.24309E-02	2.54837E-01	2.84816E-01	9.02000E-01
10	14.10	4.35378E-03	5.99462E-02	2.54837E-01	2.84816E-01	9.02000E-01

LOI  
MADE IN U.S.A.

12  
11  
10  
9  
8  
7  
6  
5  
4  
3

C  
3  
RUN=4530 TOP AIR PT = 644.70  
TPC = 760.00 DEG-R MINF = 7.938  
TI = 543.00 DEG-R R/FT = 3.06015E+06  
TO = 1345.00 DEG-R  
SQROCK= .0586 ALPHA=25.000  
MODEL=31 PHI= 0.000  
HS= 7.25173E-02 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/TO
1	1.10	2.18405E-02	3.01177E-01	3.23789E-01	3.90896E-01	9.02000E-01
2	1.60	1.81092E-02	2.49722E-01	3.23789E-01	3.90896E-01	9.02000E-01
3	2.50	1.44873E-02	1.99778E-01	3.23789E-01	3.90896E-01	9.02000E-01
4	3.50	1.22440E-02	1.68843E-01	3.23789E-01	3.90896E-01	9.02000E-01
5	4.70	1.05660E-02	1.45703E-01	3.23789E-01	3.90896E-01	9.02000E-01
6	5.80	9.51141E-03	1.31161E-01	3.23789E-01	3.90896E-01	9.02000E-01
7	7.90	8.14977E-03	1.12384E-01	3.23789E-01	3.90896E-01	9.02000E-01
8	10.60	7.03568E-03	9.70207E-02	3.23789E-01	3.90896E-01	9.02000E-01
9	14.20	6.07876E-03	8.38250E-02	3.23789E-01	3.90896E-01	9.02000E-01



RUN=4531 TOP AIR PT = 639.70  
TPC = 760.00 DEG-R MINF = 7.937  
TI = 542.00 DEG-R R/FT = 3.11441E+06  
TO = 1325.00 DEG-R  
SQROCK= .0586 ALPHA=25.000  
MODEL=41 PHI= 0.000  
HS= 7.21447E-02 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/TO
1	1.20	2.18118E-02	3.02334E-01	3.33767E-01	4.07741E-01	9.02000E-01
2	1.60	1.88896E-02	2.61829E-01	3.33767E-01	4.07741E-01	9.02000E-01
3	2.60	1.48182E-02	2.05396E-01	3.33767E-01	4.07741E-01	9.02000E-01
4	3.40	1.29581E-02	1.79613E-01	3.33767E-01	4.07741E-01	9.02000E-01
5	4.10	1.18002E-02	1.63563E-01	3.33767E-01	4.07741E-01	9.02000E-01
6	5.20	1.04780E-02	1.45237E-01	3.33767E-01	4.07741E-01	9.02000E-01
7	6.60	9.30058E-03	1.28916E-01	3.33767E-01	4.07741E-01	9.02000E-01
8	8.10	8.39537E-03	1.16368E-01	3.33767E-01	4.07741E-01	9.02000E-01
9	9.40	7.79324E-03	1.08022E-01	3.33767E-01	4.07741E-01	9.02000E-01
10	9.90	7.59389E-03	1.05259E-01	3.33767E-01	4.07741E-01	9.02000E-01
11	12.70	6.70471E-03	9.29343E-02	3.33767E-01	4.07741E-01	9.02000E-01

ORIGINAL PAGE IS  
OF POOR QUALITY

RUN=4532 TOP AIR PT = 1414.70  
 TPC = 910.00 DEG-R MINF = 8.034  
 TI = 543.00 DEG-R R/FT = 5.99565E+06  
 TQ = 1415.00 DEG-R  
 SQROCK= .0613 ALPHA=25.000  
 MODEL=22 PHI= 0.000  
 HS= 1.04971E-01 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/TO
1	1.30	4.14170E-02	3.94558E-01	5.00457E-01	7.70352E-01	9.02000E-01
2	2.00	3.33914E-02	3.18103E-01	5.00457E-01	7.70352E-01	9.02000E-01
3	2.70	2.87388E-02	2.73779E-01	5.00457E-01	7.70352E-01	9.02000E-01
4	3.80	2.42247E-02	2.30776E-01	5.00457E-01	7.70352E-01	9.02000E-01
5	5.20	2.07085E-02	1.97279E-01	5.00457E-01	7.70352E-01	9.02000E-01
6	6.30	1.88139E-02	1.79230E-01	5.00457E-01	7.70352E-01	9.02000E-01
7	7.90	1.68010E-02	1.60055E-01	5.00457E-01	7.70352E-01	9.02000E-01
8	8.30	1.63912E-02	1.56150E-01	5.00457E-01	7.70352E-01	9.02000E-01
9	8.80	1.59187E-02	1.51649E-01	5.00457E-01	7.70352E-01	9.02000E-01
10	11.20	1.41104E-02	1.34423E-01	5.00457E-01	7.70352E-01	9.02000E-01

RUN=4533 TOP AIR PT = 178.70  
 TPC = 760.00 DEG-R MINF = 7.762  
 TI = 543.00 DEG-R R/FT = 1.05357E+06  
 TO = 1220.00 DEG-R  
 SQROCK= .0586 ALPHA=25.000  
 MODEL=31 PHI= 0.000  
 HS= 3.97352E-02 BTU/FT.SQ-SEC-DEG-R

COL. T, SEC	H, BTU/FT.SQ-SEC-DEG-R	h/HS	T-BAR	BETA	TAW/TO
1 2.70	1.81795E-02	4.57515E-01	3.89280E-01	5.09760E-01	9.02000E-01
2 3.60	1.57439E-02	3.96220E-01	3.89280E-01	5.09760E-01	9.02000E-01
3 5.50	1.27374E-02	3.20558E-01	3.89280E-01	5.09760E-01	9.02000E-01
4 7.00	1.12905E-02	2.84144E-01	3.89280E-01	5.09760E-01	9.02000E-01
5 9.60	9.64113E-03	2.42634E-01	3.89280E-01	5.09760E-01	9.02000E-01
6 12.90	8.31704E-03	2.09311E-01	3.89280E-01	5.09760E-01	9.02000E-01

RUN=4534 TOP AIR PT = 1414.70  
 TPC = 1010.00 DEG-R MINF = 8.034  
 TI = 543.00 DEG-R R/FT = 6.03110E+06  
 TO = 1410.00 DEG-R  
 SQRCK = .0617 ALPHA = 25.000  
 MODEL = 41 PHI = 0.000  
 HS = 1.04762E-01 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/TO
1	1.30	6.99156E-02	6.67374E-01	6.40762E-01	1.29199E+00	9.02000E-01
2	1.60	6.30211E-02	6.01563E-01	6.40762E-01	1.29199E+00	9.02000E-01
3	2.00	5.63678E-02	5.38054E-01	6.40762E-01	1.29199E+00	9.02000E-01
4	2.40	5.14565E-02	4.91174E-01	6.40762E-01	1.29199E+00	9.02000E-01
5	2.50	5.04169E-02	4.81250E-01	6.40762E-01	1.29199E+00	9.02000E-01
6	3.30	4.38822E-02	4.18875E-01	6.40762E-01	1.29199E+00	9.02000E-01
7	3.40	4.32321E-02	4.12669E-01	6.40762E-01	1.29199E+00	9.02000E-01
8	4.80	3.63852E-02	3.47313E-01	6.40762E-01	1.29199E+00	9.02000E-01
9	5.50	3.39910E-02	3.24459E-01	6.40762E-01	1.29199E+00	9.02000E-01
10	7.00	3.01298E-02	2.87602E-01	6.40762E-01	1.29199E+00	9.02000E-01
11	10.00	2.52084E-02	2.40625E-01	6.40762E-01	1.29199E+00	9.02000E-01
12	11.80	2.32062E-02	2.21513E-01	6.40762E-01	1.29199E+00	9.02000E-01

RUN=4535 TOP AIR PT = 1414.70  
 TPC = 960.00 DEG-R MINF = 8.034  
 TI = 544.00 DEG-R R/FT = 6.10306E+06  
 TO = 1400.00 DEG-R  
 SQRDCK= .0617-- AL-PHA=25.000  
 MODEL=31 PHI= 0.000  
 HS= 1.04770E-01 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/TO
1	1.30	5.53841E-02	5.28624E-01	5.78742E-01	1.02346E+00	9.02000E-01
2	1.60	4.99225E-02	4.76495E-01	5.78742E-01	1.02346E+00	9.02000E-01
3	2.10	4.35760E-02	4.15919E-01	5.78742E-01	1.02346E+00	9.02000E-01
4	2.30	4.16383E-02	3.97424E-01	5.78742E-01	1.02346E+00	9.02000E-01
5	2.50	3.99380E-02	3.81196E-01	5.78742E-01	1.02346E+00	9.02000E-01
6	4.10	3.11864E-02	2.97664E-01	5.78742E-01	1.02346E+00	9.02000E-01
7	6.00	2.57799E-02	2.46061E-01	5.78742E-01	1.02346E+00	9.02000E-01
8	7.80	2.26105E-02	2.15810E-01	5.78742E-01	1.02346E+00	9.02000E-01
9	10.30	1.96761E-02	1.87802E-01	5.78742E-01	1.02346E+00	9.02000E-01
10	11.60	1.85408E-02	1.76966E-01	5.78742E-01	1.02346E+00	9.02000E-01

RUN=4536 TOP AIR PT = 174.70  
TPC = 710.00 DEG-R MINF = 7.759  
TI = 543.00 DEG-R R/FT = 1.05276E+06  
TO = 1205.00 DEG-R  
SQROCK= .0574 ALPHA=25.000  
MODEL=22 PHI= 0.000  
HS= 3.92234E-02 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/TO
1	1.30	1.83009E-02	4.66581E-01	3.07036E-01	3.63524E-01	9.02000E-01
2	2.20	1.40680E-02	3.58664E-01	3.07036E-01	3.63524E-01	9.02000E-01
3	4.30	1.00626E-02	2.56546E-01	3.07036E-01	3.63524E-01	9.02000E-01
4	6.10	8.44850E-03	2.15394E-01	3.07036E-01	3.63524E-01	9.02000E-01
5	9.00	6.95542E-03	1.77328E-01	3.07036E-01	3.63524E-01	9.02000E-01
6	12.60	5.87840E-03	1.49870E-01	3.07036E-01	3.63524E-01	9.02000E-01

RUN=4537 TOP AIR PT = 170.70  
TPC = 760.00 DEG-R MINF = 7.755  
TI = 542.00 DEG-R R/FT = 1.04432E+06  
TO = 1195.00 DEG-R  
SQROCK= .0586 -- --ALPHA=25.000  
MODEL=41 PHI= 0.000  
HS= 3.88261E-02 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/TO
1	3.70	1.66113E-02	4.27838E-01	4.06800E-01	5.45264E-01	9.02000E-01
2	4.70	1.47386E-02	3.79605E-01	4.06800E-01	5.45264E-01	9.02000E-01
3	6.70	1.23443E-02	3.17939E-01	4.06800E-01	5.45264E-01	9.02000E-01
4	11.40	9.46351E-03	2.43741E-01	4.06800E-01	5.45264E-01	9.02000E-01
5	14.60	8.36235E-03	2.15379E-01	4.06800E-01	5.45264E-01	9.02000E-01

RUN=4538 TOP AIR PT = 1419.70  
 TPC = 760.00 DEG-R MINF = 8.034  
 TI = 542.00 DEG-R R/FT = 6.12388E+06  
 TO = 1400.00 DEG-R  
 SQROCK=.0586 ALPHA=25.000  
 MODEL=22 PHI= 0.000  
 HS= 1.05174E-01 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/TO
1	1.30	1.83075E-02	1.74069E-01	3.02442E-01	3.56208E-01	9.02000E-01
2	1.70	1.60095E-02	1.52219E-01	3.02442E-01	3.56208E-01	9.02000E-01
3	1.80	1.55584E-02	1.47930E-01	3.02442E-01	3.56208E-01	9.02000E-01
4	2.30	1.37638E-02	1.30866E-01	3.02442E-01	3.56208E-01	9.02000E-01
5	2.90	1.22575E-02	1.16545E-01	3.02442E-01	3.56208E-01	9.02000E-01
6	3.30	1.14906E-02	1.09253E-01	3.02442E-01	3.56208E-01	9.02000E-01
7	3.70	1.08518E-02	1.03179E-01	3.02442E-01	3.56208E-01	9.02000E-01
8	4.80	9.52753E-03	9.05882E-02	3.02442E-01	3.56208E-01	9.02000E-01
9	5.90	8.59360E-03	8.17083E-02	3.02442E-01	3.56208E-01	9.02000E-01
10	7.20	7.77920E-03	7.39650E-02	3.02442E-01	3.56208E-01	9.02000E-01
11	8.50	7.15965E-03	6.80742E-02	3.02442E-01	3.56208E-01	9.02000E-01
12	11.50	6.15534E-03	5.85253E-02	3.02442E-01	3.56208E-01	9.02000E-01

200

12  
11  
10  
9  
8  
7  
6  
5  
4



RUN=4539 TOP AIR PT = 164.70  
 TPC = 635.00 DEG-R MINF = 7.750  
 TI = 542.00 DEG-R R/FT = 9.61362E+05  
 TO = 1230.00 DEG-R  
 SQROCK= .0537 ALPHA=25.000  
 MODEL=31 PHI= 0.000  
 HS= 3.81618E-02 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/TO
1	1.30	7.87577E-03	2.06378E-01	1.63888E-01	1.67221E-01	9.02000E-01
2	2.20	6.05415E-03	1.58644E-01	1.63888E-01	1.67221E-01	9.02000E-01
3	3.60	4.73275E-03	1.24018E-01	1.63888E-01	1.67221E-01	9.02000E-01
4	4.90	4.05664E-03	1.06301E-01	1.63888E-01	1.67221E-01	9.02000E-01
5	5.80	3.72864E-03	9.77060E-02	1.63888E-01	1.67221E-01	9.02000E-01
6	7.90	3.19485E-03	8.37186E-02	1.63888E-01	1.67221E-01	9.02000E-01
7	11.00	2.70750E-03	7.09478E-02	1.63888E-01	1.67221E-01	9.02000E-01
8	13.80	2.41727E-03	6.33426E-02	1.63888E-01	1.67221E-01	9.02000E-01

ORIGINAL PAGE IS  
 OF POOR QUALITY

RUN=4540 TOP AIR PT = 1949.70  
TPC =1010.00 DEG-R MINF = 8.071  
TI = 542.00 DEG-R R/FT = 8.36876E+06  
TO =1395.00 DEG-R  
SQROCK= .0617 ALPHA=25.000  
MODEL=22 PHI= 0.000  
HS= 1.21593E-01 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT. SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/TO
1	1.30	7.34361E-02	6.03950E-01	6.53367E-01	1.35705E+00	9.02000E-01
2	1.50	6.83653E-02	5.62247E-01	6.53367E-01	1.35705E+00	9.02000E-01
3	1.80	6.24087E-02	5.13259E-01	6.53367E-01	1.35705E+00	9.02000E-01
4	2.70	5.09565E-02	4.19074E-01	6.53367E-01	1.35705E+00	9.02000E-01
5	4.50	3.94707E-02	3.24614E-01	6.53367E-01	1.35705E+00	9.02000E-01
6	7.40	3.07798E-02	2.53138E-01	6.53367E-01	1.35705E+00	9.02000E-01
7	10.10	2.63464E-02	2.16677E-01	6.53367E-01	1.35705E+00	9.02000E-01
8	11.40	2.47987E-02	2.03949E-01	6.53367E-01	1.35705E+00	9.02000E-01

RUN=4541 TOP AIR PT = 1414.70  
 TPC = 810.00 DEG-R MINF = 8.034  
 TI = 544.00 DEG-R R/FT = 6.03110E+06  
 TO = 1410.00 DEG-R  
 SQROCK= .0595 --- ALPHA=25.000  
 MODEL=41 PHI= 0.000  
 HS= 1.05090E-01 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/TO
1	1.30	2.42233E-02	2.30501E-01	3.65475E-01	4.64182E-01	9.02000E-01
2	2.10	1.90588E-02	1.81357E-01	3.65475E-01	4.64182E-01	9.02000E-01
3	3.20	1.54394E-02	1.46916E-01	3.65475E-01	4.64182E-01	9.02000E-01
4	4.80	1.26062E-02	1.19956E-01	3.65475E-01	4.64182E-01	9.02000E-01
5	6.30	1.10036E-02	1.04707E-01	3.65475E-01	4.64182E-01	9.02000E-01
6	6.90	1.05143E-02	1.00051E-01	3.65475E-01	4.64182E-01	9.02000E-01
7	8.80	9.31031E-03	8.85937E-02	3.65475E-01	4.64182E-01	9.02000E-01
8	10.70	8.44333E-03	8.03438E-02	3.65475E-01	4.64182E-01	9.02000E-01

RUN=4542 TOP AIR PT = 166.70  
 TPC = 610.00 DEG-R MINF = 7.752  
 TI = 545.00 DEG-R R/FT = 9.59352E+05  
 T0 = 1240.00 DEG-R  
 SQROCK= .0527 ALPHA=25.000  
 MODEL=22 PHI= 0.000  
 HS= 3.83459E-02 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/T0
1	1.30	5.10357E-03	1.33093E-01	1.13343E-01	1.10417E-01	9.02000E-01
2	2.30	3.83691E-03	1.00060E-01	1.13343E-01	1.10417E-01	9.02000E-01
3	3.40	3.15578E-03	8.22976E-02	1.13343E-01	1.10417E-01	9.02000E-01
4	4.70	2.68409E-03	6.99967E-02	1.13343E-01	1.10417E-01	9.02000E-01
5	6.30	2.31833E-03	6.04583E-02	1.13343E-01	1.10417E-01	9.02000E-01
6	7.20	2.16860E-03	5.65536E-02	1.13343E-01	1.10417E-01	9.02000E-01
7	9.70	1.86836E-03	4.87237E-02	1.13343E-01	1.10417E-01	9.02000E-01
8	11.50	1.71592E-03	4.47484E-02	1.13343E-01	1.10417E-01	9.02000E-01
9	12.60	1.63931E-03	4.27505E-02	1.13343E-01	1.10417E-01	9.02000E-01
10	14.70	1.51770E-03	3.95793E-02	1.13343E-01	1.10417E-01	9.02000E-01

RUN=4543 TOP AIR PT = 1404.70  
 TPC = 810.00 DEG-R MINF = 8.033  
 TI = 545.00 DEG-R R/FT = 5.78381E+06  
 TO = 1440.00 DEG-R  
 SQROCK= .0595 -ALPHA=25.000  
 MODEL=31 PHI= 0.000  
 HS= 1.04962E-01 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/TO
1	1.30	2.28969E-02	2.18144E-01	3.51515E-01	4.38765E-01	9.02000E-01
2	1.70	2.00228E-02	1.90762E-01	3.51515E-01	4.38765E-01	9.02000E-01
3	2.50	1.65112E-02	1.57306E-01	3.51515E-01	4.38765E-01	9.02000E-01
4	3.40	1.41582E-02	1.34889E-01	3.51515E-01	4.38765E-01	9.02000E-01
5	4.50	1.23067E-02	1.17249E-01	3.51515E-01	4.38765E-01	9.02000E-01
6	5.50	1.11319E-02	1.06056E-01	3.51515E-01	4.38765E-01	9.02000E-01
7	6.60	1.01619E-02	9.68152E-02	3.51515E-01	4.38765E-01	9.02000E-01
8	7.50	9.53275E-03	9.08207E-02	3.51515E-01	4.38765E-01	9.02000E-01
9	8.60	8.90225E-03	8.48138E-02	3.51515E-01	4.38765E-01	9.02000E-01
10	10.30	8.13449E-03	7.74992E-02	3.51515E-01	4.38765E-01	9.02000E-01
11	11.90	7.56790E-03	7.21011E-02	3.51515E-01	4.38765E-01	9.02000E-01

RUN=4544 TOP AIR PT = 174.70  
 TPC = 635.00 DEG-R MINE = 7.759  
 TI = 542.00 DEG-R R/FT = 9.51232E+05  
 TO = 1280.00 DEG-R  
 SQROCK= .0537 ALPHA=25.000  
 MODEL=41 PHI= 0.000  
 HS= 3.93680E-02 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/TO
1	1.30	7.21388E-03	1.83242E-01	1.51822E-01	1.53167E-01	9.02000E-01
2	2.10	5.67585E-03	1.44174E-01	1.51822E-01	1.53167E-01	9.02000E-01
3	3.00	4.74875E-03	1.20625E-01	1.51822E-01	1.53167E-01	9.02000E-01
4	3.80	4.21938E-03	1.07178E-01	1.51822E-01	1.53167E-01	9.02000E-01
5	5.30	3.57275E-03	9.07526E-02	1.51822E-01	1.53167E-01	9.02000E-01
6	7.90	2.92635E-03	7.43333E-02	1.51822E-01	1.53167E-01	9.02000E-01
7	11.40	2.43606E-03	6.18792E-02	1.51822E-01	1.53167E-01	9.02000E-01
8	14.80	2.13801E-03	5.43083E-02	1.51822E-01	1.53167E-01	9.02000E-01

RUN=4545 TOP AIR PT = 1944.70  
 TPC = 860.00 DEG-R MINF = 8.070  
 TI = 542.00 DEG-R R/FT = 8.29830E+06  
 TO = 1400.00 DEG-R  
 SQROCK= .0604 -ALPHA=25.000  
 MODEL=22 PHI= 0.000  
 HS= 1.21798E-01 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/TO
1	.70	4.47854E-02	3.67702E-01	4.41176E-01	6.20366E-01	9.02000E-01
2	.80	4.18929E-02	3.43954E-01	4.41176E-01	6.20366E-01	9.02000E-01
3	1.00	3.74701E-02	3.07642E-01	4.41176E-01	6.20366E-01	9.02000E-01
4	1.40	3.16680E-02	2.60005E-01	4.41176E-01	6.20366E-01	9.02000E-01
5	1.80	2.79286E-02	2.29303E-01	4.41176E-01	6.20366E-01	9.02000E-01
6	2.20	2.52624E-02	2.07412E-01	4.41176E-01	6.20366E-01	9.02000E-01
7	2.60	2.32380E-02	1.90791E-01	4.41176E-01	6.20366E-01	9.02000E-01
8	2.70	2.28036E-02	1.87225E-01	4.41176E-01	6.20366E-01	9.02000E-01
9	3.10	2.12816E-02	1.74729E-01	4.41176E-01	6.20366E-01	9.02000E-01
10	3.30	2.06266E-02	1.69351E-01	4.41176E-01	6.20366E-01	9.02000E-01
11	3.50	2.00286E-02	1.64441E-01	4.41176E-01	6.20366E-01	9.02000E-01
12	3.90	1.89737E-02	1.55780E-01	4.41176E-01	6.20366E-01	9.02000E-01
13	4.30	1.80697E-02	1.48358E-01	4.41176E-01	6.20366E-01	9.02000E-01
14	4.70	1.72837E-02	1.41905E-01	4.41176E-01	6.20366E-01	9.02000E-01
15	5.30	1.62760E-02	1.33631E-01	4.41176E-01	6.20366E-01	9.02000E-01
16	6.50	1.46970E-02	1.20667E-01	4.41176E-01	6.20366E-01	9.02000E-01
17	6.90	1.42646E-02	1.17117E-01	4.41176E-01	6.20366E-01	9.02000E-01
18	8.10	1.31657E-02	1.08094E-01	4.41176E-01	6.20366E-01	9.02000E-01
19	10.30	1.16753E-02	9.58576E-02	4.41176E-01	6.20366E-01	9.02000E-01
20	11.80	1.09080E-02	8.95580E-02	4.41176E-01	6.20366E-01	9.02000E-01

ORIGINAL PAGE IS  
 OF POOR QUALITY

RUN=4546 TOP AIR PT = 639.70  
TPC = 860.00 DEG-R MINF = 7.937  
TI = 543.00 DEG-R R/FT = 3.17441E+06  
TO = 1310.00 DEG-R  
SQROCK= .0604 ALPHA=35.000  
MODEL=31 PHI= 0.000  
HS= 7.20267E-02 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/TO
1	3.80	2.18329E-02	3.03122E-01	4.75883E-01	7.04639E-01	9.23000E-01
2	5.10	1.88460E-02	2.61652E-01	4.75883E-01	7.04639E-01	9.23000E-01
3	7.20	1.58612E-02	2.20213E-01	4.75883E-01	7.04639E-01	9.23000E-01
4	10.30	1.32613E-02	1.84116E-01	4.75883E-01	7.04639E-01	9.23000E-01
5	11.80	1.23898E-02	1.72016E-01	4.75883E-01	7.04639E-01	9.23000E-01



RUN=4548 TOP AIR PT = 669.70  
 TPC = 860.00 DEG-R MINF = 7.943  
 TI = 542.00 DEG-R R/FT = 3.25480E+06  
 TO = 1325.00 DEG-R  
 SQRCK= .0604 ALPHA=35.000  
 MODEL=41 PHI= 0.000  
 HS= 7.36623E-02 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/TO
1	2.80	2.46217E-02	3.34251E-01	4.66977E-01	6.82118E-01	9.23000E-01
2	5.20	1.80674E-02	2.45273E-01	4.66977E-01	6.82118E-01	9.23000E-01
3	7.00	1.55721E-02	2.11399E-01	4.66977E-01	6.82118E-01	9.23000E-01
4	9.00	1.37333E-02	1.86436E-01	4.66977E-01	6.82118E-01	9.23000E-01
5	11.10	1.23662E-02	1.67877E-01	4.66977E-01	6.82118E-01	9.23000E-01
6	13.20	1.13399E-02	1.53945E-01	4.66977E-01	6.82118E-01	9.23000E-01
7	15.00	1.06378E-02	1.44413E-01	4.66977E-01	6.82118E-01	9.23000E-01

RUN=4549 TOP AIR PT = 649.70  
IPC = 710.00 DEG-R MINF = 7.939  
TI = 544.00 DEG-R R/ET = 3.12170E+06  
TO = 1335.00 DEG-R  
SQROCK= .0574 ALPHA=35.000  
MODEL=22 PHI= 0.000  
HS= 7.26281E-02 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/TO
1	1.20	1.39244E-02	1.91722E-01	2.41207E-01	2.65739E-01	9.23000E-01
2	1.60	1.20589E-02	1.66036E-01	2.41207E-01	2.65739E-01	9.23000E-01
3	2.00	1.07858E-02	1.48507E-01	2.41207E-01	2.65739E-01	9.23000E-01
4	2.60	9.45975E-03	1.30249E-01	2.41207E-01	2.65739E-01	9.23000E-01
5	4.30	7.35584E-03	1.01281E-01	2.41207E-01	2.65739E-01	9.23000E-01
6	6.60	5.93738E-03	8.17504E-02	2.41207E-01	2.65739E-01	9.23000E-01

1 012

ADEN

12

11

10

9

8

7

6

5

4

3

RUN=4550 TOP AIR PT = 644.70  
 IPC = 760.00 DEG-R MINF = 7.938  
 TI = 542.00 DEG-R R/FT = 3.06015E+06  
 TO = 1345.00 DEG-R  
 SQROCK= .0586 ALPHA=35.000  
 MODEL=31 PHI= 0.000  
 HS= 7.25173E-02 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/TO
1	.40	3.43750E-02	4.74025E-01	3.11680E-01	3.71001E-01	9.23000E-01
2	1.30	1.90678E-02	2.62942E-01	3.11680E-01	3.71001E-01	9.23000E-01
3	1.70	1.66743E-02	2.29936E-01	3.11680E-01	3.71001E-01	9.23000E-01
4	2.50	1.37500E-02	1.89610E-01	3.11680E-01	3.71001E-01	9.23000E-01
5	2.90	1.27666E-02	1.76049E-01	3.11680E-01	3.71001E-01	9.23000E-01
6	3.30	1.19678E-02	1.65034E-01	3.11680E-01	3.71001E-01	9.23000E-01
7	3.70	1.13024E-02	1.55859E-01	3.11680E-01	3.71001E-01	9.23000E-01
8	4.70	1.00282E-02	1.38287E-01	3.11680E-01	3.71001E-01	9.23000E-01
9	5.20	9.53391E-03	1.31471E-01	3.11680E-01	3.71001E-01	9.23000E-01
10	6.00	8.87559E-03	1.22393E-01	3.11680E-01	3.71001E-01	9.23000E-01
11	8.10	7.63889E-03	1.05339E-01	3.11680E-01	3.71001E-01	9.23000E-01
12	11.70	6.35594E-03	8.76473E-02	3.11680E-01	3.71001E-01	9.23000E-01
13	14.90	5.63222E-03	7.76673E-02	3.11680E-01	3.71001E-01	9.23000E-01
14	17.00	5.27288E-03	7.27121E-02	3.11680E-01	3.71001E-01	9.23000E-01

RUN=4551 TOP AIR PT = 1389.70  
TPC = 910.00 DEG-R MINF = 8.032  
TI = 542.00 DEG-R R/FT = 5.92822E+06  
TO = 1410.00 DEG-R  
SQROCK = .0613 ALPHA = 35.000  
MODEL = 22 PHI = 0.000  
HS = 1.04063E-01 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/TO
1	1.30	3.91002E-02	3.75736E-01	4.84574E-01	7.27261E-01	9.23000E-01
2	2.50	2.81956E-02	2.70947E-01	4.84574E-01	7.27261E-01	9.23000E-01
3	2.90	2.61789E-02	2.51568E-01	4.84574E-01	7.27261E-01	9.23000E-01
4	3.30	2.45411E-02	2.35829E-01	4.84574E-01	7.27261E-01	9.23000E-01
5	3.40	2.41775E-02	2.32335E-01	4.84574E-01	7.27261E-01	9.23000E-01
6	3.80	2.28696E-02	2.19767E-01	4.84574E-01	7.27261E-01	9.23000E-01
7	5.00	1.99373E-02	1.91589E-01	4.84574E-01	7.27261E-01	9.23000E-01
8	6.00	1.82002E-02	1.74896E-01	4.84574E-01	7.27261E-01	9.23000E-01
9	6.50	1.74861E-02	1.68034E-01	4.84574E-01	7.27261E-01	9.23000E-01
10	8.10	1.56642E-02	1.50526E-01	4.84574E-01	7.27261E-01	9.23000E-01
11	10.70	1.36288E-02	1.30967E-01	4.84574E-01	7.27261E-01	9.23000E-01

RUN=4552 TOP AIR PT = 674.70  
 TPC = 760.00 DEG-R MINF = 7.944  
 TI = 541.00 DEG-R R/FT = 3.27818E+06  
 TO = 1325.00 DEG-R  
 SQROCK= .0586 ALPHA=35.000  
 MODEL=41 PHI= 0.000  
 HS= 7.39513E-02 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/TO
1	1.30	1.98629E-02	2.68594E-01	3.21126E-01	3.86471E-01	9.23000E-01
2	2.20	1.52687E-02	2.06470E-01	3.21126E-01	3.86471E-01	9.23000E-01
3	2.60	1.40452E-02	1.89925E-01	3.21126E-01	3.86471E-01	9.23000E-01
4	3.00	1.30754E-02	1.76810E-01	3.21126E-01	3.86471E-01	9.23000E-01
5	3.80	1.16178E-02	1.57100E-01	3.21126E-01	3.86471E-01	9.23000E-01
6	4.60	1.05593E-02	1.42787E-01	3.21126E-01	3.86471E-01	9.23000E-01
7	5.50	9.65679E-03	1.30583E-01	3.21126E-01	3.86471E-01	9.23000E-01
8	6.50	8.88296E-03	1.20119E-01	3.21126E-01	3.86471E-01	9.23000E-01
9	8.80	7.63436E-03	1.03235E-01	3.21126E-01	3.86471E-01	9.23000E-01
10	10.00	7.16167E-03	9.68430E-02	3.21126E-01	3.86471E-01	9.23000E-01
11	10.50	6.98907E-03	9.45091E-02	3.21126E-01	3.86471E-01	9.23000E-01
12	12.10	6.51061E-03	8.80391E-02	3.21126E-01	3.86471E-01	9.23000E-01
13	13.70	6.11863E-03	8.27386E-02	3.21126E-01	3.86471E-01	9.23000E-01
14	15.00	5.84748E-03	7.90720E-02	3.21126E-01	3.86471E-01	9.23000E-01
15	16.80	5.52535E-03	7.47160E-02	3.21126E-01	3.86471E-01	9.23000E-01

ORIGINAL PAGE IS  
 OF POOR QUALITY

RUN=4506 SIDE AIR PT = 659.70  
 TPC = 710.00 DEG-R MINF = 7.941  
 TI = 540.00 DEG-R R/FT = 3.05244E+06  
 TO = 1365.00 DEG-R  
 SQROCK= .0574 ALPHA=30.000  
 MODEL=22 PHI= 0.000  
 HS= 7.33111E-02 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/TO
1	4.30	7.57503E-03	1.03327E-01	2.46914E-01	2.73657E-01	9.00000E-01
2	4.70	7.24552E-03	9.88325E-02	2.46914E-01	2.73657E-01	9.00000E-01
3	5.50	6.69788E-03	9.13624E-02	2.46914E-01	2.73657E-01	9.00000E-01
4	7.50	5.73572E-03	7.82381E-02	2.46914E-01	2.73657E-01	9.00000E-01
5	8.40	5.41975E-03	7.39280E-02	2.46914E-01	2.73657E-01	9.00000E-01
6	9.60	5.06971E-03	6.91533E-02	2.46914E-01	2.73657E-01	9.00000E-01
7	10.40	4.87082E-03	6.64404E-02	2.46914E-01	2.73657E-01	9.00000E-01
8	12.00	4.53448E-03	6.18526E-02	2.46914E-01	2.73657E-01	9.00000E-01
9	13.70	4.24383E-03	5.78880E-02	2.46914E-01	2.73657E-01	9.00000E-01

RUN=4513 SIDE AIR PT = 171.70  
TPC = 635.00 DEG-R MINF = 7.756  
TI = 541.00 DEG-R R/FT = 1.00031E+06  
TO = 1230.00 DEG-R  
SQROCK= .0537 ALPHA=30.000  
MODEL=31 PHI= 0.000  
HS= 3.88940E-02 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/TO
1	2.60	5.65510E-03	1.45398E-01	1.66078E-01	1.69806E-01	9.00000E-01
2	4.20	4.44941E-03	1.14399E-01	1.66078E-01	1.69806E-01	9.00000E-01
3	9.20	3.00631E-03	7.72949E-02	1.66078E-01	1.69806E-01	9.00000E-01
4	14.30	2.41134E-03	6.19979E-02	1.66078E-01	1.69806E-01	9.00000E-01

RUN=4519 SIDE AIR PT = 1414.70  
 TPC = 810.00 DEG-R MINF = 8.034  
 TF = 540.00 DEG-R R/FT = 6.17649E+06  
 TO = 1390.00 DEG-R  
 SQRCK = .0595 ALPHA=30.000  
 MODEL=31 PHI= 0.000  
 HS= 1.04939E-01 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/TO
1	1.50	2.38611E-02	2.27380E-01	3.79747E-01	4.91155E-01	9.00000E-01
2	3.80	1.49915E-02	1.42858E-01	3.79747E-01	4.91155E-01	9.00000E-01
3	7.00	1.10455E-02	1.05256E-01	3.79747E-01	4.91155E-01	9.00000E-01
4	9.60	9.43192E-03	8.98798E-02	3.79747E-01	4.91155E-01	9.00000E-01
5	10.60	8.97600E-03	8.55352E-02	3.79747E-01	4.91155E-01	9.00000E-01
6	11.60	8.58039E-03	8.17652E-02	3.79747E-01	4.91155E-01	9.00000E-01



RUN=4522 SIDE AIR PT = 639.70  
 TPC = 610.00 DEG-R MINF = 7.937  
 TI = 541.00 DEG-R R/FT = 3.17441E+06  
 TO = 1310.00 DEG-R  
 SQRQCK= .0527 ALPHA=30.000  
 MODEL=22 PHI= 0.000  
 HS= 7.16596E-02 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/TO
1	.70	6.60590E-03	9.21844E-02	1.08150E-01	1.04875E-01	9.00000E-01
2	1.50	4.51269E-03	6.29739E-02	1.08150E-01	1.04875E-01	9.00000E-01
3	1.90	4.00963E-03	5.59538E-02	1.08150E-01	1.04875E-01	9.00000E-01
4	2.30	3.64432E-03	5.08560E-02	1.08150E-01	1.04875E-01	9.00000E-01
5	2.70	3.36356E-03	4.69380E-02	1.08150E-01	1.04875E-01	9.00000E-01
6	3.10	3.13906E-03	4.38052E-02	1.08150E-01	1.04875E-01	9.00000E-01
7	3.50	2.95425E-03	4.12261E-02	1.08150E-01	1.04875E-01	9.00000E-01
8	3.90	2.79865E-03	3.90548E-02	1.08150E-01	1.04875E-01	9.00000E-01
9	4.70	2.54937E-03	3.55760E-02	1.08150E-01	1.04875E-01	9.00000E-01
10	5.10	2.44735E-03	3.41524E-02	1.08150E-01	1.04875E-01	9.00000E-01
11	5.90	2.27539E-03	3.17527E-02	1.08150E-01	1.04875E-01	9.00000E-01
12	6.70	2.13522E-03	2.97968E-02	1.08150E-01	1.04875E-01	9.00000E-01
13	7.50	2.01814E-03	2.81628E-02	1.08150E-01	1.04875E-01	9.00000E-01
14	8.70	1.87379E-03	2.61485E-02	1.08150E-01	1.04875E-01	9.00000E-01
15	9.90	1.75656E-03	2.45126E-02	1.08150E-01	1.04875E-01	9.00000E-01
16	10.70	1.68962E-03	2.35784E-02	1.08150E-01	1.04875E-01	9.00000E-01
17	11.50	1.62979E-03	2.27435E-02	1.08150E-01	1.04875E-01	9.00000E-01
18	12.30	1.57590E-03	2.19914E-02	1.08150E-01	1.04875E-01	9.00000E-01
19	15.90	1.38606E-03	1.93423E-02	1.08150E-01	1.04875E-01	9.00000E-01

ORIGINAL PAGE IS  
 OF POOR QUALITY

RUN=4529 SIDE AIR PT = 649.70  
TPC = 710.00 DEG-R MINF = 7.939  
TI = 541.00 DEG-R R/FT = 3.12170E+06  
TO = 1335.00 DEG-R  
SQROCK= .0574 ALPHA=25.000  
MODEL=22 PHI= 0.000  
HS= 7.26281E-02 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/TO
1	1.60	1.29910E-02	1.78871E-01	2.55867E-01	2.86281E-01	9.00000E-01
2	4.60	7.66170E-03	1.05492E-01	2.55867E-01	2.86281E-01	9.00000E-01
3	5.60	6.94401E-03	9.56105E-02	2.55867E-01	2.86281E-01	9.00000E-01
4	6.70	6.34844E-03	8.74102E-02	2.55867E-01	2.86281E-01	9.00000E-01
5	7.90	5.84643E-03	8.04982E-02	2.55867E-01	2.86281E-01	9.00000E-01
6	10.00	5.19642E-03	7.15483E-02	2.55867E-01	2.86281E-01	9.00000E-01
7	13.40	4.48902E-03	6.18083E-02	2.55867E-01	2.86281E-01	9.00000E-01
8	14.60	4.30059E-03	5.92138E-02	2.55867E-01	2.86281E-01	9.00000E-01

RUN=4549 SIDE AIR PT = 649.70  
 TPC = 710.00 DEG-R MINE = 7.939  
 TI = 544.00 DEG-R R/FT = 3.12170E+06  
 TO = 1335.00 DEG-R  
 SQROCK= .0574 ALPHA=35.000  
 MODEL=22 PHI= 0.000  
 HS= 7.26281E-02 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/TO
1	1.80	1.20420E-02	1.65804E-01	2.52471E-01	2.81464E-01	9.00000E-01
2	5.90	6.65134E-03	9.15809E-02	2.52471E-01	2.81464E-01	9.00000E-01
3	10.10	5.08364E-03	6.99955E-02	2.52471E-01	2.81464E-01	9.00000E-01
4	14.90	4.68341E-03	6.44848E-02	2.52471E-01	2.81464E-01	9.00000E-01
5	14.60	4.22823E-03	5.82176E-02	2.52471E-01	2.81464E-01	9.00000E-01
6	18.10	3.79749E-03	5.22867E-02	2.52471E-01	2.81464E-01	9.00000E-01

RUN=4550 SIDE AIR PT = 644.70  
TPC = 760.00 DEG-R MINF = 7.938  
TI = 542.00 DEG-R R/FT = 3.06015E+06  
TO = 1345.00 DEG-R  
SQROCK= .0586 ALPHA=35.000  
MODEL=31 PHI= 0.000  
HS= 7.25173E-02 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/TO
1	8.50	7.93466E-03	1.09418E-01	3.26103E-01	3.94766E-01	9.00000E-01
2	9.90	7.35225E-03	1.01386E-01	3.26103E-01	3.94766E-01	9.00000E-01
3	11.20	6.91240E-03	9.53207E-02	3.26103E-01	3.94766E-01	9.00000E-01
4	14.80	6.01322E-03	8.29212E-02	3.26103E-01	3.94766E-01	9.00000E-01
5	18.60	5.36391E-03	7.39673E-02	3.26103E-01	3.94766E-01	9.00000E-01

RUN=4551 SIDE AIR PT = 1389.70  
TPC = 910.00 DEG-R MINF = 8.032  
TI = 542.00 DEG-R R/FT = 5.92822E+06  
TO = 1410.00 DEG-R  
SQROCK= .0613 ALPHA=35.000  
MODEL=22 PHI= 0.000  
HS= 1.04063E-01 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/TO
1	7.70	1.73744E-02	1.66961E-01	5.06190E-01	7.86494E-01	9.00000E-01
2	11.30	1.43422E-02	1.37823E-01	5.06190E-01	7.86494E-01	9.00000E-01
3	13.30	1.32200E-02	1.27038E-01	5.06190E-01	7.86494E-01	9.00000E-01

RUN=4552 SIDE AIR PT = 674.70 PSLP  
 TPC = 760.00 DEG-R MINF = 7.944  
 TI = 541.00 DEG-R R/FT = 3.27818E+06  
 TO = 1325.00 DEG-R  
 SQROCK= .0586 ALPHA=35.000  
 MODEL=41 PHI= 0.000  
 HS= 7.39513E-02 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/TO
1	8.80	8.13514E-03	1.10007E-01	3.36147E-01	4.11821E-01	9.00000E-01
2	10.90	7.30960E-03	9.88434E-02	3.36147E-01	4.11821E-01	9.00000E-01
3	13.00	6.69322E-03	9.05084E-02	3.36147E-01	4.11821E-01	9.00000E-01
4	14.50	6.33757E-03	8.56992E-02	3.36147E-01	4.11821E-01	9.00000E-01
5	15.20	6.18992E-03	8.37026E-02	3.36147E-01	4.11821E-01	9.00000E-01
6	17.70	5.73614E-03	7.75665E-02	3.36147E-01	4.11821E-01	9.00000E-01

RUN=4556 TOP ATR PT = 171.70  
 TPC = 710.00 DEG-R MINF = 7.756  
 TI = 536.00 DEG-R R/FT = 9.11711E+05  
 TO = 1300.00 DEG-R  
 SQROCK= .0574 -- ALPHA=35.000  
 MODEL=22 PHI= 0.000  
 HS= 3.92274E-02 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T,SEC	H,BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/TO
1	1.80	1.26297E-02	3.21960E-01	2.62088E-01	2.95200E-01	9.23000E-01
2	3.80	8.69233E-03	2.21588E-01	2.62088E-01	2.95200E-01	9.23000E-01
3	6.90	6.45065E-03	1.64442E-01	2.62088E-01	2.95200E-01	9.23000E-01
4	8.20	5.91726E-03	1.50845E-01	2.62088E-01	2.95200E-01	9.23000E-01
5	11.80	4.93272E-03	1.25747E-01	2.62088E-01	2.95200E-01	9.23000E-01
6	14.80	4.40450E-03	1.12281E-01	2.62088E-01	2.95200E-01	9.23000E-01
7	19.10	3.87714E-03	9.88375E-02	2.62088E-01	2.95200E-01	9.23000E-01

RUN=4557 TOP AIR PT = 171.70  
TPC = 760.00 DEG-R MINF = 7.756  
TI = 533.00 DEG-R R/FT = 9.41790E+05  
TO = 1275.00 DEG-R  
SQROCK= .0586 ALPHA=35.000  
MODEL=41 PHI= 0.000  
HS= 3.91988E-02 BTU/FT, SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT, SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/TO
1	3.60	1.36101E-02	3.47208E-01	3.52580E-01	4.40672E-01	9.23000E-01
2	8.90	8.65602E-03	2.20824E-01	3.52580E-01	4.40672E-01	9.23000E-01
3	13.60	7.00235E-03	1.78637E-01	3.52580E-01	4.40672E-01	9.23000E-01
4	17.00	6.26309E-03	1.59778E-01	3.52580E-01	4.40672E-01	9.23000E-01

(, \$, OR = EXPECTED, MISSING  
ERROR NUMBER 0066 DETECTED BY INPUTN AT ADDRESS 011716  
CALLED FROM HEATS AT 000134

#### ERROR SUMMARY

ERROR	TIMES
0066	0001



RUN=4558 TOP AIR PT = 1449.70  
 TPC = 960.00 DEG-R MINF = 8.037  
 TT = 534.00 DEG-R R/FT = 6.13873E+06  
 TO = 1415.00 DEG-R  
 SOROCK = .0617 ALPHA=35.000  
 MDEL=31 PHI= 0.000  
 HS= 1.06087E-01 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAN/TO
1	1.30	5.01940E-02	4.73140E-01	5.51781E-01	9.27552E-01	9.23000E-01
2	2.50	3.61954E-02	3.41186E-01	5.51781E-01	9.27552E-01	9.23000E-01
3	2.90	3.36066E-02	3.16783E-01	5.51781E-01	9.27552E-01	9.23000E-01
4	4.20	2.79254E-02	2.63231E-01	5.51781E-01	9.27552E-01	9.23000E-01
5	5.30	2.48591E-02	2.34328E-01	5.51781E-01	9.27552E-01	9.23000E-01
6	6.30	2.28010E-02	2.14927E-01	5.51781E-01	9.27552E-01	9.23000E-01
7	7.60	2.07595E-02	1.95684E-01	5.51781E-01	9.27552E-01	9.23000E-01
8	9.70	1.83754E-02	1.73211E-01	5.51781E-01	9.27552E-01	9.23000E-01
9	11.70	1.67313E-02	1.57713E-01	5.51781E-01	9.27552E-01	9.23000E-01
10	15.30	1.46311E-02	1.37916E-01	5.51781E-01	9.27552E-01	9.23000E-01

RUN=4559 TOR AIR PT = 1974.70  
TPC =1010.00 DEG-R MINF = 8.072  
TI = -536.00 DEG-R R/FT = 8.17704E+06  
TO =1425.00 DEG-R  
SQROCK= .0617 ALPHA=35.000  
MODEL=22 PHI= 0.000  
HS= 1.22582E-01 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/TO
1	1.30	6.17861E-02	5.04041E-01	6.08258E-01	1.14177E+00	9.23000E-01
2	3.30	3.87798E-02	3.16359E-01	6.08258E-01	1.14177E+00	9.23000E-01
3	5.00	3.15049E-02	2.57011E-01	6.08258E-01	1.14177E+00	9.23000E-01
4	6.10	2.85232E-02	2.32687E-01	6.08258E-01	1.14177E+00	9.23000E-01
5	7.20	2.62540E-02	2.14176E-01	6.08258E-01	1.14177E+00	9.23000E-01
6	9.40	2.29773E-02	1.87445E-01	6.08258E-01	1.14177E+00	9.23000E-01

20

RUN=4563 TOP AIR PT = 1424.70  
 TPC =1010.00 DEG-R MINF = 8.035  
 TI = 534.00 DEG-R R/FT = 5.93155E+06  
 TO =1430.00 DEG-R  
 SQROCK= .0617 ALPHA=35.000  
 MODEL=41 PHI= 0.000  
 HS= 1.05255E-01 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/TO
1	1.30	6.11937E-02	5.81382E-01	6.05683E-01	1.13082E+00	9.23000E-01
2	3.70	3.62725E-02	3.44614E-01	6.05683E-01	1.13082E+00	9.23000E-01
3	6.00	2.84841E-02	2.70619E-01	6.05683E-01	1.13082E+00	9.23000E-01
4	9.10	2.31290E-02	2.19742E-01	6.05683E-01	1.13082E+00	9.23000E-01
5	13.30	1.91316E-02	1.81764E-01	6.05683E-01	1.13082E+00	9.23000E-01

RUN=4561 TOP AIR PT = 160.70  
TPC = 635.00 DEG-R MINF = 7.746  
TI = 538.00 DEG-R R/FT = 8.84160E+05  
TO = 1275.00 DEG-R  
SQROCK= .0537 ALPHA=35.000  
MODEL=31 PHI= 0.000  
HS= 3.78795E-02 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/TO
1	1.30	7.21493E-03	1.90471E-01	1.51841E-01	1.53190E-01	9.23000E-01
2	2.30	5.42425E-03	1.43198E-01	1.51841E-01	1.53190E-01	9.23000E-01
3	3.30	4.52842E-03	1.19548E-01	1.51841E-01	1.53190E-01	9.23000E-01
4	4.50	3.87791E-03	1.02375E-01	1.51841E-01	1.53190E-01	9.23000E-01
5	6.60	3.20208E-03	8.45333E-02	1.51841E-01	1.53190E-01	9.23000E-01
6	8.30	2.85539E-03	7.53808E-02	1.51841E-01	1.53190E-01	9.23000E-01
7	12.00	2.37472E-03	6.26915E-02	1.51841E-01	1.53190E-01	9.23000E-01
8	16.70	2.01301E-03	5.31424E-02	1.51841E-01	1.53190E-01	9.23000E-01

RUN=4562 TOP AIR PT = 1394.70  
 TPC = 760.00 DEG-R MINF = 8.032  
 TI = 541.00 DEG-R R/FT = 5.84493E+06  
 T0 = 1425.00 DEG-R  
 SQROCK= .0586 \*-- ALPHA=35.000  
 MODEL=22 PHI= 0.000  
 HS= 1.04489E-01 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/T0
1	1.30	1.67485E-02	1.60289E-01	2.82845E-01	3.25875E-01	9.23000E-01
2	1.50	1.55921E-02	1.49221E-01	2.82845E-01	3.25875E-01	9.23000E-01
3	1.80	1.42335E-02	1.36220E-01	2.82845E-01	3.25875E-01	9.23000E-01
4	2.20	1.28747E-02	1.23215E-01	2.82845E-01	3.25875E-01	9.23000E-01
5	3.00	1.10252E-02	1.05515E-01	2.82845E-01	3.25875E-01	9.23000E-01
6	4.00	9.54814E-03	9.13790E-02	2.82845E-01	3.25875E-01	9.23000E-01
7	5.00	8.54012E-03	8.17319E-02	2.82845E-01	3.25875E-01	9.23000E-01
8	5.70	7.99855E-03	7.65489E-02	2.82845E-01	3.25875E-01	9.23000E-01
9	6.00	7.79603E-03	7.46107E-02	2.82845E-01	3.25875E-01	9.23000E-01

RUN=4563 TOP AIR PT = 165.70  
TPC = 635.00 DEG-R MINF = 7.751  
TI = 536.00 DEG-R R/FT = 9.47438E+05  
TO =1245.00 DEG-R  
SQROCK= .0537 ALPHA=35.000  
MODEL=41 PHI= 0.000  
HS= 3.83167E-02 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/TO
1	1.30	7.74163E-03	2.02043E-01	1.61465E-01	1.64373E-01	9.23000E-01
2	3.40	4.78701E-03	1.24933E-01	1.61465E-01	1.64373E-01	9.23000E-01
3	4.50	4.16100E-03	1.08595E-01	1.61465E-01	1.64373E-01	9.23000E-01
4	5.80	3.66514E-03	9.56538E-02	1.61465E-01	1.64373E-01	9.23000E-01
5	7.80	3.16051E-03	8.24839E-02	1.61465E-01	1.64373E-01	9.23000E-01
6	10.80	2.68591E-03	7.00978E-02	1.61465E-01	1.64373E-01	9.23000E-01
7	16.00	2.20670E-03	5.75912E-02	1.61465E-01	1.64373E-01	9.23000E-01

RUN=4565 TOP AIR PT = 1469.70  
 TPC = 810.00 DEG-R MINF = 8.038  
 TI = 538.00 DEG-R R/FT = 6.07688E+06  
 TO = 1435.00 DEG-R  
 SQROCK= .0595 ALPHA=35.000  
 MODEL=31 PHI= 0.000  
 HS= 1.07168E-01 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/TO
1	1.30	2.23707E-02	2.08745E-01	3.45834E-01	4.28681E-01	9.23000E-01
2	1.60	2.01647E-02	1.88160E-01	3.45834E-01	4.28681E-01	9.23000E-01
3	2.00	1.80358E-02	1.68295E-01	3.45834E-01	4.28681E-01	9.23000E-01
4	2.60	1.58185E-02	1.47605E-01	3.45834E-01	4.28681E-01	9.23000E-01
5	3.30	1.40409E-02	1.31018E-01	3.45834E-01	4.28681E-01	9.23000E-01
6	4.40	1.21598E-02	1.13465E-01	3.45834E-01	4.28681E-01	9.23000E-01
7	5.90	1.05009E-02	9.79854E-02	3.45834E-01	4.28681E-01	9.23000E-01
8	7.60	9.25220E-03	8.63338E-02	3.45834E-01	4.28681E-01	9.23000E-01

RUN=4567 TOP AIR PT = 1464.70  
TPC = 860.00 DEG-R MINF = 8.038  
TI = 537.00 DEG-R R/FT = 6.12777E+06  
TO = 1425.00 DEG-R  
SQROCK= .0604 ALPHA=35.000  
MODEL=41 PHI= 0.000  
HS= 1.06859E-01 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/TO
1	1.30	2.98002E-02	2.78874E-01	4.15020E-01	5.62540E-01	9.23000E-01
2	1.70	2.60595E-02	2.43868E-01	4.15020E-01	5.62540E-01	9.23000E-01
3	2.00	2.40257E-02	2.24835E-01	4.15020E-01	5.62540E-01	9.23000E-01
4	2.60	2.10719E-02	1.97194E-01	4.15020E-01	5.62540E-01	9.23000E-01
5	3.00	1.96169E-02	1.83577E-01	4.15020E-01	5.62540E-01	9.23000E-01
6	3.30	1.87040E-02	1.75034E-01	4.15020E-01	5.62540E-01	9.23000E-01
7	3.90	1.72051E-02	1.61008E-01	4.15020E-01	5.62540E-01	9.23000E-01
8	4.80	1.55085E-02	1.45131E-01	4.15020E-01	5.62540E-01	9.23000E-01
9	8.10	1.19385E-02	1.11722E-01	4.15020E-01	5.62540E-01	9.23000E-01
10	11.00	1.02446E-02	9.58702E-02	4.15020E-01	5.62540E-01	9.23000E-01
11	14.10	9.04860E-03	8.46779E-02	4.15020E-01	5.62540E-01	9.23000E-01

232

12

11

10

9

8

7

6

5

4



RUN=4568 TOP AIR PT = 1929.70  
 TPC =1010.00 DEG-R MINF = 8.070  
 TI = 540.00 DEG-R R/FT = 7.85879E+06  
 TO =1440.00 DEG-R  
 SQROCK= .0617 - ALPHA=30.000  
 MODEL=31 PHI= 0.000  
 HS= 1.21392E-01 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/TO
1	1.30	6.16804E-02	5.08111E-01	6.07801E-01	1.13981E+00	9.12000E-01
2	2.00	4.97283E-02	4.09652E-01	6.07801E-01	1.13981E+00	9.12000E-01
3	4.90	3.17703E-02	2.61717E-01	6.07801E-01	1.13981E+00	9.12000E-01
4	7.10	2.63931E-02	2.17421E-01	6.07801E-01	1.13981E+00	9.12000E-01
5	11.20	2.10141E-02	1.73110E-01	6.07801E-01	1.13981E+00	9.12000E-01

RUN=4569 TOP AIR PT = 794.70  
 TPC = 810.00 DEG-R MINE = 7.964  
 TI = 539.00 DEG-R R/FT = 3.54256E+06  
 TO = 1390.00 DEG-R  
 SOROCK= .0595 ALPHA=30.000  
 MODEL= 22 PHI= 0.000  
 HS= 8.01982E-02 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/TO
1	1.30	2.48509E-02	3.09868E-01	3.71905E-01	4.76208E-01	9.12000E-01
2	2.90	1.66385E-02	2.07468E-01	3.71905E-01	4.76208E-01	9.12000E-01
3	4.30	1.36641E-02	1.70379E-01	3.71905E-01	4.76208E-01	9.12000E-01
4	5.70	1.18680E-02	1.47983E-01	3.71905E-01	4.76208E-01	9.12000E-01
5	7.30	1.04870E-02	1.30764E-01	3.71905E-01	4.76208E-01	9.12000E-01
6	9.10	9.39276E-03	1.17119E-01	3.71905E-01	4.76208E-01	9.12000E-01
7	11.40	8.39192E-03	1.04640E-01	3.71905E-01	4.76208E-01	9.12000E-01
8	14.4		9.54 E-02			

RUN=4570 TOP AIR PT = 1884.70  
TPC = 860.00 DEG-R MINF = 8.067  
TI = 542.00 DEG-R R/FT = 7.59384E+06  
TO = 1450.00 DEG-R  
SQROCK= .0604 ALPHA=30.000  
MODEL=31 PHI= 0.000  
HS= 1.20444E-01 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/TO
1	1.30	2.89603E-02	2.40446E-01	4.07483E-01	5.46685E-01	9.12000E-01
2	2.80	1.97331E-02	1.63836E-01	4.07483E-01	5.46685E-01	9.12000E-01
3	4.10	1.63073E-02	1.35393E-01	4.07483E-01	5.46685E-01	9.12000E-01
4	6.30	1.31554E-02	1.09224E-01	4.07483E-01	5.46685E-01	9.12000E-01
5	7.90	1.17479E-02	9.75383E-02	4.07483E-01	5.46685E-01	9.12000E-01

RUN=4571 TOP AIR PT = 789.70  
TPC = 860.00 DEG-R MINF = 7.964  
TI = 548.00 DEG-R R/FT = 4.01591E+06  
TO = 1285.00 DEG-R  
SQROCK= .0604 ALPHA=30.000  
MODEL=22 PHI= 0.000  
HS= 7.92744E-02 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/TO
1	1.30	4.07509E-02	5.14049E-01	5.00064E-01	7.69258E-01	9.12000E-01
2	4.70	2.14319E-02	2.70350E-01	5.00064E-01	7.69258E-01	9.12000E-01
3	7.10	1.74373E-02	2.19962E-01	5.00064E-01	7.69258E-01	9.12000E-01
4	12.40	1.31947E-02	1.66443E-01	5.00064E-01	7.69258E-01	9.12000E-01
5	16.30	1.15084E-02	1.45172E-01	5.00064E-01	7.69258E-01	9.12000E-01

RUN=4572 TOP AIR PT = 914.70  
 TPC = 860.00 DEG-R MINF = 7.982  
 TI = 543.00 DEG-R R/FT = 4.31229E+06  
 TO = 1340.00 DEG-R  
 SOROCK= .0604 ALPHA=30.000  
 MODEL=22 PHI= 0.000  
 HS= 8.52539E-02 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/TO
1	1.30	3.61124E-02	4.23586E-01	4.66808E-01	6.81696E-01	9.12000E-01
2	3.20	2.30172E-02	2.69984E-01	4.66808E-01	6.81696E-01	9.12000E-01
3	5.20	1.80562E-02	2.11793E-01	4.66808E-01	6.81696E-01	9.12000E-01
4	7.70	1.48382E-02	1.74048E-01	4.66808E-01	6.81696E-01	9.12000E-01
5	11.00	1.24146E-02	1.45619E-01	4.66808E-01	6.81696E-01	9.12000E-01
6	13.80	1.10838E-02	1.30009E-01	4.66808E-01	6.81696E-01	9.12000E-01

RUN=4573 TOP AIR PT = 167.70  
TPC = 760.00 DEG-R MINF = 7.753  
TI = 544.00 DEG-R R/FT = 1.00542E+06  
TO = 1210.00 DEG-R  
SQROCK= .0586 ALPHA=30.000  
MODEL=31V0 PHI= 0.000  
HS= 3.85647E-02 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/TO
1	3.70	1.53357E-02	3.97662E-01	3.86045E-01	5.03393E-01	9.12000E-01
2	6.80	1.13123E-02	2.93333E-01	3.86045E-01	5.03393E-01	9.12000E-01
3	8.00	1.04294E-02	2.70439E-01	3.86045E-01	5.03393E-01	9.12000E-01
4	12.80	8.24518E-03	2.13801E-01	3.86045E-01	5.03393E-01	9.12000E-01

RUN=4574 TOP AIR PT = 869.70  
 TPC = 760.00 DEG-R MINF = 7.976  
 TI = 539.00 DEG-R R/FT = 3.93447E+06  
 TO = 1375.00 DEG-R  
 SOROCK= .0586 ALPHA=30.000  
 MODEL=22 PHI= 0.000  
 HS= 8.35322E-02 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT. SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/TO
1	1.40	1.81672E-02	2.17488E-01	3.09091E-01	3.66822E-01	9.12000E-01
2	2.50	1.35951E-02	1.62753E-01	3.09091E-01	3.66822E-01	9.12000E-01
3	3.20	1.20165E-02	1.43855E-01	3.09091E-01	3.66822E-01	9.12000E-01
4	4.20	1.04889E-02	1.25567E-01	3.09091E-01	3.66822E-01	9.12000E-01
5	6.10	8.70338E-03	1.04192E-01	3.09091E-01	3.66822E-01	9.12000E-01
6	8.70	7.28775E-03	8.72447E-02	3.09091E-01	3.66822E-01	9.12000E-01
7	11.10	6.45196E-03	7.72391E-02	3.09091E-01	3.66822E-01	9.12000E-01

11.4

RUN=4577 TOP AIR PT = 164.70  
TPC = 810.00 DEG-R MINE = 7.750  
TI = 536.00 DEG-R R/FT = 9.29425E+05  
TO = 1255.00 DEG-R  
SQROCK= .0595 ALPHA=30.000  
MODEL=31V30 PHI= 0.000  
HS= 3.84023E-02 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/TO
1	3.60	2.01170E-02	5.23849E-01	4.50243E-01	6.41501E-01	9.12000E-01
2	7.90	1.35800E-02	3.53626E-01	4.50243E-01	6.41501E-01	9.12000E-01
3	14.40	1.00585E-02	2.61924E-01	4.50243E-01	6.41501E-01	9.12000E-01
4	18.20	8.94702E-03	2.32982E-01	4.50243E-01	6.41501E-01	9.12000E-01



RUN=4579 TOP AIR PT = 170.70  
TPC = 660.00 DEG-R MINF = 7.755  
TI = 536.00 DEG-R R/FT = 1.00159E+06  
TO = 1225.00 DEG-R  
SQROCK=0.0546 ALPHA=30.000  
MODEL=31V30 PHI= 0.000  
HS= 3.88214E-02 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/TO
1	1.30	1.09392E-02	2.81784E-01	2.13352E-01	2.28437E-01	9.12000E-01
2	3.50	6.66691E-03	1.71733E-01	2.13352E-01	2.28437E-01	9.12000E-01
3	6.80	4.78304E-03	1.23206E-01	2.13352E-01	2.28437E-01	9.12000E-01
4	11.30	3.71039E-03	9.55759E-02	2.13352E-01	2.28437E-01	9.12000E-01

RUN=4581 TOP AIR PT = 639.70  
TPC = 960.00 DEG-R MINF = 7.937  
TI = 540.00 DEG-R R/FT = 2.99997E+06  
TO = 1355.00 DEG-R  
SQROCK= .0617 ALPHA=30.000  
MODEL=31V30 PHI= 0.000  
HS= 7.21515E-02 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/TO
1	1.30	6.07323E-02	8.41732E-01	6.03656E-01	1.12229E+00	9.12000E-01
2	1.80	5.16125E-02	7.15335E-01	6.03656E-01	1.12229E+00	9.12000E-01
3	5.80	2.87526E-02	3.98503E-01	6.03656E-01	1.12229E+00	9.12000E-01
4	9.30	2.27065E-02	3.14705E-01	6.03656E-01	1.12229E+00	9.12000E-01

RUN=4582 TOP AIR PT = 634.70  
TPC = 760.00 DEG-R MINF = 7.936  
TI = 539.00 DEG-R R/FT = 3.03331E+06  
TO = 1340.00 DEG-R  
SQROCK= .0586 ALPHA=30.000  
MODEL=31V30 PHI= 0.000  
HS= 7.19655E-02 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/TO
1	1.30	2.00686E-02	2.78864E-01	3.23535E-01	3.90472E-01	9.12000E-01
2	2.10	1.57899E-02	2.19409E-01	3.23535E-01	3.90472E-01	9.12000E-01
3	2.60	1.41906E-02	1.97186E-01	3.23535E-01	3.90472E-01	9.12000E-01
4	3.30	1.25959E-02	1.75028E-01	3.23535E-01	3.90472E-01	9.12000E-01
5	4.70	1.05545E-02	1.46661E-01	3.23535E-01	3.90472E-01	9.12000E-01
6	7.60	8.30006E-03	1.15334E-01	3.23535E-01	3.90472E-01	9.12000E-01
7	12.00	6.60537E-03	9.17853E-02	3.23535E-01	3.90472E-01	9.12000E-01

ORIGINAL PAGE IS  
OF POOR QUALITY

RUN=4583 TOP AIR PT = 1444.70  
TPC =1010.00 DEG-R MINF = 8.036  
TI = 540.00 DEG-R R/FT = 6.01188E+06  
TO =1430.00 DEG-R  
SQROCK= .0617 ALPHA=30.000  
MODEL=31V30 PHI= 0.000  
HS= 1.05943E-01 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/TO
1	1.30	6.33839E-02	5.98281E-01	6.15054E-01	1.17129E+00	9.12000E-01
2	2.20	4.87236E-02	4.59902E-01	6.15054E-01	1.17129E+00	9.12000E-01
3	3.40	3.91933E-02	3.69945E-01	6.15054E-01	1.17129E+00	9.12000E-01
4	7.20	2.69330E-02	2.54220E-01	6.15054E-01	1.17129E+00	9.12000E-01
5	11.10	2.16915E-02	2.04746E-01	6.15054E-01	1.17129E+00	9.12000E-01

RUN=4584 TOP AIR PT = 1419.70  
TPC = 810.00 DEG-R MINF = 8.034  
TI = 542.00 DEG-R R/FT = 5.80985E+06  
TO = 1445.00 DEG-R  
SQROCK= .0595 ALPHA=30.000  
MODEL=31V30 PHI= 0.000  
HS= 1.05521E-01 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/TO
1	1.20	2.32458E-02	2.20295E-01	3.45432E-01	4.27974E-01	9.12000E-01
2	1.90	1.84739E-02	1.75073E-01	3.45432E-01	4.27974E-01	9.12000E-01
3	4.70	1.17459E-02	1.11313E-01	3.45432E-01	4.27974E-01	9.12000E-01
4	7.90	9.05984E-03	8.58584E-02	3.45432E-01	4.27974E-01	9.12000E-01

RUN=4586 TOP AIR PT = .644.70  
TPC = 910.00 DEG-R MINF = 7.938  
TI = 542.00 DEG-R R/FT = 3.00399E+06  
TO = 1360.00 DEG-R  
SQROCK= .0613 ALPHA=30.000  
MODEL=31V0 PHI= 0.000  
HS= 7.25010E-02 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/TO
1	4.20	2.53609E-02	3.49801E-01	5.26979E-01	8.47869E-01	9.12000E-01
2	7.50	1.89783E-02	2.61767E-01	5.26979E-01	8.47869E-01	9.12000E-01
3	12.80	1.45273E-02	2.00374E-01	5.26979E-01	8.47869E-01	9.12000E-01
4	15.60	1.31591E-02	1.81503E-01	5.26979E-01	8.47869E-01	9.12000E-01

RUN=4588 TOP AIR PT = 649.70  
 TPC = 710.00 DEG-R MINF = 7.939  
 TI = 542.00 DEG-R R/FT = 3.00792E+06  
 TO = 1365.00 DEG-R  
 SQROCK= .0574 ALPHA=30.000  
 MODEL=31V0 PHI= 0.000  
 HS= 7.27930E-02 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/TO
1	1.30	1.32264E-02	1.81698E-01	2.39017E-01	2.62725E-01	9.12000E-01
2	2.10	1.04065E-02	1.42960E-01	2.39017E-01	2.62725E-01	9.12000E-01
3	4.10	7.44768E-03	1.02313E-01	2.39017E-01	2.62725E-01	9.12000E-01
4	5.90	6.20850E-03	8.52898E-02	2.39017E-01	2.62725E-01	9.12000E-01
5	8.80	5.08360E-03	6.98364E-02	2.39017E-01	2.62725E-01	9.12000E-01

RUN=4590 TOP AIR PT = 1399.70  
TPC =1010.00 DEG-R MINF = 8.033  
TI = 536.00 DEG-R R/FT = 5.89955E+06  
TO =1420.00 DEG-R  
SQROCK= .0617 ALPHA=30.000  
MODEL=31V0 PHI= 0.000  
HS= 1.04315E-01 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T,SEC	H,BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/TO
1	1.30	6.56836E-02	6.29663E-01	6.24473E-01	1.21379E+00	9.12000E-01
2	2.40	4.83418E-02	4.63420E-01	6.24473E-01	1.21379E+00	9.12000E-01
3	3.50	4.00308E-02	3.83748E-01	6.24473E-01	1.21379E+00	9.12000E-01
4	8.00	2.64779E-02	2.53825E-01	6.24473E-01	1.21379E+00	9.12000E-01
5	11.00	2.25804E-02	2.16463E-01	6.24473E-01	1.21379E+00	9.12000E-01



RUN=4591 TOP AIR PT = 1404.70  
 TPC = 860.00 DEG-R MINF = 8.033  
 TI = 539.00 DEG-R R/FT = 5.98995E+06  
 T0 = 1410.00 DEG-R  
 SQROCK= .0604 ALPHA=30.000  
 MODEL=31V0 PHI= 0.000  
 HS= 1.04680E-01 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/T0
1	1.30	3.14976E-02	3.00895E-01	4.29765E-01	5.94583E-01	9.12000E-01
2	2.50	2.27132E-02	2.16978E-01	4.29765E-01	5.94583E-01	9.12000E-01
3	3.60	1.89277E-02	1.80815E-01	4.29765E-01	5.94583E-01	9.12000E-01
4	6.40	1.41958E-02	1.35612E-01	4.29765E-01	5.94583E-01	9.12000E-01
5	8.60	1.22462E-02	1.16987E-01	4.29765E-01	5.94583E-01	9.12000E-01
6	11.20	1.07310E-02	1.02513E-01	4.29765E-01	5.94583E-01	9.12000E-01

RUN=4592 TOP AIR PT = 1909.70  
TPC =1010.00 DEG-R MINF = 8.068  
TI = 539.00 DEG-R R/FT = 7.91685E+06  
TO =1425.00 DEG-R  
SQROCK= .0617 ALPHA=30.000  
MODEL=31V0 PHI= 0.000  
HS= 1.20675E-01 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/TO
1	1.30	6.43952E-02	5.33625E-01	6.19248E-01	1.18998E+00	9.12000E-01
2	4.50	3.46114E-02	2.86815E-01	6.19248E-01	1.18998E+00	9.12000E-01
3	8.10	2.57978E-02	2.13779E-01	6.19248E-01	1.18998E+00	9.12000E-01

RUN=4593 TOP AIR PT = 1909.70  
 TPC = 860.00 DEG-R MINF = 8.068  
 TI = 539.00 DEG-R R/FT = 8.01028E+06  
 TO = 1415.00 DEG-R  
 SQROCK= .0604 ALPHA=30.000  
 MODEL=31V0 PHI= 0.000  
 HS= 1.20895E-01 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/TO
1	1.30	3.11920E-02	2.58008E-01	4.27157E-01	5.88814E-01	9.12000E-01
2	2.50	2.24929E-02	1.86052E-01	4.27157E-01	5.88814E-01	9.12000E-01
3	3.90	1.80087E-02	1.48961E-01	4.27157E-01	5.88814E-01	9.12000E-01
4	6.40	1.40580E-02	1.16283E-01	4.27157E-01	5.88814E-01	9.12000E-01

RUN=4594 TOP AIR PT = 166.70  
TPC = 760.00 DEG-R MINF = 7.752  
TI = 536.00 DEG-R R/FT = 9.92782E+05  
TO = 1215.00 DEG-R  
SQROCK= .0586 ALPHA=30.000  
MODEL=41 PHI= 0.000  
HS= 3.84766E-02 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/TO
1	5.60	1.27349E-02	3.30978E-01	3.91554E-01	5.14271E-01	9.12000E-01
2	12.00	8.69959E-03	2.26101E-01	3.91554E-01	5.14271E-01	9.12000E-01
3	15.20	7.72979E-03	2.00896E-01	3.91554E-01	5.14271E-01	9.12000E-01

RUN=4595 TOP AIR PT = 644.70  
 TPC = 860.00 DEG-R MINF = 7.938  
 TI = 536.00 DEG-R R/FT = 3.07927E+06  
 TO = 1340.00 DEG-R  
 SQROCK= .0604 ALPHA=30.000  
 MODEL=41 PHI= 0.000  
 HS= 7.24562E-02 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/TO
1	1.40	3.54967E-02	4.89905E-01	4.72248E-01	6.95368E-01	9.12000E-01
2	3.10	2.38545E-02	3.29227E-01	4.72248E-01	6.95368E-01	9.12000E-01
3	5.80	1.74396E-02	2.40692E-01	4.72248E-01	6.95368E-01	9.12000E-01
4	9.80	1.34165E-02	1.85167E-01	4.72248E-01	6.95368E-01	9.12000E-01
5	15.40	1.07026E-02	1.47712E-01	4.72248E-01	6.95368E-01	9.12000E-01

RUN=4596 TOP AIR PT = 1394.7J  
 TPC =1010.00 DEG-R MINF = 8.032  
 TI = 534.00 DEG-R R/FT = 6.01978E+06  
 TO =1400.00 DEG-R  
 SQROCK= .0617 ALPHA=30.000  
 MODEL=41 PHI= 0.000  
 HS= 1.03993E-01 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/TO
1	4.30	3.84509E-02	3.69744E-01	6.40819E-01	1.29228E+00	9.12000E-01
2	5.10	3.53066E-02	3.39509E-01	6.40819E-01	1.29228E+00	9.12000E-01
3	7.00	3.01365E-02	2.89792E-01	6.40819E-01	1.29228E+00	9.12000E-01
4	9.80	2.54700E-02	2.44919E-01	6.40819E-01	1.29228E+00	9.12000E-01
5	13.50	2.17007E-02	2.08674E-01	6.40819E-01	1.29228E+00	9.12000E-01

RUN=4597 TOP AIR PT = 177.70  
 TPC = 660.00 DEG-R MINF = 7.761  
 TI = 537.00 DEG-R R/FT = 1.04075E+06  
 TO = 1225.00 DEG-R  
 SQROCK = .0546 ALPHA=30.000  
 MODEL=41 PHI= 0.000  
 HS= 3.95407E-02 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T,SEC	H,BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/TO
1	1.30	1.08549E-02	2.74525E-01	2.11996E-01	2.26676E-01	9.12000E-01
2	3.70	6.43424E-03	1.62725E-01	2.11996E-01	2.26676E-01	9.12000E-01
3	6.40	4.89225E-03	1.23727E-01	2.11996E-01	2.26676E-01	9.12000E-01
4	8.60	4.22036E-03	1.06735E-01	2.11996E-01	2.26676E-01	9.12000E-01
5	11.10	3.71481E-03	9.39491E-02	2.11996E-01	2.26676E-01	9.12000E-01
6	14.80	3.21712E-03	8.13623E-02	2.11996E-01	2.26676E-01	9.12000E-01

RUN=4598 TOP AIR PT = 159.70  
 TPC = 760.00 DEG-R MINF = 7.745  
 TI = 536.00 DEG-R R/FT = 9.20892E+05  
 TO = 1240.00 DEG-R  
 SQRCK = .0586 ALPHA=30.000  
 MODEL=41V30 PHI= 0.000  
 HS= 3.78126E-02 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/TO
1	3.30	1.56458E-02	4.13771E-01	3.76547E-01	4.85017E-01	9.12000E-01
2	8.10	9.98647E-03	2.64104E-01	3.76547E-01	4.85017E-01	9.12000E-01
3	9.80	9.07907E-03	2.40107E-01	3.76547E-01	4.85017E-01	9.12000E-01
4	12.00	8.20472E-03	2.16984E-01	3.76547E-01	4.85017E-01	9.12000E-01
5	18.90	6.53768E-03	1.72897E-01	3.76547E-01	4.85017E-01	9.12000E-01
6	20.90	6.21701E-03	1.64416E-01	3.76547E-01	4.85017E-01	9.12000E-01



RUN=4599 TOP AIR PT = 649.70  
 TPC = 910.00 DEG-R MINF = 7.939  
 TI = 535.00 DEG-R R/FT = 3.02640E+06  
 TO = 1360.00 DEG-R  
 SQROCK = .0613 ALPHA = 30.000  
 MODEL = 41V30 PHI = 0.000  
 HS = 7.27615E-02 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/TO
1	2.70	3.21721E-02	4.42158E-01	5.31674E-01	8.62384E-01	9.12000E-01
2	3.90	2.67688E-02	3.67898E-01	5.31674E-01	8.62384E-01	9.12000E-01
3	8.00	1.86903E-02	2.56871E-01	5.31674E-01	8.62384E-01	9.12000E-01
4	9.70	1.69736E-02	2.33278E-01	5.31674E-01	8.62384E-01	9.12000E-01
5	13.10	1.46058E-02	2.00735E-01	5.31674E-01	8.62384E-01	9.12000E-01

RUN=4600 TOP AIR PT = 177.70  
 TPC = 660.00 DEG-R MINF = 7.761  
 TI = 536.00 DEG-R R/FT = 9.86084E+05  
 TO = 1265.00 DEG-R  
 SQROCK = .0546 ALPHA=30.000  
 MODEL=41V30 PHI= 0.000  
 HS= 3.96754E-02 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/TO
1	2.00	8.19498E-03	2.06551E-01	2.00751E-01	2.12261E-01	9.12000E-01
2	2.50	7.32981E-03	1.84745E-01	2.00751E-01	2.12261E-01	9.12000E-01
3	3.30	6.37978E-03	1.60799E-01	2.00751E-01	2.12261E-01	9.12000E-01
4	4.30	5.58893E-03	1.40866E-01	2.00751E-01	2.12261E-01	9.12000E-01
5	7.80	4.14969E-03	1.04591E-01	2.00751E-01	2.12261E-01	9.12000E-01
6	11.00	3.49435E-03	8.80735E-02	2.00751E-01	2.12261E-01	9.12000E-01
7	15.40	2.95327E-03	7.44357E-02	2.00751E-01	2.12261E-01	9.12000E-01

RUN=4601	TOP	AIR	PT = 664.70
TPC	= 760.00	DEG-R	MINF = 7.942
TI	= 536.00	DEG-R	R/FT = 3.01918E+06
TO	=1380.00	DEG-R	
SQROCK=	.0586		ALPHA=30.000
MODEL=	41V30		PHI= 0.000
HS=	7.37455E-02	BTU/FT.SQ-SEC-DEG-R	

CONTOUR	T,SEC	H,BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/TO
1	1.30	1.89290E-02	2.56680E-01	3.10009E-01	3.68301E-01	9.12000E-01
2	1.70	1.65530E-02	2.24460E-01	3.10009E-01	3.68301E-01	9.12000E-01
3	2.20	1.45509E-02	1.97312E-01	3.10009E-01	3.68301E-01	9.12000E-01
4	3.20	1.20649E-02	1.63602E-01	3.10009E-01	3.68301E-01	9.12000E-01
5	5.00	9.65195E-03	1.30882E-01	3.10009E-01	3.68301E-01	9.12000E-01
6	9.80	6.89425E-03	9.34870E-02	3.10009E-01	3.68301E-01	9.12000E-01

RUN=4556 SIDE AIR PT = 171.70  
TPC = 710.00 DEG-R MINF = 7.756  
TI = 536.00 DEG-R R/FT = 9.11711E+05  
TO = 1300.00 DEG-R  
SQROCK= .0574 ALPHA=35.000  
MODEL=22 PHI= 0.000  
HS= 3.92274E-02 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT. SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/TO
1	1.30	1.57721E-02	4.02068E-01	2.74448E-01	3.13292E-01	9.00000E-01
2	3.80	9.22506E-03	2.35169E-01	2.74448E-01	3.13292E-01	9.00000E-01
3	6.00	7.34151E-03	1.87153E-01	2.74448E-01	3.13292E-01	9.00000E-01
4	8.70	6.09679E-03	1.55422E-01	2.74448E-01	3.13292E-01	9.00000E-01
5	12.20	5.14851E-03	1.31248E-01	2.74448E-01	3.13292E-01	9.00000E-01
6	18.60	4.16970E-03	1.06296E-01	2.74448E-01	3.13292E-01	9.00000E-01

RUN=4557 SIDE AIR PT = 171.70  
TPC = 760.00 DEG-R MINF = 7.756  
TI = 533.00 DEG-R R/FT = 9.41790E+05  
TO = 1275.00 DEG-R  
SQROCK= .0586 ALPHA=35.000  
MODEL=41 PHI= 0.000  
HS= 3.91988E-02 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/TO
1	1.30	2.42335E-02	6.18221E-01	3.69406E-01	4.71510E-01	9.00000E-01
2	10.70	8.44688E-03	2.15488E-01	3.69406E-01	4.71510E-01	9.00000E-01
3	13.50	7.52006E-03	1.91844E-01	3.69406E-01	4.71510E-01	9.00000E-01

ORIGINAL PAGE IS  
OF POOR QUALITY

RUN=4558 SIDE AIR PT = 1449.70  
TPC = 960.00 DEG-R MINF = 8.037  
TI = 534.00 DEG-R R/FT = 6.13873E+06  
TO = 1415.00 DEG-R  
SQROCK= .0617 ALPHA=35.000  
MODEL=31 PHI= 0.000  
HS= 1.06087E-01 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/TO
1	1.30	5.48426E-02	5.16959E-01	5.76065E-01	1.01346E+00	9.00000E-01
2	3.80	3.20773E-02	3.02368E-01	5.76065E-01	1.01346E+00	9.00000E-01
3	5.90	2.57433E-02	2.42662E-01	5.76065E-01	1.01346E+00	9.00000E-01
4	7.80	2.23894E-02	2.11048E-01	5.76065E-01	1.01346E+00	9.00000E-01
5	10.00	1.97738E-02	1.86392E-01	5.76065E-01	1.01346E+00	9.00000E-01
6	11.80	1.82032E-02	1.71588E-01	5.76065E-01	1.01346E+00	9.00000E-01
7	13.20	1.72109E-02	1.62234E-01	5.76065E-01	1.01346E+00	9.00000E-01

RUN=4561 SIDE AIR PT = 160.70  
TPC = 635.00 DEG-R MINF = 7.746  
TI = 538.00 DEG-R R/FT = 8.84160E+05  
TO = 1275.00 DEG-R  
SQROCK= .0537 ALPHA=35.000  
MODEL=31 PHI= 0.000  
HS= 3.78795E-02 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T,SEC	H,BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/TO
1	8.10	3.05024E-03	8.05248E-02	1.59147E-01	1.61660E-01	9.00000E-01
2	17.00	2.10548E-03	5.55838E-02	1.59147E-01	1.61660E-01	9.00000E-01

RUN=4562 SIDE AIR PT = 1394.70  
TPC = 760.00 DEG-R MINF = 8.032  
TI = 541.00 DEG-R R/FT = 5.84493E+06  
TO = 1425.00 DEG-R  
SQROCK= .0586 ALPHA=35.000  
MODET=22 PHI= 0.000  
HS= 1.04489E-01 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/TO
1	4.30	9.75136E-03	9.33239E-02	2.95347E-01	3.45066E-01	9.00000E-01
2	6.70	7.81200E-03	7.47635E-02	2.95347E-01	3.45066E-01	9.00000E-01
3	9.40	6.59532E-03	6.31195E-02	2.95347E-01	3.45066E-01	9.00000E-01
4	11.90	5.86173E-03	5.60988E-02	2.95347E-01	3.45066E-01	9.00000E-01



RUN=4564    SIDE    AIR    PT = 659.70  
 TPC    = 635.00 DEG-R    MINF = 7.941  
 TI    = 539.00 DEG-R    R/FT = 2.96151E+06  
 TO    =1390.00 DEG-R  
 SQROCK= .0537    ALPHA=35.000  
 MODEL=22    PHI= 0.000  
 HS= 7.32464E-02 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/TO
1	3.30	3.95864E-03	5.40456E-02	1.34831E-01	1.33915E-01	9.00000E-01
2	4.10	3.55150E-03	4.84870E-02	1.34831E-01	1.33915E-01	9.00000E-01
3	5.80	2.98600E-03	4.07665E-02	1.34831E-01	1.33915E-01	9.00000E-01
4	8.50	2.46657E-03	3.36750E-02	1.34831E-01	1.33915E-01	9.00000E-01
5	12.50	2.03399E-03	2.77691E-02	1.34831E-01	1.33915E-01	9.00000E-01
6	15.30	1.83848E-03	2.50999E-02	1.34831E-01	1.33915E-01	9.00000E-01

RUN=4565 SIDE AIR PT = 1469.70  
TPC = 810.00 DEG-R MINF = 8.038  
TI = 538.00 DEG-R R/FT = 6.07688E+06  
TO = 1435.00 DEG-R  
SQROCK= .0595 ALPHA=35.000  
MODEL=31 PHI= 0.000  
HS= 1.07168E-01 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/TO
1	9.90	8.62124E-03	8.04462E-02	3.60982E-01	4.55901E-01	9.00000E-01
2	15.20	6.95770E-03	6.49234E-02	3.60982E-01	4.55901E-01	9.00000E-01

266

12  
11  
10  
9  
8  
7  
6  
5  
4  
3

RUN=4569 SIDE AIR PT = 794.70  
TPC = 810.00 DEG-R MINF = 7.964  
TI = 539.00 DEG-R R/FT = 3.54256E+06  
T0 = 1390.00 DEG-R  
SQROCK= .0595 ALPHA=30.000  
MODEL=22 PHI= 0.000  
HS= 8.01982E-02 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/T0
1	10.60	9.00671E-03	1.12306E-01	3.80618E-01	4.92835E-01	9.00000E-01
2	14.30	7.75445E-03	9.66910E-02	3.80618E-01	4.92835E-01	9.00000E-01

RUN=4570 SIDE AIR PT = 1884.70  
TPC = 860.00 DEG-R MINF = 8.067  
TI = 542.00 DEG-R R/FT = 7.59384E+06  
TO = 1450.00 DEG-R  
SQROCK= .0604 ALPHA=30.000  
MODEL=31 PHI= 0.000  
HS= 1.20444E-01 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/TO
1	6.20	1.37365E-02	1.14049E-01	4.16776E-01	5.66283E-01	9.00000E-01
2	11.00	1.03127E-02	8.56227E-02	4.16776E-01	5.66283E-01	9.00000E-01

RUN=4573 SIDE AIR PT = 167.70  
TPC = 760.00 DEG-R MINF = 7.753  
TI = 544.00 DEG-R R/FT = 1.00542E+06  
TO = 1210.00 DEG-R  
SQROCK= .0586 ALPHA=30.000  
MODEL=31V0 PHI= 0.000  
HS= 3.85647E-02 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/TO
1	2.20	2.06959E-02	5.36653E-01	3.96330E-01	5.23839E-01	9.00000E-01
2	4.00	1.53485E-02	3.97993E-01	3.96330E-01	5.23839E-01	9.00000E-01
3	5.10	1.35928E-02	3.52468E-01	3.96330E-01	5.23839E-01	9.00000E-01
4	7.00	1.16024E-02	3.00854E-01	3.96330E-01	5.23839E-01	9.00000E-01

RUN=4584 SIDE AIR PT = 1419.70  
TPC = 810.00 DEG-R MINF = 8.034  
TI = 542.00 DEG-R R/FT = 5.80985E+06  
TO = 1445.00 DEG-R  
SQROCK= .0595 ALPHA=30.000  
MODEL=31V30 PHI= 0.000  
HS= 1.05521E-01 BTU/FT.SQ-SFC-DEG-R

CONTOUR	T, SEC	H, BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/TO
1	5.40	1.13177E-02	1.07256E-01	3.53329E-01	4.42016E-01	9.00000E-01
2	6.60	1.02372E-02	9.70163E-02	3.53329E-01	4.42016E-01	9.00000E-01
3	9.30	8.62409E-03	8.17288E-02	3.53329E-01	4.42016E-01	9.00000E-01
4	13.90	7.05419E-03	6.68512E-02	3.53329E-01	4.42016E-01	9.00000E-01

RUN=4586 SIDE AIR PT = 644.70  
TPC = 910.00 DEG-R MINF = 7.938  
TI = 542.00 DEG-R R/FT = 3.00399E+06  
TO = 1360.00 DEG-R  
SQROCK= .0613 ALPHA=30.000  
MODEL=31V0 PHI= 0.000  
HS= 7.25010E-02 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/TO
1	2.30	3.58705E-02	4.94759E-01	5.39589E-01	8.87443E-01	9.00000E-01
2	3.40	2.95027E-02	4.06928E-01	5.39589E-01	8.87443E-01	9.00000E-01
3	4.60	2.53643E-02	3.49847E-01	5.39589E-01	8.87443E-01	9.00000E-01

ORIGINAL PAGE IS  
OF POOR QUALITY

RUN=4588 SIDE AIR PT = 649.70  
TPC = 710.00 DEG-R MINF = 7.939  
TI = 542.00 DEG-R R/FT = 3.00792E+06  
TO = 1365.00 DEG-R  
SQROCK= .0574 ALPHA=30.000  
MODEL=31V0 PHI= 0.000  
HS= 7.27930E-02 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/TO
1	1.30	1.36229E-02	1.87146E-01	2.44720E-01	2.70601E-01	9.00000E-01
2	6.00	6.34112E-03	8.71116E-02	2.44720E-01	2.70601E-01	9.00000E-01
3	9.90	4.93655E-03	6.78163E-02	2.44720E-01	2.70601E-01	9.00000E-01
4	13.70	4.19644E-03	5.76489E-02	2.44720E-01	2.70601E-01	9.00000E-01



RUN=4593 SIDE AIR PT = 1909.70  
TPC = 860.00 DEG-R MINF = 8.068  
TI = 539.00 DEG-R R/FT = 8.01028E+06  
TO = 1415.00 DEG-R  
SQRDCK= .0604 ALPHA=30.000  
MODEL=31V0 PHI= 0.000  
HS= 1.20895E-01 BTU/FT.SQ-SEC-DEG-R

CONTOUR	T, SEC	H, BTU/FT.SQ-SEC-DEG-R	H/HS	T-BAR	BETA	TAW/TO
1	9.20	1.21650E-02	1.00624E-01	4.37032E-01	6.10899E-01	9.00000E-01